POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT

Reporting Date: 23-Aug-14 Till now the maximum generation is: 7418 MW 21:00 Hrs on 18-Jul-14 Generation & Demand 22-Aug-14 Today's Actual Min Gen. & Probable Gen. & Demand The Summary of Yesterday's (5082.0 12:00 Min. Gen. at Day Peak Generation Hour Evening Peak Generation: E.P. Demand (at gen end): 6724.0 MW Hour 21:00 Max Generation 6690 MW 6900 MW 6724.0 MW Hour: 21:00 Max Demand Maximum Generation 6724.0 MW Hour : 21:00 Shortage 210 MW Total Gen. (MKWH) 133.8 System L/ Factor 78.37% Load Shed 191 MW EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR Export from East grid to West grid :- Maximum MW 10:00 7.867 MKWHR. -160 at Energy Import from West grid to East grid :- Maximum MW at Energy MKWHR Water Level of Kaptai Lake at 6:00 A M on 23-Aug-14 87.64 Ft.(MSL) Actual : Ft.(MSL) Rule curve 96.04 Gas Consumed: Total 902.71 MMCFD. Oil Consumed (PDB): HSD Liter FO Liter Cost of the Consumed Fuel (PDB+Pvt) : Gas Tk74,285,908 Coal Tk15,546,485 : Tk373,653,641 Total: Tk463,486,034 Load Shedding & Other Information Area Yesterday Today Estimated Demand(s/s end) Estimated Shedding (s/s end) Rates of Shedding MW MW MW (On Estimated Demand) Dhaka 0:00 2500 54 Chittagong Area 0:00 655 26 0:00 718 30 Khulna Area Rajshahi Area 0:00 690 23 Comilla Area 0:00 475 16 12 Mymensingh Area 0:00 390 Sylhet Area 0:00 12 320 Barisal Area 0:00 142 5 400 13 Rangpur Area 0:00 Total 6290 191 0 Information of the Generating machines under shut down Forced Shut- Down Planned Shut- Down 1) Haripur GT: Unit-3 (18/06/2009) 1) Ghorasal ST: Unit-6 (18/07/2010) 2) Megnaghat CCPP (21/04/2014) 3) Svihet 150 MW GT (28/07/14) 4) Barapukuria ST: Unit-1(16/08/2014) Additional Information of Machines, lines, Interruption / Forced Load shed etc. Description Forced load shaded / Interrupted Areas a) Dohazari-Cox'sbazar 132 kV Ckt-2 tripped at 10:52 from both end showing Dist. ABC,3-phase,Z1,E/F relays and was switched on at 12:04. b) Siddirgonj-Siddirgonj Desh energy 132 kV Ckt tripped at 14:47 due to PT burst at Siddirganj Desh energy end and showing O/C at Siddirganj end. c) Siddirganj-Maniknagar 230 kV Ckt-1 & 2 tripped at 14:20 showing O/C, E/F relay at Maniknagar end and Power interruption occurred (about 130 MW) under Maniknagor, Narinda S/S areas from 14:20 to 14:35. was switched on at 14:35. d) Rangpur 132/33 kV T1 transformer was shut down from 15:40 to 17:05 due to project work. e) Rangpur 132/33 kV T2 transformer was shut down from 17:35 to 18:40 due to project work. f) Rajshahi 132/33 kV T3 transformer was shut down from 19:17 to 19:41 due to project work. g) Rajshahi 132/33 kV T1 transformer was shut down at 06:30(23/08/2014) due to 33 kV bus conductor change. h) Ullon 132/33 kV T1 & T2 transformer were shut down at 07:19 (23/08/2014) due to 914 CB replacement work Sub Divisional Engineer **Executive Engineer** Superintendent Engineer Network Operation Division **Network Operation Division** Load Despatch Circle