

### Load Shedding & Other Information

### Information of the Generating machines under maintenance

**Additional Information of Machines. lines. Interruption / Forced Load shed etc**

Description	Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday.	So about 540 MW (19:00) of load shed was imposed over the whole area of the national grid.
b) Due to gas limitation, Siddhirganj (190 MW), RPCL (175 MW), Raozan (360 MW), NEPC (95MW) and Haripur Power Ltd. (360 MW) were limited to 150 MW, 95 MW, 240 MW 50 MW and 333 MW respectively.	
c) Due to gas limitation, Shahjibazar -2, 3 ,4 & 5, Haripur SBU GT-1 & 3 (66 MW) were under shut down.	
d) Ashuganj unit -1 was forced shut down at 11:28 due to vacuum pump problem.	
e) After maintenance, Tongi GT was synchronized at 17:28.	
f) Raozan unit -1 tripped at 03:16 (07/06/09) due to gas pressure abnormal and super heater tube leakage.	
g) Ishurdi 132/33 KV T2 transformer rwas under shut down from 10:36 to 11:14 due to red-hot maintenance of Y-phase bus isolator.	Partial power interruption occurred (04 MW) under Ishurdi S/S areas from 10:36 to 11:14.
h) Comilla (N) - Feni 132 KV line -1 & 2 tripped at 12:55 from both end showing at Feni end 'DIST Z1 R-phase' & 'DIST ABC' and at Comilla (N) end 'SOTF' & 'DIST Z3' respectively. At the same time, Comilla (N) -Comilla (S) 132 KV line from Comilla (N) end showing 'Directional O/C' and Chandpur - Chowmuhani 132 KV line -1 & 2 from Chandpur end showing ' Directional O/C' also tripped. Power supply was normalized at Feni and Chowmuhani S/S areas by closing of Feni - Hathazari 132 KV line -1 & 2 at 13:00 and Comilla (S) by switching on Comilla (N) - Comilla (S) 132 KV line at 13:13.Comilla (N) - Feni 132 KV line -1 & 2 and Chandpur - Chowmuhani 132 KV line -1 & 2 were switched on at 13:02, 13:24 , 13:33 and 13:34 respectively.	Power interruption occurred under Comilla (S) (about 55 MW), Feni (about 22 MW) and Chowmuhani (about 25 MW) S/S areas from 12:55 to 13:13, 12:55 to 13:00 and 12:55 to 13:00 respectively.
i) Aminbazar 230/132 KV T03 transformer was under shut down from 13:56 to 15:14 due to fire fighting action test.	
j) Chatak 132/33 KV T2 transformer tripped at 20:15 showing ' O/C at A-phase' due to 33 KV SPPM feeder fault and was switched on at 20:20.	
k) Siddhirganj 132/33 KV T1 transformer tripped at 00:58 (07/06/09) showing 'Over current' and T2 deloaded due to tripping of 33 KV breaker of DPDC. They were switched on at 01:06(07/06/09).	Power interruption occurred (86 MW) under Siddhirganj S/S areas from 00:58 (07/06/09) to 01:06 (07/06/09).  Due to generation shortage and MVAR problem , about 100 MW (09:00) of load shed has been running since morning (07/06/09) over the whole area (except Sylhet) of the national grid.

Deputy / Asstt. Manager  
Load Despatch Division

Manager  
Load Despatch Division

Deputy General Manager  
Load Despatch Circle