POWER GRID COMPANY OF BANGLADESH LTD.
NATIONAL LOAD DESPATCH CENTER
DAILY REPORT QF-LDC-08 Page -1 Reporting Date : 6-Sep-14 Till now the maximum generation is :The Summary of Yesterday's (
Day Peak Generation :
Evening Peak Generation :
E.P. Demand (at gen end) : 7418 MW 21:00 Hrs
 Hrs
 on
 18-Jul-14

 Today's Actual Min Gen. & Probable Gen. & D

 Min. Gen. at
 7:00
 4997

 Max Generation
 :
 6655
 5-Sep-14 5146.0 6535.0 Generation & Demand
MW
MW
MW Hour Hour Hour MW MW MW MW 21:00 21:00 6535.0 Max Demand 6800 Maximum Generation 6562.0 MW Hour: 22:00 Shortage 145 Total Gen. (MKWH) 135.8 78.37% Load Shed MW System L/ Factor : EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR Export from East grid to West grid :- Maximum -340 Energy 7.867 Import from West grid to East grid :- Maximum -Water Level of Kaptai Lake at 6:00 A M on MW Energy MKWHR 6-Sep-14 Actual : 87.64 Ft.(MSL) 100.15 Ft.(MSL) Gas Consumed : Total Oil Consumed (PDB) HSD Liter FO Liter Cost of the Consumed Fuel (PDB+Pvt) : Gas Tk63,067,478 Coal Tk14,062,146 Oil : Tk455,294,445 Total: Tk532,424,069 Load Shedding & Other Information Area Yesterday Today Estimated Demand(s/s end) Estimated Shedding (s/s end) Rates of Shedding MW On Estimated Demand) Dhaka Chittagong Area 0:00 629 24 26 25 18 0:00 687 667 460 380 Rajshahi Area 0:00 Comilla Area 14 Mymensingh Area 0:00 298 138 Sylhet Area 0:00 Barisal Area 0:00 Rangpur Area 0:00 389 15 Total 6006 128 Information of the Generating machines under shut down. Planned Shut- Down Forced Shut- Down 1) Ghorasal ST: Unit-6 (18/07/2010) 2) Megnaghat CCPP (21/04/2014) 3) Ghorasal ST: Unit -3 (19/08/2014) 4) Ashuganj ST: Unit-1(23/08/2014) 5) Ashuganj CCPP: GT-2(22/08/2014) 6) Ashuganj ST :Unit-2 (03/09/2014) 7) Haripur 412 ST (06/09/2014) 8) Rangpur (05/09/2014) Additional Information of Machines. lines. Interruption / Forced Load shed etc. Forced load shaded / Interrupted Areas

Power interruption occurred (about 40 MW) under Tangail S/S areas a) Tangail 33 kV bus was under shut down from 08:42 to 12:15 due to development work from 08:42 to 12:15. b) B.Baria 70 MW was under shut down from 09:55 to 13:12 due to CT test by PDB energy audit unit.
c) Shyampur 132/33 kV T1 transformer was under shut down from 11:51 to 13:12 due to maintenance work.
d) Rampura-Ullon-Moghbazar (Former Rampura-Moghbazar Ckt-2) 132 kV Ckt switched on at 11:55.) Matuail-Maniknagar 132 kV Ckt tripped at 15:15 showing dist.relay and was switched on at 18:04. Hanpur-Ullion 132 kV Ckt was switched on at 21:10.

All Armour State Ckt was switched on at 21:10.

After maintenance Seralganj 210 MW synchronized at 23:09.

Meghnaghat CCPP (Summit) 210 MW was under shut down from 00:18 to 06:29 (06/09/2014) due to project work.

Meghnaghat S/S-Summit Meghnaghat P/S 230 kV Ckt was under shut down from 01:07 to 03:49 (06/09/2014) due to Haripur EGCB 412 ST tripped at 02:07 (06/09/2014) due to HRSG tripping.
) Tangail 132/33 kV T2 tranformer was under shut down from 07:21 to 09:15 (06/09/2014) due to new feeder connection. Power interruption occurred (about 40 MW) under Tangail S/S areas from 07:21 to 09:15 (06/09/2014). Tangail 22 MW was under shut down from 07:10 to 09:35 (06/09/2014) due maintenance work at Tangail 13:233 kV S/S.

Sub Divisional Engineer Executive Engineer

twork Operation Division Network Operation Division Superintendent Engineer Load Despatch Circle