

QF-LDC-08  
Page -1

Description	Forced load shaded / Interrupted Areas
<p>a) There was generation shortage in the evening peak hour yesterday.</p> <p>b) Due to low gas pressure RPCL (210 MW) was limited to 108 MW.</p> <p>c) Ashuganj #5 tripped at 12:07 due to interface turbine generator event recorder high speed and was synchronized at 16:41.</p> <p>d) Ashuganj #3 tripped at 14:17 due to boiler drum level low and was synchronized at 19:26.</p> <p>e) Khulna-110 MW &amp; 60 MW was shut down at 22:20 &amp; 22:50 due to water treatment plant problem.</p> <p>f) Hathazari-Kaptai 132kV line-1 &amp; 2 was under shut down from 08:30 to 15:47 due to annual maint.</p> <p>g) Hathazari-Feni 132kV line-1 was under shut down from 08:36 to 17:03 due to annual maint.</p> <p>h) Madanhat-Khulsi 132kV line-1 was under shut down from 09:15 to 15:46 due to annual maint.</p> <p>i) Netrokona-Mymensing 132kV line-1 was under shut down from 08:35 to 13:53 due to annual maint.</p> <p>j) Chawmahoni 132/33 T3 transformer tripped at 22:39 showing E/F relays.</p> <p>k) Barishal-Bhandaria 132 kV line- was shut down at 07:30(24/01/11) due to annual maint.</p> <p>l) Barapukuria 230/132 kV T1 transformer was under shut down from 10:25 to 18:00 due to annual maint.</p>	<p>So about 445 MW (21:00) of load shed was imposed over the whole areas of the national grid .</p> <p>Power interruption occurred (about 10 MW) under Barapukuria S/S areas from 22:39 to 23:11.</p> <p>Due to generation shortage, about 150 MW (09:00) of load shed has been running since morning (24/01/11) over the whole area (except Sylhet) of the national grid.</p>

Deputy / Asstt. Manager	Manager	Deputy General Manager
Network Operation Division	Network Operation Division	Load Despatch Circle