POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT

			DAI	LT REPORT				Reporting Date :	16-Sep-14	Page -1	
Till now the max	vimum generatio	on is · -	7418 MW			21:00	Hrs on	18-Jul-14	10-3ep-14		
The Summary of		15-Sep-14	Generation & Demand			21.00		Min Gen. & Proba	bla Can & Da	mand	
				Llava i		0.00	Min. Gen. at				
Day Peak Generat		5584.0	MW	Hour :		9:00		7:00	5445	MW	
Evening Peak Gen		6289.0	MW	Hour :		18:30	Max Generation	:	6225	MW	
E.P. Demand (at g	,	6900.0	MW	Hour :		18:30	Max Demand	:	7000	MW	
Maximum Genera	tion :	6426.0	MW	Hour :		1:00	Shortage	:	775	MW	
Total Gen. (MKWF	H) :	137.0	System L/ Factor :			78.37%	Load Shed	:	683	MW	
		EXF	PORT / IMPORT THROUG	SH EAST-WEST INTE	RCONNEC	TOR					
Export from East g	rid to West grid :-	Maximum	MW at	17:00	Energy	7.867	MKWHR.				
Import from West	grid to East grid :-	Maximum	-			MW at		Energy	-	MKWHR.	
		Water Level of Kaptai L	ake at 6:00 A M on			16-Sep-14					
Actual :	87.64	Ft.(MSL),		Ru	le curve :	102.45	Ft.(MSL)				
Gas Consumed :	Total	805.21	MMCFD.			Oil Consumed (I	PDB) :				
							,	HSD :		Liter	
								FO :		Liter	
								10 .		Eller	
Cost of the Consu	mad Fuel (DDB - F	hut) · Coo ·	т	CO 7CO 1EE							
Cost of the Consur				62,769,155		01	TI-5 40 070 000	Tatal	TI-047 450 400	- -	
		Coal :	16	:12,304,379		Oil	: Tk542,076,929	Total :	Tk617,150,463	5	
		Load Shedding & Oth	er Information								
Area Yesterday						Today					
		Estimated Demand(s/s end)			Estimated Shedding (s/s end) Rates of Shedding				dding		
	MW			MW				MW	(On Estimated	Demand)	
Dhaka	149	(17:50-01:30)		2405				203	-		
Chittagong Area	72	(17:50-01:30)		645				84	_		
									-		
Khulna Area	86	(17:50-01:30)		705				94	-		
Rajshahi Area	74	(17:50-01:30)		687				91	-		
Comilla Area	53	(17:50-01:30)		475				63	-		
Mymensingh Area	39	(17:50-01:30)		397				53	-		
Sylhet Area	21	,		302				22			
		(17:50-01:30)							-		
Barisal Area	13	(17:50-01:30)		143				19	-		
Rangpur Area	43	(17:50-01:30)		405				54	-		
	-										
Total	550			6164				683			
	Planned Shut- Down 1) Haripur GT: Unit-3 (18/06/2009)					Forced Shut- Down 1) Ghorasal ST: Unit-6 (18/07/2010) 2) 2) Megnaghat CCPP (21/04/2014) 3) 3) Ashuganj ST: Unit-1(23/08/2014) 4) 4) Ashuganj CCPP: GT-2(22/08/2014) 5) 5) Barisal GT: Unit-2 (16/08/2014) 6) 6) Meghnaghat CCPP (Summit) GT-1 (30/08/2014)					
						7) Ghorasal ST: Unit-1 (11/09/2014)					
Additional Information of Machines. lines. Interruption / Forced Load shed etc											
	Description					Forced load cha	ded / Interruptor	d Areas			
a) There was generation shortage in the evening peak hour yesterday.						Forced load shaded / Interrupted Areas So about 550 MW (18:30) of load shed was imposed over the whole areas					
a, more the generation onortage in the overling pour hour yearendary.						of the national grid.					
b) Madanaghat - Khulshi 132 kV Ckt-1 tripped at 11:53 from both end showing earth fault relay at Madanaghat end at Khulshi end and was switched on at 14:58.											
c) Halishahar - Khulshi 132 kV Ckt-1 tripped at 12:08 from both end showing distance relay at Halishahar end and						earth fault relay					
at Khulshi end and was switched on at 12:34. d) Hasnabad 230/132 kV T2 transformer was shut down from 11:13 to 16:57 due to annunciator changing.											
e) After maintenance Baghabari GT 100 MW was synchronized at 12:11 and again tripped at 13:02 due to oil tube f) Bogra - Barapukuria 230 kV Ckt-2 tripped at 14:16 from Barapukuria end and was switched on at 15:12.						leakage.					
g) Hathazari - Kaptai 132 kV Ckt-2 tripped at 00:12 from both end showing earth fault relay at Hathazari end and dis Kaptai end and was switched on at 00:21 (16/09/2014)						stance relay at					
h) Kaptai - Madanaghat 132 kV Ckt-1& 2 tripped at 01:23 from both end showing distance relay and were switched respectively.						on at 08:15 & 08	:16				
i) Madanaghat - Chandraghona 132 kV Ckt tripped at 01:23 from both end showing distance relay and was switched on i) Chandraghona - Kaptai 132 kV Ckt tripped at 01:20 from Kaptai end showing distance relay and was switched on at 0 k) Naogaon 132/33 kV T2 transformer shut down at 06:25 (16/09/2014) due to breaker replacement.											
к) Naogaon 132/33	3 KV 12 transform	er shut down at 06:25 (16/09/2014) due to break	er replacement.							
Sub Divisional Engineer Executive Engineer									dent Enginee		
Network Operation Division Network Operation Division								Load De	spatch Circle		

QF-LDC-08 Page -1