

Till now the maximum generation is :-

7418 MW

21:00

Hrs on 18-Jul-14

Reporting Date : 26-Sep-14

The Summary of Yesterday's (25-Sep-14		Generation & Demand		Today's Actual Min Gen. & Probable Gen. & Demand	
Day Peak Generation	: 5296.0	MW	Hour : 12:00	Min. Gen. at 7:00	4623 MW
Evening Peak Generation	: 6183.0	MW	Hour : 21:00	Max Generation	: 6440 MW
E.P. Demand (at gen end)	: 6700.0	MW	Hour : 21:00	Max Demand	: 6700 MW
Maximum Generation	: 6223.0	MW	Hour : 22:00	Shortage	: 260 MW
Total Gen. (MKWH)	: 131.0	System L/ Factor	: 78.37%	Load Shed	: 232 MW

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Export from East grid to West grid :- Maximum	-50	MW	at 17:00	Energy	7.867	MKWHR.
Import from West grid to East grid :- Maximum	-	MW	at -	Energy	-	MKWHR.
Water Level of Kaptai Lake at 6:00 A M on 26-Sep-14						
Actual : 87.64	Ft.(MSL) ,	Rule curve : 104.80	Ft.(MSL)			

Gas Consumed : Total	764.37	MMCFD.	Oil Consumed (PDB) :	HSD : Liter
				FO : Liter
Cost of the Consumed Fuel (PDB+Pvt) :	Gas : Tk65,114,433			
	Coal : Tk15,698,837	Oil : Tk470,332,739	Total : Tk551,146,009	

Load Shedding & Other Information

Area	Yesterday		Today	
	MW	Estimated Demand(s/s end)	Estimated Shedding (s/s end)	Rates of Shedding (On Estimated Demand)
		MW	MW	
Dhaka	137 (18:35-23:50)	2373	72	-
Chittagong Area	58 (18:35-23:50)	617	28	-
Khulna Area	64 (18:35-23:50)	673	30	-
Rajshahi Area	57 (18:35-23:50)	654	29	-
Comilla Area	44 (18:35-23:50)	451	20	-
Mymensingh Area	33 (18:35-23:50)	375	17	-
Sylhet Area	33 (18:35-23:50)	304	13	-
Barisal Area	12 (18:35-23:50)	135	6	-
Rangpur Area	32 (18:35-23:50)	383	17	-
	-			
Total	470	5965	232	

Information of the Generating machines under shut down.

Planned Shut- Down	Forced Shut- Down
1) Haripur GT: Unit-3 (18/06/2009)	1) Ghorasal ST: Unit-6 (18/07/2010) 9) Sirajganj 210MW(23/9/14) 2) Meghnaghat CCPP (21/04/2014) 3) Ashuganj ST: Unit-1(23/08/2014) 4) Ashuganj CCPP: GT-2(22/08/2014) 5) Sikaibaha ST 60 MW(3/7/14) 6) Ghorasal ST: Unit-1 (11/09/2014) 7) Ashuganj CCPP GT-2 (22/09/2014) 8) Fenchuganj GT-4 (22/09/2014)

Additional Information of Machines. lines. Interruption / Forced Load shed etc.

Description	Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday.	So about 470 MW (21:00) of load shed was imposed over the whole areas of the national grid .
b) Dohazari-Cox's Bazar 132 kV Ckt-2 was shut down from 09:34 to 10:59 due to red hot maintenance at Y-phase.	
c) Ashuganj # 3 was synchronized at 11:17 .	
d) Aminbazar-Meghnaghat 230 kV Ckt-2 was shot down from 11:54 to 18:05 due to project work.	
e) Gopalganj 100 MW tripped at 18:34 and was synchronized at 19:38.	
f) Khulna(S)-Satkhira 132 kV Ckt was shut down from 14:10 to 15:44 due to maintenance work.	Power interruption occurred (about 27 MW) under Khulna S/S areas from 15:20 to 15:55.
g) Naogaon 132/33 kV T2 transformer was switched on at 16:35.	
h) Kabirpur 132/33 kV T2 transformer was shut down at 07:25(26/09/2014) due to new bay extension work.	Power interruption occurred (about 17 MW) under Kabirpur S/S areas from 07:25(26/09/2014) to till.
i) Ghorashal 45 MW RPP tripped at 02:52(26/09/2014) due to auxiliary failure and was synchronized at 03:40(26/09/2014).	
Sub Divisional Engineer Network Operation Division	Executive Engineer Network Operation Division Superintendent Engineer Load Despatch Circle