

Till now the maximum generation is :-

7418 MW

21:00

Reporting Date : 10-Oct-14

Hrs on 18-Jul-14

The Summary of Yesterday's (9-Oct-14				Generation & Demand				Today's Actual Min Gen. & Probable Gen. & Demand			
Day Peak Generation	:	4909.0	MW	Hour :	12:00	Min. Gen. at	7:00	4344	MW		
Evening Peak Generation	:	6432.0	MW	Hour :	18:30	Max Generation	:	7100	MW		
E.P. Demand (at gen end)	:	6432.0	MW	Hour :	18:30	Max Demand	:	6500	MW		
Maximum Generation	:	6432.0	MW	Hour :	18:30	Shortage	:	-600	MW		
Total Gen. (MKWH)	:	125.7	System L/ Factor	:	78.37%	Load Shed	:	0	MW		
EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR											
Export from East grid to West grid :- Maximum				-120	MW	at	7:00	Energy	7.867	MKWHR.	
Import from West grid to East grid :- Maximum				-	MW	at	-	Energy	-	MKWHR.	
Water Level of Kaptai Lake at 6:00 A M on 10-Oct-14											
Actual	:	87.64	Ft.(MSL)	Rule curve	:	106.81	Ft.(MSL)				
Gas Consumed : Total				884.50	MMCFD.	Oil Consumed (PDB) :					
								HSD	:	Liter	
								FO	:	Liter	
Cost of the Consumed Fuel (PDB+Pvt) :				Gas	:	Tk68,157,172					
				Coal	:	Tk15,390,241	Oil	:	Tk231,638,583	Total	: Tk315,185,996
Load Shedding & Other Information											
Area	Yesterday						Today				
	MW		Estimated Demand(s/s end) MW				Estimated Shedding (s/s end) MW		Rates of Shedding (On Estimated Demand)		
Dhaka	-	0.00	2277				-		-		
Chittagong Area	-	0.00	582				-		-		
Khulna Area	-	0.00	635				-		-		
Rajshahi Area	-	0.00	618				-		-		
Comilla Area	-	0.00	426				-		-		
Mymensingh Area	-	0.00	354				-		-		
Sylhet Area	-	0.00	288				-		-		
Barisal Area	-	0.00	128				-		-		
Rangpur Area	-	0.00	362				-		-		
Total	0		5670				0				
Information of the Generating machines under shut down.											
	Planned Shut- Down					Forced Shut- Down					
	1) Haripur GT: Unit-3 (18/06/2009)					1) Ghorasal ST: Unit-6 (18/07/2010) 2) Megnaghat CCPP (21/04/2014) 3) Ashuganj ST: Unit-1(23/08/2014) 4) Ghorasal ST: Unit-3 (03/10/2014) 5) Ghorasal ST: Unit-1(07/10/2014) 6) Barisal GT: Unit-1 (17/09/2014) 7) Ashuganj ST: Unit-2(09/10/2014)					
Additional Information of Machines. lines. Interruption / Forced Load shed etc.											
Description						Forced load shaded / Interrupted Areas					
a) Rangpur 132/33 kV T1 transformer was under shut down from 09:30 to 13:50 due to annual maintenance.						Power interruption occurred (about 09 MW) under Natore S/S areas from 10:05 to 11:18.					
b) Natore 132/33 kV T1 transformer was under shut down from 10:05 to 11:18 due to maintenance works.											
c) Madaripur 132/33 kV T1,T2 & T3 transformers tripped at 18:45 showing E/F relay and were switched on at 19:10						Power interruption occurred (about 76 MW) under Madaripur S/S areas from 18:45 to 19:10.					
d) Sylhet 132/33 kV T1 & T2 transformers were under shut down from 06:18 to 07:44 (10/10/2014) due to 33 kV bus maintenance.						Power interruption occurred (about 50 MW) under Sylhet S/S areas from 06:18 to 07:44 (10/10/2014).					
Sub Divisional Engineer				Executive Engineer				Superintendent Engineer			
Network Operation Division				Network Operation Division				Load Despatch Circle			