

Till now the maximum generation is :-

7418 MW

21:00

Hrs on 18-Jul-14

Reporting Date : 24-Oct-14

The Summary of Yesterday's (23-Oct-14)				Generation & Demand		Today's Actual Min Gen. & Probable Gen. & Demand			
Day Peak Generation	:	5590.0	MW	Hour :	12:00	Min. Gen. at	7:00	4269	MW
Evening Peak Generation	:	6860.0	MW	Hour :	19:00	Max Generation	:	6800	MW
E.P. Demand (at gen end)	:	6860.0	MW	Hour :	19:00	Max Demand	:	6700	MW
Maximum Generation	:	6860.0	MW	Hour :	19:00	Shortage	:	-100	MW
Total Gen. (MKWH)	:	131.8		System L/ Factor	:	Load Shed	:	0	MW

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Export from East grid to West grid :-	Maximum	130	MW	at	14:00	Energy	7.867	MKWHR.
Import from West grid to East grid :-	Maximum	-	MW	at	-	Energy	-	MKWHR.
Water Level of Kaptai Lake at 6:00 A M on 24-Oct-14								
Actual	:	87.64	Ft.(MSL)	Rule curve	:	108.20	Ft.(MSL)	

Gas Consumed :	Total	824.73	MMCFD.	Oil Consumed (PDB) :				
				HSD	:		Liter	
				FO	:		Liter	
Cost of the Consumed Fuel (PDB+Pvt) :	Gas	:	Tk67,530,405					
	Coal	:	Tk8,281,043	Oil	:	Tk416,028,718	Total	: Tk491,840,166

Load Shedding & Other Information

Area	Yesterday		Today	
	MW		Estimated Demand(s/s end) MW	
Dhaka	-	0.00	2453	-
Chittagong Area	-	0.00	631	-
Khulna Area	-	0.00	690	-
Rajshahi Area	-	0.00	669	-
Comilla Area	-	0.00	460	-
Mymensingh Area	-	0.00	379	-
Sylhet Area	-	0.00	309	-
Barisal Area	-	0.00	137	-
Rangpur Area	-	0.00	388	-
Total	0		6116	0

Information of the Generating machines under shut down.

Planned Shut- Down	Forced Shut- Down
1) Haripur GT: Unit-3 (18/06/2009)	1) Ghorasal ST: Unit-6 (18/07/2010) 2) Megnaghat CAPP (21/04/2014) 3) Ashuganj ST: Unit-1(23/08/2014) 4) Ghorasal ST: Unit-1 (12/10/2014) 5) Siddhirganj ST (14/10/2014) 6) Barapukuria ST: Unit-1(23/10/2014) 7) Haripur 412 MW CAPP (23/10/2014)

Additional Information of Machines. lines. Interruption / Forced Load shed etc.

Description	Forced load shaded / Interrupted Areas
a) Kulshi-Bakulia 132 kV Ckt-1 was under shut down from 08:35 to 16:25 due to A/M. b) Rangpur 33 kV Bus was under shut down from 09:01 to 09:50 due to 33 kV feeder isolator loop connector B phase. c) Sikalbaha 150 MW tripped at 11:12 due to line work on the P/S and was synchronized at 12:53. d) Mymensingh-Kishorgonj 132 kV Ckt-2 tripped at 13:10 from both end showing Dist. C, E/F and was switched on at 20:14. e) Haripur 412 MW EGCB GT was synchronized at 17:26. f) Ashuganj ST-2 was force shut down at 23:58 due to boiler tube leakage. g) Ghorashal unit-4 was shut down at 00:45(24/10/2014) due to major overhauling. h) Khulna@ 132 kV Main Bus was shut down at 07:25 (24/10/2014) due to project work. i) Jamalpur 132/33 kV T2 transformer was shut down at 06:35 due to project work. j) Ullon-Dhanmondi 132 kV Ckt-2 was shut down at 07:56 due to DPDC work.	Superintendent Engineer Load Despatch Circle
Sub Divisional Engineer Network Operation Division	Executive Engineer Network Operation Division