

Till now the maximum generation is :-				7418 MW		21:00		Hrs on 18-Jul-14		Reporting Date : 9-Nov-14	
The Summary of Yesterday's ( 8-Nov-14				Generation & Demand				Today's Actual Min Gen. & Probable Gen. & Demand			
Day Peak Generation :		5110.0		MW		Hour :		12:00		Min. Gen. at 5:00 4709 MW	
Evening Peak Generation :		6763.0		MW		Hour :		19:00		Max Generation : 6650 MW	
E.P. Demand (at gen end) :		6763.0		MW		Hour :		19:00		Max Demand : 6900 MW	
Maximum Generation :		6763.0		MW		Hour :		19:00		Shortage : 250 MW	
Total Gen. (MKWH) :		124.8		System L/ Factor :		78.37%		Load Shed :		227 MW	
EXPORT /IMPORT THROUGH EAST-WEST INTERCONNECTOR											
Export from East grid to West grid :- Maximum				50		MW		at 17:00		Energy 7.867 MKWHR.	
Import from West grid to East grid :- Maximum				-		MW		at -		Energy - MKWHR.	
Actual :		87.64		Water Level of Kaptai Lake at 6:00 A M on Ft.(MSL) ,				Rule curve :		9-Nov-14 108.20 Ft.( MSL )	
Gas Consumed : Total		818.14		MMCFD.		Oil Consumed (PDB) :		HSD : Liter		FO : Liter	
Cost of the Consumed Fuel (PDB+Pvt) :				Gas : Tk66,180,938		Coal : Tk12,538,747		Oil : Tk374,035,188		Total : Tk452,754,874	
Load Shedding & Other Information											
Area		Yesterday				Today					
		MW		Estimated Demand(s/s end) MW		Estimated Shedding (s/s end) MW		Rates of Shedding (On Estimated Demand)			
Dhaka		-		0:00 2490		68		-			
Chittagong Area		-		0:00 650		28		-			
Khulna Area		-		0:00 712		31		-			
Rajshahi Area		-		0:00 690		30		-			
Comilla Area		-		0:00 475		21		-			
Mymensingh Area		-		0:00 392		17		-			
Sylhet Area		-		0:00 314		9		-			
Barisal Area		-		0:00 142		6		-			
Rangpur Area		-		0:00 400		17		-			
Total		0		6265		227					
Information of the Generating machines under shut down.											
		Planned Shut- Down				Forced Shut- Down					
		1) Haripur GT: Unit-3 (18/06/2009)				1) Ghorasal ST: Unit-6 (18/07/2010) 8) Fenchuganj CCPP-2 ST (07/11/2014) 2) Ashuganj ST: Unit-1(23/08/2014) 9) Sylhet 150MW GT(07/11/2014) 3) Ghorasal ST: Unit-1 (12/10/2014) 10) Ashuganj ST: Unit-4(08/11/2014) 4) Siddhirganj ST (14/10/2014) 5) Haripur 360MW (06/11/2014) 6) Baghabari 71 MW (22/10/2014) 7) Khulna ST 110 MW (04/11/2014)					
Additional Information of Machines. lines. Interruption / Forced Load shed etc.											
Description						Forced load shaded / Interrupted Areas					
a) Comilla(N) 230/132 kV To1 transformer was shut down from 08:16 to 14:14 due to A/M. b) Ishurdi - Baghabari 230 kV Ckt-1 was shut down from 08:21 to 14:59 due to A/M. c) Savar 132/33 kV T1 transformer was shut down from 08:06 to 16:06 due to A/M. d) Manikganj 132/33 kV T2 transformer was shut down from 08:21 to 14:44 due to A/M. e) Kabirpur - Manikganj 132 kV Ckt-2 was shut down from 08:23 to 17:23 due to A/M. f) Hathazari - Feni132 kV Ckt-1 was shut down from 08:31 to 15:50 due to A/M. g) Kishorganj 132/33 kV T3 transformer was shut down from 08:30 to 15:41 due to A/M. h) Bagherhat 132/33 kV T1 transformer was shut down from 09:01 to 17:13 due to A/M. i) Tangail 132/33 kV T1 transformer was shut down from 09:10 to 14:20 due to A/M. j)Tongi 230/132 kV To2 transformer was shut down from 09:32 to 17:30 due to A/M. k) Chatak 132/33 kV T2 transformer was shut down from 11:07 to 18:36 due to A/M. l) Bogra - Sirajganj 132 kV Ckt-1 was shut down from 09:35 to 16:33 due to A/M. m) Haripur 132/33 kV T02 transformer was shut down from 09:33 to 15:53 due to A/M. n) Barisal 132/33 kV T1 transformer was shut down at 07:07 (09/11/2014) due to A/M. o) Aminbazar 230/132 kV T2 transformer was shut down from 09:50 to 17:40 due to A/M. p) Purbasadipur 132/33 kV T2 transformer was shut down from 09:32 to 20:08 due to A/M. q) Mymensing 132/33 kV T2 transformer was shut down from 08:43 to 14:44 due to A/M. r) Shaympur 132/33 kV T1 transformer was shut down at 10:16 due to A/M. s) Meghnaghat 230 kV bus was shut down from 10:28 to 16:19 due to A/M. t) Maniknagar- Siddirganj 230 kV Ckt-2 tripped at 14:54 showing following relay distance SOTF, Auto recloser block(REF-676) and was switched on at 15:19. u) Rampura - Bashundhara 132 kV Ckt-1 tripped at 16:45 showing distance relay at Rampura end and was switched on at 17:02. and shut down at 07:55 (09/11/2014) due to A/M. v) Ashuganj unit-4 was shut down at 23:46 due to work on turbine side. w) Mymensing RPCL GT-2 was shut down at 23:58 due to high vibration. x) Hasnabad - Sitalakha 132 kV Ckt was shut down at 07:28 (09/11/2014) due to A/M. y) Juida - Shahmipur 132 kV Ckt-2 was shut down at 07:28 (09/11/2014) due to A/M. z) Lalbagh Kamraungir char 132 kV Ckt tripped at 07:50 Showing O/C relay at Lalbagh end and . was switched on at 09:55											
Sub Divisional Engineer Network Operation Division						Executive Engineer Network Operation Division					
						Superintendent Engineer Load Despatch Circle					