POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT QF-LDC-08 Page -1 Reporting Date : 18-Jul-14 11-Nov-14 7418 MW 21:00 Till now the maximum generation is: Generation & Demand The Summary of Yesterday's (10-Nov-14 Today's Actual Min Gen. & Probable Gen. & Demand 5373.0 Hour 12:00 Day Peak Generation Min. Gen. at Evening Peak Generation 6665.0 MW Hour: 19:30 Max Generation 6690 MW E.P. Demand (at gen end) 6665.0 MW Hour 19:30 Max Demand MW Maximum Generation 6665.0 MW Hour: 19:30 Shortage 60 MW Total Gen. (MKWH) 126.5 System L/ Factor 78.37% Load Shed 56 EXPORT/IMPORT THROUGH EAST-WEST INTERCONNECTOR MKWHR. Export from East grid to West grid :- Maximum 20 MW at 17:00 Energy 7.867 Import from West grid to East grid :- Maximum MW Energy MKWHR Water Level of Kaptai Lake at 6:00 A M on 11-Nov-14 Ft.(MSL) Rule curve 108.00 Ft.(MSL) 820.97 MMCFD. Oil Consumed (PDB): Gas Consumed : Total HSD Liter FO Liter Cost of the Consumed Fuel (PDB+Pvt) : Gas Tk65 987 523 : Tk387,706,473 Total : Tk460,217,271 Tk6,523,276 Oil Load Shedding & Other Information Area Yesterday Today Estimated Demand(s/s end) Rates of Shedding Estimated Shedding (s/s end) MW MW (On Estimated Demand) Dhaka 0:00 2493 Chittagong Area 653 0:00 Khulna Area 715 12 0:00 Rajshahi Area 693 12 0:00 Comilla Area 0:00 476 8 Mymensingh Area 0:00 391 6 Svlhet Area 314 0:00 Barisal Area 139 0:00 Rangpur Area 0:00 401 Total 6275 56 Information of the Generating machines under shut down.

| Planned Shut- Down | Forced Shut- Down | |
|------------------------------------|---|--------------|
| 1) Haripur GT: Unit-3 (18/06/2009) | 1) Ghorasal ST: Unit-6 (18/07/2010) 9) Barapukuria unit-2 | (09/11/2014) |
| | 2) Ashuganj ST: Unit-1(23/08/2014) | |
| | 3) Siddhirganj ST (14/10/2014) | |
| | 4) Baghabari 71 MW (22/10/2014) | |
| | 5) Khulna ST 110 MW (04/11/2014) | |
| | 6) Fenchuganj CCPP-2 ST (07/11/2014) | |
| | 7) Sylhet 150MW GT(07/11/2014) | |
| | 8) Ashuganj ST: Unit-4(08/11/2014) | |

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

| Description | Forced load shaded / Interrupted Areas |
|---|--|
| a) Thakurgaon 132/33 kV T2 Transformer was shut down from 08:15 to 15:23 due to A/M. | |
| b) Kishoreganj 132/33 kV T2 Transformer was shut down from 08:36 to 15:41 due to A/M. | |
| c) Dohazari - Sikalbaha 132 kV Ckt-1 was shut down from 08:29 to 16:26 due to A/M. | |
| d) Hathazari - Feni 132 kV Ckt-1 was shut down from 08:46 to 14:37 due to A/M. | |

About 10 MW Power interruption occurred under Jessore S/S areas

About 54 MW Power interruption occurred under Dhanmondi S/S areas

from 08:28 to 09:50.

from 13:34 to 14:15.

e) Jessore 132/33 kV T1 Transformer was shut down from 08:28 to 09:50 due to blue phase Jumper change in 33 kV Benapole feeder. Mymensingh 132/33 kV T2 Transformer was shut down from 09:05 to 16:04 due to A/M.

g) Tangail 132/33 kV T1 Transformer was shut down from 09:10 to 15:50 due to A/M.

h) Tongi 230/132 kV T2 Transformer was shut down from 09:16 to 17:24 due to A/M.
i) Aminbazar 230/132 kV T3 Transformer was shut down from 09:27 to 17:37 due to A/M.

j) Bogra - Sirajganj 132 kV Ckt-1 was shut down from 09:33 to 15:35 due to A/M. k) Kabirpur - Manikganj 132 kV Ckt-2 was shut down from 09:47 to 16:26 due to A/M.

) Bagherhat 132/33 kV T2 Transformer was shut down at 09:11 due to A/M. n) Khulna(S) 230 kV bus-2 was shut down from 10:16 to 16:50 due to A/M.

n) Ishurdi - Natore 132 kV Ckt-1 was shut down from 08:15 to 15:37 due to A/M.

0) Ullon - Dhanmondi 132 kV Ckt-3 tripped at 13:34 from Ullon end and was switched on 14:30.

p) Sikalbaha 150 MW GT was shut down at 00:07(11/11/2014) due to heat exchange work.

r) Khulna 150MW GT was shut down at 22:37 due to maintenance work r) Sirajganj 210 MW ST tripped at 06:38 (11/11/2014) due to unknown.

s) Hasnabad - Kalyanpur 132 kV Ckt was shut down at 00:23(11/11/2014) due to red hot maintenance work at Hasnabad end and was switched on at 10:42(11/11/2014).

t) After maintenance Barisal - Madaripur 132 kV Ckt-1 switched on at 23:19(10/11/2014).) Hasnabad - Shyampur 132 kV Ckt was shut down at 06:20(11/11/2014) due to A/M.

v) Hasnabad 230/132 kV T3 Transformer was shut down from 07:05 to 11:15(11/11/2014) due to

red hot maintenance work.

Executive Engineer Sub Divisional Engineer Superintendent Engineer Load Despatch Circle letwork Operation Division Network Operation Division