

Till now the maximum generation is :-

7418 MW

21:00

Hrs

Reporting Date : 21-Nov-14

on

18-Jul-14

The Summary of Yesterday's (

20-Nov-14

Generation & Demand

Today's Actual Min Gen. & Probable Gen. & Demand

Day Peak Generation :	4638.0	MW	Hour :	12:00	Min. Gen. at 5:00	3536	MW
Evening Peak Generation :	6109.0	MW	Hour :	19:00	Max Generation :	6045	MW
E.P. Demand (at gen end) :	6109.0	MW	Hour :	19:00	Max Demand :	5800	MW
Maximum Generation :	6109.0	MW	Hour :	19:00	Shortage :	-245	MW
Total Gen. (MKWH) :	108.6	System L/ Factor :	78.37%	Load Shed :	0	MW	

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Export from East grid to West grid :-	Maximum	-190	MW	at	3:00	Energy	7.867	MKWHR.
Import from West grid to East grid :-	Maximum	-	MW	at	-	Energy	-	MKWHR.
Water Level of Kaptai Lake at 6:00 A M on 21-Nov-14								
Actual :	87.64	Ft.(MSL) ,	Rule curve :	107.00	Ft.(MSL)			

Gas Consumed : Total	792.22	MMCFD.	Oil Consumed (PDB) :		HSD :		Liter
					FO :		Liter
Cost of the Consumed Fuel (PDB+Pvt) :	Gas :	Tk63,080,584					
	Coal :	Tk3,554,599	Oil :	Tk227,148,201	Total :	Tk293,783,384	

Load Shedding & Other Information

Area	Yesterday		Today	
	MW	Estimated Demand(s/s end)	Estimated Shedding (s/s end)	Rates of Shedding (On Estimated Demand)
Dhaka	- 0.00	2166	-	-
Chittagong Area	- 0.00	551	-	-
Khulna Area	- 0.00	600	-	-
Rajshahi Area	- 0.00	586	-	-
Comilla Area	- 0.00	405	-	-
Mymensingh Area	- 0.00	338	-	-
Sylhet Area	- 0.00	276	-	-
Barisal Area	- 0.00	123	-	-
Rangpur Area	- 0.00	346	-	-
Total	0	5391	0	

Information of the Generating machines under shut down.

Planned Shut- Down	Forced Shut- Down
1) Haripur GT: Unit-3 (18/06/2009)	1) Ghorasal ST: Unit-6 (18/07/2010) 2) Ashuganj ST: Unit-1(23/08/2014) 4) Baghabari 71 MW (22/10/2014) 5) Khulna ST 110 MW (04/11/2014) 6) Fenchuganj CAPP-2 ST (07/11/2014) 7) Sylhet 150 MW GT (07/11/2014) 9) Ghorashal ST : Unit-4 (11/11/2014) 9) Barapukuria ST: Unit-2 (17/11/2014)

Additional Information of Machines. lines. Interruption / Forced Load shed etc.

Description	Forced load shaded / Interrupted Areas
a) Tongi-Bashundhara 132 kV Ckt-1 tripped at 08:05 from both end showing Dist. Z2 a-phase and was switched on at 09:18. b) Ghorashal-Ashuganj 132 kV Ckt-2 was under shut down from 08:54 to 17:15 due to A/M. c) Haripur-Meghnaghat 230 kV Ckt-2 was under shut down from 09:07 to 17:27 due to A/M. d) Goalpara 132 B-Bus was under shut down from 08:17 to 13:30 due to A/M. e) Tongi-Bashundhara 132 kV Ckt-2 was under shut down from 09:14 to 16:40 due to A/M. f) Bashundhara 132 kV main bus was shut down from 09:47 to 16:40 due to A/M. g) Aminbazar-Hasnabad 230 kV Ckt-2 was under shut down from 10:10 to 16:27 due to A/M. h) Sikalbaha-Madunaghat 132 kV Ckt-1 was under shut down from 07:50 to 15:46 due to A/M. i) Khulshi-Halishahar 132 kV Ckt-1 was under shut down from 08:40 to 14:59 due to A/M. j) Hathazari-Feni 132 kV Ckt-2 was under shut down from 08:51 to 14:21 due to A/M. k) Naogaon S/S-Shantahar P/S 132 kV Ckt was under shut down from 09:35 to 16:20 due to A/M. l) Ishurdi 230/132 kV TO2 transformer was under shut down from 11:45 to 13:17 due to PT problem. m) Barapukuria unit-1 was shut down at 20:37 due to coal mill problem. n) Maniknagar 230/132 kV T2 transformer is under shut down since 07:52(21/11/2014) due to project work.	
Sub Divisional Engineer Network Operation Division	Executive Engineer Network Operation Division Superintendent Engineer Load Despatch Circle