

Reporting Date : 25-Nov-14

Till now the maximum generation is :-

7418 MW

21:00

Hrs on 18-Jul-14

The Summary of Yesterday's (24-Nov-14		Generation & Demand		Today's Actual Min Gen. & Probable Gen. & Demand			
Day Peak Generation	:	4433.0	MW	Hour :	12:00	Min. Gen. at	4:00	3236	MW
Evening Peak Generation	:	6047.0	MW	Hour :	18:30	Max Generation	:	6214	MW
E.P. Demand (at gen end)	:	6047.0	MW	Hour :	18:30	Max Demand	:	6150	MW
Maximum Generation	:	6047.0	MW	Hour :	18:30	Shortage	:	-64	MW
Total Gen. (MKWH)	:	104.0	System L/ Factor	:	78.37%	Load Shed	:	0	MW

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Export from East grid to West grid :- Maximum		-110		MW	at	21:00	Energy	7.867	MKWHR.
Import from West grid to East grid :- Maximum		-		MW	at	-	Energy	-	MKWHR.
Actual :		87.64		Water Level of Kaptai Lake at 6:00 A M on		25-Nov-14			
		Ft.(MSL) ,		Rule curve :		106.60		Ft.(MSL)	

Gas Consumed :	Total	780.26	MMCFD.	Oil Consumed (PDB) :					
					HSD	:		Liter	
					FO	:		Liter	
Cost of the Consumed Fuel (PDB+Pvt) :		Gas	:	Tk58,772,048					
		Coal	:	Tk0		Oil	:	Tk210,950,965	Total : Tk269,723,013

Load Shedding & Other Information

Area	Yesterday		Today	
	MW		Estimated Shedding (s/s end)	Rates of Shedding (On Estimated Demand)
Dhaka	-	0:00	2246	-
Chittagong Area	-	0:00	573	-
Khulna Area	-	0:00	625	-
Rajshahi Area	-	0:00	609	-
Comilla Area	-	0:00	420	-
Mymensingh Area	-	0:00	350	-
Sylhet Area	-	0:00	285	-
Barisal Area	-	0:00	127	-
Rangpur Area	-	0:00	358	-
Total	0		5593	0

Information of the Generating machines under shut down.

Planned Shut- Down	Forced Shut- Down
1) Haripur GT: Unit-3 (18/06/2009)	1) Ghorasal ST: Unit-6 (18/07/2010) 2) Ashuganj ST: Unit-1(23/08/2014) 4) Baghabari 71 MW (22/10/2014) 5) Khuina ST 110 MW (04/11/2014) 6) Fenchuganj CCPP-2 ST (07/11/2014) 7) Sylhet 150 MW GT (07/11/2014) 8) Ghorashal ST : Unit-4 (11/11/2014) 9) Barapukuria ST: Unit-2 (16/11/2014)
	10) Barapukuria ST: Unit-1 (20/11/2014) 11) Ghorasal ST: Unit-5 (23/11/2014)

Additional Information of Machines. lines. Interruption / Forced Load shed etc.

Description	Forced load shaded / Interrupted Areas	
a) Gopalganj 132/33 kV T2 transformer was shut down from 08:09 to 16:52 due to A/M. b) Panchaghar-Thakurgaon 132 kV Ckt was shut down from 08:20 to 16:05 due to A/M. c) Panchaghar 132/33 kV T1 & T2 transformer were shut down from 08:20 to 16:06 due to A/M. d) Ashuganj -Kishoreganj 132 kV Ckt-1 was shut down from 08:18 to 16:05 due to A/M. e) Shahjadpur - Pabna 132 kV Ckt-1 was shut down from 08:26 to 17:25 due to A/M. f) Feni - Hathazari 132 kV Ckt-1 was shut down at 08:35 to till now due to A/M. g) Uttara 132 kV reserve bus was shut down from 08:38 to 15:30 due to A/M. h) Joydabpur - Kabirpur 132 kV Ckt-2 was shut down from 09:38 to 16:24 due to A/M. i) Mirpur - Aminbazar 132kV Ckt-2 was shut down from 08:38 to 16:01 due to A/M. j) Khulshi- Halishahar 132 kV Ckt-1 was shut down from 08:52 to 15:09 due to A/M. k) Jamalpur 132/33 kV T1 Transformer was shut down from 09:03 to 16:32 due to A/M. l) Tangail - Kabirpur 132 kV Ckt-1 was shut down from 09:17 to 17:13 due to A/M. m) Bogra - Sirajganj 230 kV Ckt-1 was shut down from 09:07 to 14:26 due to A/M. n) Munshiganj 132/33 kV T1 Transformer was shut down from 09:28 to 16:20 due to A/M. o) Naogaon 132/33 kV T2 Transformer was shut down from 09:10 to 13:15 due to A/M. p) Aminbazar 230 kV Ckt-1 was shut down from 09:55 to 16:58 due to development work. q) Aminbazar - Meghnaghat 230 kV Ckt-2 was shut down from 09:24 to 13:37 due to project work. r) Manikganj - Kabirpur 132 kV Ckt-1 was shut down from 09:46 to 16:53 due to project work. s) Noapara 132/33 kV T2 Transformer was shut down from 09:16 to 16:28 due to project work. t) Jessore 132 kV capacitor bank was shut down from 09:10 to 14:45 due to A/M. u) Haripur - Rampura 230 kV Ckt-2 was shut down from 10:11 to 15:54 due to A/M. v) Jamalpur 132/33 kV T2 Transformer tripped at 11:50 showing OLTC surge and was switched on at 12:17. w) Ashuganj 132/33 kV T4 Transformer was shut down from 11:42 to 12:10 due to red hot maint at 33 kV end. x) Palashbari 132/33 kV T4 Transformer was shut down at 12:10 to due to replacement of lightning arrester. y) Aminbazar-Meghnaghat 230 kV Ckt-1 was shut down from 13:40 to 17:25 due to project work. z) Ashuganj ST #5 tripped at 15:03 due to DCS problem and was synchronized at 02:36(25/11/14). aa) Rampura-Haripur 230 kV Ckt-2 tripped at 16:53 due to lightning arrester brust at Rampura end showing dist B-n Z1 from both end and was switched on at 22:07. ab) Sikalbaha - TK Chemical 132 kV Ckt is under shut down since 06:50 (25/11/14) due to A/M. ac) Natore - Rajshahi 132 kV Ckt is under shut down since 08:01 (25/11/14) due to A/M.	About 23 MW power interruption occurred under Jamalpur S/S areas from 11:50 to 12:17.	
Sub Divisional Engineer Network Operation Division	Executive Engineer Network Operation Division	Superintendent Engineer Load Despatch Circle