

Till now the maximum generation is :-				7418 MW		21:00		Hrs on 18-Jul-14		Reporting Date : 6-Dec-14			
The Summary of Yesterday's (				5-Dec-14		Generation & Demand		Today's Actual Min Gen. & Probable Gen. & Demand					
Day Peak Generation :		3800.0		MW		Hour :		12:00		Min. Gen. at 4:00 3079 MW			
Evening Peak Generation :		5477.0		MW		Hour :		18:30		Max Generation : 5813 MW			
E.P. Demand (at gen end) :		5477.0		MW		Hour :		18:30		Max Demand : 5700 MW			
Maximum Generation :		5477.0		MW		Hour :		18:30		Shortage : -113 MW			
Total Gen. (MKWH) :		98.3		System L/ Factor :		78.37%		Load Shed :		0 MW			
EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR													
Export from East grid to West grid :- Maximum				-215		MW at 14:00		Energy 7.867		MKWHR.			
Import from West grid to East grid :- Maximum				-		MW at -		Energy -		MKWHR.			
Water Level of Kaptai Lake at 6:00 A M on				6-Dec-14									
Actual :		87.64		Ft.(MSL) ,		Rule curve :		105.55		Ft.( MSL )			
Gas Consumed : Total 739.21 MMCFD.				Oil Consumed (PDB) :				HSD : Liter		FO : Liter			
Cost of the Consumed Fuel (PDB+Pvt) :				Gas : Tk58,395,592		Coal : Tk8,476,348		Oil : Tk142,314,975		Total : Tk209,186,915			
Load Shedding & Other Information													
Area		Yesterday				Today							
		MW				Estimated Demand(s/s end)				Estimated Shedding (s/s end)		Rates of Shedding (On Estimated Demand)	
						MW				MW			
Dhaka		- 0.00				1935				-		-	
Chittagong Area		- 0.00				486				-		-	
Khulna Area		- 0.00				527				-		-	
Rajshahi Area		- 0.00				519				-		-	
Comilla Area		- 0.00				360				-		-	
Mymensingh Area		- 0.00				305				-		-	
Sylhet Area		- 0.00				249				-		-	
Barisal Area		- 0.00				111				-		-	
Rangpur Area		- 0.00				312				-		-	
Total		0				4804				0			
Information of the Generating machines under shut down.													
Planned Shut- Down						Forced Shut- Down							
1) Haripur GT: Unit-3 (18/06/2009)						1) Ghorasal ST: Unit-6 (18/07/2010) 10) Ghorasal ST: Unit-5 (23/11/2014)							
						2) Ashuganj ST: Unit-1(23/08/2014) 11) Baghabari GT 100 MW (01/12/2014)							
						4) Baghabari 71 MW (22/10/2014) 12) Sikalbaha 150 MW (01/12/2014)							
						5) Khulna ST 110 MW (04/11/2014) 13) Ashuganj Unit-5 (05/12/2014)							
						6) Fenchuganj CCPP-2 ST (07/11/2014)							
						7) Chittagong ST: unit-2 (26/11/2014)							
						8) Chittagong ST: unit-1 (04/11/2014)							
						9) Barapukuria ST: Unit-1 (20/11/2014)							
Additional Information of Machines. lines. Interruption / Forced Load shed etc.													
Description						Forced load shaded / Interrupted Areas							
a) Pabna 132 kV main bus was shut down from 08:25 to 15:35 due to A/M.						About 32 MW power interruption occurred under Pabna S/S areas from 08:25 to 15:35.							
b) Comilla (N)-Feni 132 kV Ckt-1 & 2 were shut down from 09:35 to 20:17 due to hooking of Lakdhanavi power plant.													
c) Chandpur-Chowmohani 132 kV Ckt-1 & 2 were shut down from 09:39 to 20:17 due to A/M.													
d) 230 kV Bogra-132 kV Bogra 132 kV Ckt-1 was shut down from 09:12 to 14:01 due to A/M.													
e) Haripur-Shyampur 132 kV Ckt was shut down from 10:20 to 23:01 due to A/M.													
f) Sirajganj 132/33 kV T3 transformer was shut down from 10:43 to 17:05 due to A/M.													
g) After maintenance Ghorasal ST: Unit-5 was synchronized on at 18:16 and tripped at 20:56 due to cooling system problem of generator.													
h) Sylhet 132/33 kv T4 transformer was shut down from 06:47 to 11:31 (06/12/2014) due to A/M.													
i) Baraulia 132 kV bus was shut down from 07:20 to 11:32(06/12/2014) due to A/M.						About 40 MW power interruption occurred under Baraulia S/S areas from 07:20 to 11:32(06/12/2014).							
j) Ashuganj-Sirajganj 230 kV Ckt-2 is under shut down since 05:45(06/12/2014) due to project works.													
k) Comilla (S)-Comilla (N) 132 kV Ckt tripped at 07:10(06/12/2014) showing distance relay from Comilla (S) end and was switched on at 07:19(06/12/2014).													
l) Ashuganj-Kishoreganj 132 kV Ckt-2 is under shut down since 07:26(06/12/2014) due to A/M.													
m) Bhandaria 132/33 kV T1 transformer is under shut down since 07:05(06/12/2014) due to A/M.													
Sub Divisional Engineer				Executive Engineer				Superintendent Engineer					
Network Operation Division				Network Operation Division				Load Despatch Circle					