

Till now the maximum generation is :-				7418 MW		21:00		Hrs on 18-Jul-14		Reporting Date : 13-Dec-14	
The Summary of Yesterday's (12-Dec-14				Generation & Demand				Today's Actual Min Gen. & Probable Gen. & Demand			
Day Peak Generation :	3916.0	MW	Hour :	9:00		Min. Gen. at	5:00	2937	MW		
Evening Peak Generation :	5422.0	MW	Hour :	18:30		Max Generation :		5965	MW		
E.P. Demand (at gen end) :	5422.0	MW	Hour :	18:30		Max Demand :		5600	MW		
Maximum Generation :	5422.0	MW	Hour :	18:30		Shortage :		-365	MW		
Total Gen. (MKWH) :	90.9	System L/ Factor :		78.37%		Load Shed :		0	MW		
EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR											
Export from East grid to West grid :- Maximum				-150	MW	at	17:00	Energy	7.867	MKWHR.	
Import from West grid to East grid :- Maximum				-	MW	at	-	Energy	-	MKWHR.	
Water Level of Kaptai Lake at 6:00 A M on 13-Dec-14											
Actual :		87.64	Ft.(MSL) ,		Rule curve :		104.90	Ft.(MSL)			
Gas Consumed : Total		721.77	MMCFD.		Oil Consumed (PDB) :						
					HSD :		Liter				
					FO :		Liter				
Cost of the Consumed Fuel (PDB+Pvt) :		Gas :	Tk55,583,811								
		Coal :	Tk2,343,194		Oil :		Tk136,540,666	Total :		Tk194,467,671	
Load Shedding & Other Information											
Area	Yesterday		Estimated Demand(s/s end)				Today		Rates of Shedding		
	MW		MW				Estimated Shedding (s/s end)		(On Estimated Demand)		
Dhaka	-	0:00	2079				-		-		
Chittagong Area	-	0:00	527				-		-		
Khulna Area	-	0:00	572				-		-		
Rajshahi Area	-	0:00	561				-		-		
Comilla Area	-	0:00	388				-		-		
Mymensingh Area	-	0:00	326				-		-		
Sylhet Area	-	0:00	265				-		-		
Barisal Area	-	0:00	118				-		-		
Rangpur Area	-	0:00	333				-		-		
Total	0		5169				0				
Information of the Generating machines under shut down.											
	Planned Shut- Down					Forced Shut- Down					
1) Haripur GT: Unit-3 (18/06/2009)					9) Ashuganj Unit-5 (05/12/2014)						
					1) Ghorasal ST: Unit-6 (18/07/2010) 2) Ashuganj ST: Unit-1(23/08/2014) 3) Baghabari 71 MW (22/10/2014) 4) Khulna ST 110 MW (04/11/2014) 5) Fenchuganj CCPP-2 ST (07/11/2014) 6) Chittagong ST: unit-1 (04/11/2014) 7) Baghabari GT 100 MW (01/12/2014) 8) Sikalbaha 150 MW (01/12/2014)						
Additional Information of Machines, lines, Interruption / Forced Load shed etc											
Description						Forced load shaded / Interrupted Areas					
a) Cox's Bazar-Dohazari 132 kV Ckt-1 was under shut down from 08:30 to 15:56 due to A/M. b) Ghorashal 230 kV AT-2 transformer was under shut down from 08:28 to 12:13 due to A/M. c) New Bogra 132 kV Ckt-2 was under shut down from 09:10 to 12:50 due to A/M. d)Kallyanpur 132/33 kV GT-1 transformer was under shut down from 08:33 to 17:22 due to A/M Again shut down was given from 17:29 to 20:05 due to PT problem. e) Hasnabad 230/132 kV AT-2 transformer was under shut down from 08:34 to 14:37 (13/12/2014) due to OLTC maintenance work. f) After maintenance Raozan unit-2 was synchronized at 15:26. g) Tongi(Old) -Tongi (New) 132 kV Ckt-1 & 2 kV tripped at 16:02 from Tongi (Old) end showing diff.relay and Ckt-1 was switched on at 16:30. h)After maintenance Barapukuria Unit 1 was synchronized at 17:17. i)Meghnaghat- Hasnabad 230 kV Ckt-1 tripped at 03:40 from Meghnaghat end showing dist.relay and was switched on at 04:30 (13/12/2014). j)Kamrangirchar-Kallyanpur 132 kV Circuit breaker was under shut down from 02:12 to 12:52 (13/12/2014) due to Red hot. k) Meghnaghat-Hasnabad 230 kV Ckt-2 tripped at 06:05 from both end due to heavy fog and was synchronized at 06:47 l) Ashuganj-Kishorganj 132 kV Ckt-2 was shut down at 07:21(13/12/2014) due to A/M.						Power interruption occurred (about 40 MW) under Tongi (New) S/S areas from 16:02 to 16:30.					
Sub Divisional Engineer Network Operation Division						Executive Engineer Network Operation Division					
Superintendent Engineer Load Dispatch Circle						Superintendent Engineer Load Dispatch Circle					