POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT QF-LDC-08 Page -1 Reporting Date: 11-Feb-15 7418 MW Till now the maximum generation is : 21:00 Hrs on 18-Jul-14 Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand The Summary of Yesterday's (Day Peak Generation 5082.0 MW Hour 9:00 Min. Gen. at MW Evening Peak Generation 6340.0 MW Hour: 19:00 Max Generation 6533 MW 6340.0 MW E.P. Demand (at gen end): MW Hour: 19:00 Max Demand 6400 Maximum Generation 6340.0 MW Hour: 19:00 Shortage -133 MW Total Gen. (MKWH) 115.3 75.77% Load Shed 0 MW EXPORT/IMPORT THROUGH EAST-WEST INTERCONNECTOR Export from East grid to West grid :- Maximum 1:00 Energy 7.867 MKWHR. -60 MW MW Import from West grid to East grid :- Maximum Energy MKWHR. at Water Level of Kaptai Lake at 6:00 A M on 11-Feb-15 Actual : 87 64 Ft.(MSL) Rule curve 95.60 Ft.(MSL) Gas Consumed: Total 761.96 MMCFD. Oil Consumed (PDB): HSD Liter FO Liter Tk59,129,471 Cost of the Consumed Fuel (PDB+Pvt): Gas Tk16,874,579 : Tk308,194,900 Total: Tk384,198,950 Load Shedding & Other Information Area Yesterday Today Estimated Demand (S/S end) Estimated Shedding (S/S end) Rates of Shedding MW MW (On Estimated Demand) Dhaka 0:00 Chittagong Area 0:00 612 Khulna Area 0:00 669 650 Rajshahi Area 0:00 Comilla Area 0:00 447 Mymensingh Area 0.00 370 Sylhet Area 0:00 301 Barisal Area 0:00 134 Rangpur Area 0:00 378 Total 0 5947 Information of the Generating machines under shut down Planned Shut- Down Forced Shut- Down 1) Haripur GT: Unit-3 (18/06/2009) 1) Ghorasal ST: Unit-6 (18/07/2010) 09) Ghorasal ST:Unit-4 (05/01/2015) 2) Ashuganj ST: Unit-1(23/08/2014) 10) Ghorasal ST:Unit-3 (25/01/2015) 3) Khulna ST 110 MW (04/11/2014) 11) Siddhirgonj ST (07/02/2015) 4) Fenchuganj CCPP-1 ST (07/11/2014) 5) Baghabari GT 100 MW (01/12/2014) 6) Sikalbaha Peaking GT (01/12/2014) 7) Chittagong ST: Unit-1(17/1/15) 08) Haripur 412 MW CCPP(02/01/2015) Additional Information of Machines, lines, Interruption / Forced Load shed etc. Forced load shaded / Interrupted Areas Description a) Kaptai(old) 132 kV bus was under shut down from 09:01 to 12:45 due to A/M. a) Replandon 192 w dos was drine sind court microsoft of 22-9 due to 7 mil. b) Aminbazar-Savar 132 kV Ckt-2 was under shut down from 09:10 to 16:55 due to A/M. c) Mirpur-Uttara 132 kV Ckt was shut down from 09:52 to 16:30 due to isolator & Transformer painting work. d) After maintenance Uttara-Tongi 132 kV was switched on at 09:46. e) Hathazari 230/132 kV MT4 Transformer was under shut down from 10:20 to 11:05 due to 230 kV side isolator R-phase red hot maintenance. f) Hasnabad 230/132 kV TR3 Transformer was under shut down from 10:26 to 17:40 due to CB & LA testing work. g) Siddhirganj 625 B Mid breaker was under shut down from 10:31 to 12:03 due to maintenance work. h) Maniknagar-Siddhirganj 230 kV Ckt-2 tripped at 11:19 from both end with TR-2 transformer at Maniknagar end showing line differential L1,L2 red phase & REL670 at yellow phase zone-1 at Maniknagar end. and dist Z1 at Siddhirganj end and was switched on at 11:47. Netrokona 132/33 kV T2 transformer was under shut down at 13:45 due to replacement of new transformer.) After maint Fenchuganj GT-3 was synchronized at 16:03. k) Siddhirganj GT-2 was shut down at 21:24 due to bleed valve leakage Barisal -Madaripur 132 kV Ckt-1 asunder shut down since 06:14(11/02/2015) due to under construction safety work of 230 kV line

Sub Divisional Engineer Network Operation Division Executive Engineer Network Operation Division Superintendent Engineer Load Despatch Circle