## POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT OF-LDC-08 Page -1 Reporting Date: 18-Jul-14 15-Mar-15 Till now the maximum generation is: 7418 MW The Summary of Yesterday's ( 14-Mar-15 Generation & Demand Today's Actual Min Gen. & Probable Gen. & Der MW Hour 12:00 Day Peak Generation 5961.0 Min. Gen. at 5:00 4931 MW Evening Peak Generation 7211.0 MW Hour : 19:30 Max Generation 7462 MW E.P. Demand (at gen end): 7211.0 MW Hour : 19:30 Max Demand 7350 MW Maximum Generation 7211.0 MW Hour : 19:30 Shortage -112 MW Total Gen. (MKWH) System L/ Factor 78.25% 135.4 MW Load Shed 0 EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR Export from East grid to West grid :- Maximum -280 MW at 16:00 Energy 7.867 MKWHR. Import from West grid to East grid :- Maximum MW MKWHR at Energy Water Level of Kaptai Lake at 6:00 A M on 15-Mar-15 87.64 Ft.(MSL) Rule curve 90.76 Ft.( MSL ) Actual: Gas Consumed: Total 959.63 MMCFD. Oil Consumed (PDB): HSD : Liter FO : Liter Tk73,332,480 Cost of the Consumed Fuel (PDB+Pvt): Gas Tk17,266,041 : Tk337,711,741 Total: Tk428,310,262 **Load Shedding & Other Information** Area Yesterday Today Estimated Demand (S/S end) Rates of Shedding Estimated Shedding (S/S end) MW MW MW (On Estimated Demand) Dhaka 0:00 2806 730 Chittagong Area 0:00 Khulna Area 0:00 802 Rajshahi Area 0:00 771 528 Comilla Area 0:00 Mymensingh Area 0:00 429 Sylhet Area 0:00 350 Barisal Area 0:00 155 0:00 440 Rangpur Area 7011 Total Information of the Generating machines under shut down Planned Shut- Down 1) Haripur GT: Unit-3 (18/06/2009) Forced Shut- Down 1) Ghorasal ST: Unit-6 (18/07/2010) 2) Ashuganj ST: Unit-1(23/08/2014) 3) Khulna ST 110 MW (04/11/2014) 4) Fenchuganj CCPP-1 ST (07/11/2014) 5) Baghabari GT 100 MW (01/12/2014) 6) Ghorasal ST:Unit-4 (05/01/2015) 7)Chittagong ST: Unit-1 (10/03/2015) Additional Information of Machines, lines, Interruption / Forced Load shed etc. Forced load shaded / Interrupted Areas a) Dohazari-Cox's Bazar 132 kV Ckt-1 was under shut down from 08:15 to 15:25 due to A/M. ) Meghnaghat 230 kV Bus-1 was under shut down from 08:24 to 13:58 due to replace Y-Phase loop of Meghnaghat-Hasnabad 230 kV Ckt-2. c) Haripur-Meghnaghat 230 kV Ckt-1 tripped at 09:52 showing distance relay at both end and was switched at 10:12 d) Meghnaghat 450 MW GT-1 tripped at 10:04 due to auxiliary failure and was synchronized at 12:38. e) Khulna © 132/33 kV T3 transformer shut down at 10:08 due to painting work. f) Palashbari-Rangpur 132 kV Ckt-1 was under shut down from 11:25 to 17:28 due to 132 kV breaker maintenance at Palashbari end. g) Bibiyana 230/400 kV transformer tripped at 08:57 showing intertrip as 33/0.4 kV auxiliary transformer got burst. h) Rampura-Moghbazar 132 kV Ckt-1 tripped at 09:58 showing O/C relay and was switched on at 13:47. After maintenance Sikalbaha 150 MW was synchronized at 16:23. n) After maintenance Haripur SBU #1 was synohronized at 17:05. k) Ashuganj-Shahjibazar 132 kV Ckt-3 was shut down at 18:48 due to red hot maintenance. Haripur 360 MW ST was forced shut down at 20:28 due to red hot maintenance and was synchronized at

Sub Divisional Engineer Network Operation Division

08:16 (15/03/2015).

Executive Engineer Network Operation Division Superintendent Engineer Load Dispatch Circle