POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT QF-LDC-08 Page -1 Reporting Date: 16-Mar-15 7418 MW 21:00 18-Jul-14 Till now the maximum generation is: Hrs on 15-Mar-15 Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand The Summary of Yesterday's (Hour: 12:00 Day Peak Generation 6048.0 Min. Gen. at 5104 Max Generation Evening Peak Generation 7225.0 MWHour: 19:30 7371 MWE.P. Demand (at gen end): 7225.0 MW 19:30 Max Demand 7350 MWHour: 7225.0 Maximum Generation MW 19:30 Shortage -21 MWHour: Total Gen. (MKWH) System L/ Factor 146.4 84.40% Load Shed 0 MWEXPORT/IMPORT THROUGH EAST-WEST INTERCONNECTOR Export from East grid to West grid :- Maximum 18:30 MKWHR. -180 Energy 7.867 Import from West grid to East grid :- Maximum MW Energy MKWHR. at Water Level of Kaptai Lake at 6:00 A M on 16-Mar-15 87.64 Ft.(MSL) 90.60 Ft.(MSL) Rule curve Actual: MMCFD. Gas Consumed: Total 946.81 Oil Consumed (PDB): HSD : Liter FO Liter Cost of the Consumed Fuel (PDB+Pvt): Tk81,230,304 Gas : Coal Tk18,476,099 Oil : Tk368,595,138 Total: Tk468,301,541 **Load Shedding & Other Information** Area Yesterday Today Estimated Demand (S/S end) Estimated Shedding (S/S end) Rates of Shedding MW MW MW (On Estimated Demand) Dhaka 0.00 2671 Chittagong Area 0:00 692 Khulna Area 0:00 759 Rajshahi Area 0:00 732 Comilla Area 0:00 502 Mymensingh Area 0.00 410 Sylhet Area 0:00 334 Barisal Area 0.00 148 Rangpur Area 0:00 420 Total 0 6668 0 Information of the Generating machines under shut down Planned Shut- Down Forced Shut- Down 1) Ghorasal ST: Unit-6 (18/07/2010) 9) Haripur 412 MW CCPP (16/03/2015) 1) Haripur GT: Unit-3 (18/06/2009) 2) Ashuganj ST: Unit-1(23/08/2014) 3) Khulna ST 110 MW (04/11/2014) 4) Fenchuganj CCPP-1 ST (07/11/2014) 5) Baghabari GT 100 MW (01/12/2014) 6) Ghorasal ST:Unit-4 (05/01/2015) 7)Chittagong ST: Unit-1 (10/03/2015) 8) Ghorasal ST: Unit-5 (15/03/2015) Additional Information of Machines, lines, Interruption / Forced Load shed etc. Description Forced load shaded / Interrupted Areas a) B.Baria 132/33 kV T2, T3 transformers & associate 33 kV Bus section were shut down at 08:40 due to About 20 MW power interruption under B.Baria S/S area from 08:40 to 11:38. isolator replacement work and were switched on at 11:38. b) Ashuganj-225 MW was synchronized at 09:28 due to test purpose and was shut down at 11:23. c) Ashuganj 132/33 kV T4 transformer was shut down at 12:44 due to sparking at B-phase LT bushing and was switched on at 14:36.

Superintendent Engineer

Load Dispatch Circle

d) Baghabari-71 MW was shut down at 12:52 due to cleaning filter and was synchronized at 14:40.
 e) Mirour 132/33 kV T1 transformer was shut down at 10:30 for CB maintenance and was switched on at 18:55.

g) Haripur-412 MW EGCB is under shut down since 00:09(16/3/15) due to air filter replacement.
h) Haripur SBU #2 & #3 tripped at 05:45(16/3/15) due to problem with gas booster and were synchronized at

Executive Engineer

Network Operation Division

i) Shahjibazar GT-9 is under shut down since 05:46(16/3/15) due to air filter replacement.

f) Ghorasal #5 was forced shut down at 18:55 due to boiler tube leakage.

07:24 & 07:36(16/3/15).

Sub Divisional Engineer

Network Operation Division