## POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT QF-LDC-08 Page -1 Reporting Date: 23-Mar-15 7418 MW 21:00 18-Jul-14 Till now the maximum generation is: Hrs on 22-Mar-15 Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand The Summary of Yesterday's ( Hour: 11:00 Day Peak Generation 5761.0 Min. Gen. at 5175 Evening Peak Generation 7192.0 MWHour: 20:00 Max Generation 7285 MWE.P. Demand (at gen end): 7192.0 MW 20:00 Max Demand 7250 MWHour: 7192.0 Maximum Generation MW Hour: 20:00 Shortage -35 MWTotal Gen. (MKWH) 140.6 System L/ Factor 81.48% Load Shed 0 MWEXPORT/IMPORT THROUGH EAST-WEST INTERCONNECTOR Export from East grid to West grid :- Maximum 17:00 MKWHR. -240 Energy 7.867 Import from West grid to East grid :- Maximum MW Energy MKWHR. at Water Level of Kaptai Lake at 6:00 A M on 23-Mar-15 87.64 Ft.(MSL) 89.48 Ft.( MSL ) Rule curve Actual: 926.03 MMCFD. Gas Consumed: Total Oil Consumed (PDB): HSD : Liter FO Liter Cost of the Consumed Fuel (PDB+Pvt): Tk73,627,166 Gas : Coal Tk8,827,904 Oil : Tk471,161,290 Total: Tk553,616,360 **Load Shedding & Other Information** Area Yesterday Today Estimated Demand (S/S end) Estimated Shedding (S/S end) Rates of Shedding MW MW MW (On Estimated Demand) Dhaka 0.00 2637 Chittagong Area 0:00 683 Khulna Area 0:00 749 Rajshahi Area 0:00 722 Comilla Area 0:00 496 Mymensingh Area 0.00 405 Sylhet Area 0:00 330 Barisal Area 0.00 146 Rangpur Area 0:00 415 Total 0 6583 0 Information of the Generating machines under shut down Planned Shut- Down Forced Shut- Down 1) Ghorasal ST: Unit-6 (18/07/2010) 09) Sikalbaha 60 MW (18/03/2015) 1) Haripur GT: Unit-3 (18/06/2009) 2) Ashuganj ST: Unit-1(23/08/2014) 10) Barapukuria ST: Unit-1(20/03/2015) 3) Khulna ST 110 MW (04/11/2014) 11) Ghorasal ST:Unit-3 (22/03/2015) 4) Fenchuganj CCPP-1 ST (07/11/2014) 5) Baghabari GT 100 MW (01/12/2014) 6) Ghorasal ST:Unit-4 (05/01/2015) 7)Chittagong ST: Unit-1 (10/03/2015) 8) Haripur 412 MW CCPP (16/03/2015) Additional Information of Machines, lines, Interruption / Forced Load shed etc. Description Forced load shaded / Interrupted Areas a) Ashugani 225 MW CCPP was synchronized at 08:45 and was shut down at 16:46.

Superintendent Engineer

**Load Dispatch Circle** 

b) Kulshi-Madanaghat 132 kV Ckt-2 was shut down from 09:20 to 15:05 due to A/M.

h) Jamalpur 132/33 kV T1 & T3 transformers were shut down at 06:55 due to project work.

) Sylhet-Fenchuganj 132 kV Ckt was shut down at 07:16 due to CB problem at Sylhet end.

g) Ashuganj GT-2 was synchronized at 20:05.

Sub Divisional Engineer

Network Operation Division

end and was switched on at 11:40(23/03/2015).

c) Rangpur 132 kV Bus was under shut down from 09:50 to 12:25 due to B-phase isolator maintenance.
d) Bheramara 132 /33 kV T2 transformer was under shut down 10:20 to 13:44 due to 33 kV incomer CB pole change.
e) Sirajgonj 132/33 kV T3 transformer tripped at 15:10 showing O/C relay at 33 kV end and was switched on at 15:20.
f) Netrokona 132/33 kV T2 transformer tripped at 18:38 showing O/C, under voltage relay and was switched on at 18:50.

) Rampura-Ghorashal 230 kV Ckt-2 was shut down at 07:15(23/03/2015) due to L/A replacement work at Rampura

**Executive Engineer** 

**Network Operation Division**