

POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT										OF-LDC-08 Page -1
					Reporting Date : 25-Mar-15					
Till now the maximum generation is :-					7418 MW		21:00		Hrs on 18-Jul-14	
The Summary of Yesterday's (24-Mar-15					Today's Actual Min Gen. & Probable Gen. & Demand					
Day Peak Generation :		6256.0		MW		Hour :		11:00		
Evening Peak Generation :		7335.0		MW		Hour :		21:00		
E.P. Demand (at gen end) :		7335.0		MW		Hour :		21:00		
Maximum Generation :		7335.0		MW		Hour :		21:00		
Total Gen. (MKWH) :		150.2		System L/ Factor :		85.32%		Load Shed :		
EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR										
Export from East grid to West grid :- Maximum					-120		MW at 15:00		Energy 7.867	
Import from West grid to East grid :- Maximum					-		MW at -		Energy -	
Water Level of Kaptai Lake at 6:00 A M on					25-Mar-15					
Actual :		87.64		Ft.(MSL) ,		Rule curve :		89.16 Ft.(MSL)		
Gas Consumed : Total 932.14 MMCFD. Oil Consumed (PDB) :										
HSD : Liter										
FO : Liter										
Cost of the Consumed Fuel (PDB+Pvt) :					Gas : Tk75,270,282					
					Coal : Tk15,819,917		Oil : Tk529,793,756		Total : Tk620,883,956	
Load Shedding & Other Information										
Area										
Yesterday										
Estimated Demand (S/S end)										
Today										
Estimated Shedding (S/S end)										
Rates of Shedding (On Estimated Demand)										
MW										
MW										
Dhaka - 0:00 2726 - -										
Chittagong Area - 0:00 707 - -										
Khulna Area - 0:00 777 - -										
Rajshahi Area - 0:00 748 - -										
Comilla Area - 0:00 513 - -										
Mymensingh Area - 0:00 418 - -										
Sylhet Area - 0:00 341 - -										
Barisal Area - 0:00 151 - -										
Rangpur Area - 0:00 428 - -										
Total 0 6809 0										
Information of the Generating machines under shut down.										
Planned Shut- Down										
Forced Shut- Down										
1) Haripur GT: Unit-3 (18/06/2009)										
1) Ghorasal ST: Unit-6 (18/07/2010) 09) Sikalbaha 60 MW (18/03/2015)										
2) Ashuganj ST: Unit-1(23/08/2014) 10) Ghorasal ST:Unit-3 (22/03/2015)										
3) Khulna ST 110 MW (04/11/2014)										
4) Fenchuganj CCPP-1 ST (07/11/2014)										
5) Baghabari GT 100 MW (01/12/2014)										
6) Ghorasal ST:Unit-4 (05/01/2015)										
7)Chittagong ST: Unit-1 (10/03/2015)										
8) Haripur 412 MW CCPP (16/03/2015)										
Additional Information of Machines, lines, Interruption / Forced Load shed etc.										
Description										
Forced load shaded / Interrupted Areas										
a) Rampura-Bashundhara 132 kV Ckt-2 was under shut down from 08:15 to 17:48 due to soil test at Rampura end.										
b) Madaripur 132/33 kV T2 transformer was under shut down from 09:13 to 09:42 due to red hot maintenance.										
c) Khulshi-Madunaghat 132 kV Ckt-2 was under shut down from 09:15 to 13:32 due to A/M.										
d) Gallamari 132/33 kV T2 transformer was under shut down from 12:22 to 14:19 due to red hot maintenance.										
e) Madunaghat-Khulshi 132 kV Ckt-1 was under shut down from 13:45 to 14:15 due to red hot maintenance.										
f) Noapara-Jessore 132 kV Ckt-1 & 2 tripped at 19:42 from both end showing E/F & dist.relay and were switched on at 19:48 & 19:50 respectively.										
g) Ashuganj 132/33 kV OAT12 was under shut down from 06:35 to 11:02 (25/03/2015) due to red hot maintenance.										
h) Jamalpur 132/33 kV T1 transformer was under shut down from 06:47 to 09:07(25/03/2015) due to SAS operation.										
i) Bakulia 132/33 kV T1 transformer is under shut down since 06:50 (25/03/2015) due to red hot maintenance.										
j) Sylhet 33 kV bus was under shut down from 06:47 to 08:20 (25/03/2015) due to 33 kV bus maintenance.										
Power interruption occurred (about 222 MW) under Jessore,Jhenidah, Magura & Chuadanga S/S areas from 19:42 to 19:50.										
Power interruption occurred (about 08 MW) under Jamalpur S/S areas from 06:47 to 09:07 (25/03/2015).										
Power interruption occurred (about 40 MW) under Bakulia S/S areas from 06:50 to till now (25/03/2015).										
Power interruption occurred (about 25 MW) under Sylhet S/S areas from 06:47 to 08:20 (25/03/2015).										
Sub Divisional Engineer Network Operation Division			Executive Engineer Network Operation Division			Superintendent Engineer Load Dispatch Circle				