

**POWER GRID COMPANY OF BANGLADESH LTD.
NATIONAL LOAD DESPATCH CENTER
DAILY REPORT**

OF-LDC-08
Page -1

Till now the maximum generation is :-		7418 MW		21:00		Hrs on 18-Jul-14		Reporting Date : 9-Apr-15	
The Summary of Yesterday's (8-Apr-15		Generation & Demand		Today's Actual Min Gen. & Probable Gen. & Demand			
Day Peak Generation :	4831.0	MW	Hour :	12:00	Min. Gen. at	6:00	4630	MW	
Evening Peak Generation :	6608.0	MW	Hour :	19:30	Max Generation	:	6980	MW	
E.P. Demand (at gen end) :	6608.0	MW	Hour :	19:30	Max Demand	:	6900	MW	
Maximum Generation :	6608.0	MW	Hour :	19:30	Shortage	:	-80	MW	
Total Gen. (MKWH) :	109.8	System L/ Factor	:	69.21%	Load Shed	:	0	MW	
EXPORT /IMPORT THROUGH EAST-WEST INTERCONNECTOR									
Export from East grid to West grid :-		Maximum		-40		MW	at	2:00	Energy 7.867 MKWHR.
Import from West grid to East grid :-		Maximum		-		MW	at	-	Energy - MKWHR.
Water Level of Kaptai Lake at 6:00 A M on				9-Apr-15					
Actual :		87.64		Ft.(MSL) ,		Rule curve :		86.40 Ft.(MSL)	
Gas Consumed : Total		936.64		MMCFD.		Oil Consumed (PDB) :		HSD : Liter	
								FO : Liter	
Cost of the Consumed Fuel (PDB+Pvt) :		Gas :		Tk59,996,062					
		Coal :		Tk5,546,734		Oil :		Tk194,149,691 Total : Tk259,692,488	
Load Shedding & Other Information									
Area									
Yesterday									
MW									
Estimated Demand (S/S end)									
MW									
Today									
Estimated Shedding (S/S end)									
MW									
Rates of Shedding (On Estimated Demand)									
Dhaka - 0:00 2589 - -									
Chittagong Area - 0:00 669 - -									
Khulna Area - 0:00 733 - -									
Rajshahi Area - 0:00 708 - -									
Comilla Area - 0:00 486 - -									
Mymensingh Area - 0:00 399 - -									
Sylhet Area - 0:00 325 - -									
Barisal Area - 0:00 144 - -									
Rangpur Area - 0:00 408 - -									
Total 0 6461 0									
Information of the Generating machines under shut down.									
Planned Shut- Down									
Forced Shut- Down									
1) Ghorasal ST: Unit-6 (18/07/2010) 09) B.Pukuria-2(7/4/15)									
2) Ashuganj ST: Unit-1(23/08/2014) 10) Siddiganj GT-2(8/4/15)									
3) Khulna ST 110 MW (04/11/2014) 11) Fenchuganj GT-3,4,ST(8/4/15)									
4) Fenchuganj CCGP-1 ST (07/11/2014)									
5) Baghabari GT 100 MW (01/12/2014)									
6) Ghorasal ST:Unit-4 (05/01/2015)									
7) Haripur 412 MW CCGP (16/03/2015)									
8) Siddhirgonj ST (29/03/2015)									
Additional Information of Machines, lines, Interruption / Forced Load shed etc.									
Description									
Forced load shaded / Interrupted Areas									
a) Gopalganj S/S-Gopalganj P/S 132 kV Ckt was under shut down from 09:30 to 11:52 due to red hot maintenance at main bus of Gopalganj end.									
b) Ullon-Siddirganj 132 kv Ckt-1 was under shut down from 08:34 to 14:42 due to red hot maintenance at T-joint of R-phase at Siddirganj end.									
c) Khulna(s)-Khulna @ 132 kV Ckt-1 was under shut down from 09:28 to 16:21 due to equipment painting.									
d) Serajganj 132/33 kV T3 transformer was under shut down from 09:10 to 11:40 due to 33 kV R-phase bushing spark.									
e) Saidpur-Purbasadipur 132 kV Ckt-1 was under shut down from 09:50 to 11:05 due to red hot maintenance at R-phase CT at Saidpur end.									
f) Ishurdi 230/132 kV T03 transformer was under shut down from 09:46 to 13:44 due to red hot maintenance at 230 kV DS.									
g) Saidpur 132/33 kV T2 transformer was under shut down from 12:25 to 12:35 due to red hot maintenance at 33 kV incomer CT.									
h) Ishurdi-Baghabari 132 kV Ckt was under shut down from 13:10 to 23:45 due to sky wire cut.									
i) Ghorasal-Ashuganj 132 kV Ckt-2 was shut down from 13:29 to 17:35 due to hydraulic oil replacement at Ashuganj end.									
j) Naogaon 132/33 kV T3 transformer was under shut down from 10:20 to 18:05 due to painting.									
k) Ishurdi 132/33 kV T2 transformer was under shut down from 21:30 to 22:18 due to smoke coming out from 33 kV incomer breaker.									
l) Comilla(S) 132/33 kV T2 transformer was under shut down from 21:30 to 22:10 due to red hot maintenance at 33 kv feeder.									
m) Siddirganj GT-2 was shut down at 22:51 due to filter washing.									
n) Comilla(N)-Comilla(S)-Feni 132 kV Ckt was under shut down from 23:03 to 01:16(9/4/15) due to red hot maint. at Comilla(S) end.									
o) Sylhet-Chatak 132 kV Ckt-2 tripped at 04:37(9/4/15) showing dist.Z2 and was switched on at 06:12(9/4/15).									
Sub Divisional Engineer									
Executive Engineer									
Superintendent Engineer									
Network Operation Division									
Network Operation Division									
Load Dispatch Circle									