## POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT OF-LDC-08 Page -1 Reporting Date : 15-Apr-15 30-Apr-15 Till now the maximum generation is: 7571 MW 21:00 Hrs The Summary of Yesterday's ( 29-Apr-15 Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand Hour: 12:00 Day Peak Generation 5576.0 MW Min. Gen. at 6:00 4986 MW Evening Peak Generation 7111.0 MW Hour: 20:00 Max Generation 7535 MW E.P. Demand (at gen end) 7111.0 MWHour: 20:00 Max Demand 7400 MW Maximum Generation 7111.0 MW Hour: 20:00 Shortage -135 MW Total Gen. (MKWH) 134.5 System L/ Factor 78.82% Load Shed 0 MW EXPORT/IMPORT THROUGH EAST-WEST INTERCONNECTOR Export from East grid to West grid :- Maximum MW 4:00 Energy 7.867 MKWHR Import from West grid to East grid :- Maximum MW Energy MKWHR Water Level of Kaptai Lake at 6:00 A M on 30-Apr-15 Ft.(MSL) Rule curve 82.20 Ft.( MSL ) Gas Consumed: Total 1076.01 MMCFD. Oil Consumed (PDB): HSD FO Liter Cost of the Consumed Fuel (PDB+Pvt) : Tk71,291,109 Gas Coal Tk14,882,436 : Tk169,847,083 Total: Tk256,020,627 Area Today Yesterday Estimated Demand (S/S end) Estimated Shedding (S/S end) Rates of Shedding MW MW MW (On Estimated Demand) Dhaka 0:00 2810 0:00 731 Chittagong Area Khulna Area 0:00 803 772 Raishahi Area 0:00 529 Comilla Area 0:00 Mymensingh Are 0:00 430 350 Sylhet Area 0:00 Barisal Area 0:00 155 Rangpur Area 0:00 440 Total 7020 Information of the Generating machines under shut down Planned Shut- Down Forced Shut- Down 1) Ghorasal ST: Unit-6 (18/07/2010) 9) Haripur SBU-1,2 2) Ashuganj ST: Unit-1(23/08/2014) 3) Khulna ST 110 MW (04/11/2014) 4) Ghorasal ST: Unit-4 (05/01/2015) 5) Baghabari GT 100 MW (01/12/2014) 6) Rongpur GT:(17/04/2015) 7) Meghnaghat CCPP-ST:(21/04/2015) 8) Fenchuganj ST(8/4/15) Additional Information of Machines, lines, Interruption / Forced Load shed etc. Description Forced load shaded / Interrupted Areas About 48 MW Power interruption occurred under Shyampur S/S area a) Shyampur 132/33 kV T3 & T4 Transformers were under shut down from 07:50 to 08:42 due to red hot at 33 kV IG gate feeder. from 07:50 to 08:42. b) Joydevpur-Kabirpur 132 kV Ckt-1 was shut down at 08:11 for Kadda project. c) Meghnaghat S/S-Meghnaghat (AES) P/S 230 kV Ckt was under shut down from 09:36 to 17:40 due to d) Bogra-Sirajganj 132 kV Ckt-2 was under shut down from 09:41 to 13:09 for breaker shifting at Bogra end. e) Manikganj 132/33 kV GT2 Transformer was under shut down from 12:20 to 13:23 to attend torn strand at 33 kV About 15 MW Power interruption occurred under Manikganj S/S area side breaker to bus conductor. from 12:20 to 13:23. Sirajganj 225 MW tripped at 15:06 due to gas booster problem and GT was synchronized at 18:05 and ST was synchronized at 19:39. g) Ghorasal-Joydevpur 132 kV Ckt-1& 2 tripped at 16:23 from Ghorasal end of Ckt-1 showing Z2,ABC and About 111 MW Power interruption occurred under Joydevpur S/S area Joydevpur end of Ckt-2 and were switched on at 16:50 & 16:56 respectively. from 16:23 to 16:50. n) After maintenance Ashuganj Modular is synchronized at 07:29 (30/04/2015). Faridpur 132/33 kV T1 & T2 Transformers 33 kV incomer CB tripped at 16:07 showing instantaneous E/F due to 33 kV Rajbari feeder fault and were switched on at 16:12. About 60 MW Power interruption occurred under Faridpur S/S area from 16:07 to 16:12. Ullon 132/33 kV T3 Transformer is under shut down from 05:37 to 07:51 (30/04/2015) due to red hot at About 17 MW Power interruption occurred under Ullon S/S area from 05:37 to 07:51(30/04/2015). R-phase isolator of 33 kV feeder.

Superintendent Engineer

Load Dispatch Circle

Executive Engineer

Network Operation Division

Sub Divisional Engineer

Network Operation Division