				DESPATCH CENTER EPORT		Reporting Date :	22-Mav-15	Pag
	kimum generation is :		7747 MW	21:00	Hrs on	20-May-15		
The Summary of		21-May-15	Generation & Demand	10.00		Min Gen. & Proba		
Day Peak Generation		6652.0	MW Hour:	12:00	Min. Gen. at	7:00	5412	MW
vening Peak Gene		7442.0 7442.0	MW Hour : MW Hour :	21:00 21:00	Max Generation Max Demand	:	7270 7000	MW MW
P. Demand (at ge Aaximum Generat		7442.0	MW Hour:	22:00			-270	MW
otal Gen. (MKWF		7454.0 160.0	System L/ Factor :	89.43%	Shortage Load Shed	:	-270	MW
otai Gen. (WIK WI	i) .		ORT / IMPORT THROUGH EAST-		Load Slied	•	0	191 99
xport from East g	rid to West grid :- Max		-100	MW at	10:00	Energy	7.867	MKWH
	grid to East grid :- Max		-	MW at	-	Energy	-	MKWH
			i Lake at 6:00 A M on	22-May-15				
Actual :	87.64 Ft.(N	ISL),		Rule curve : 78.00	Ft.( MSL )			
Gas Consumed :	Total	1053.05	MMCFD.	Oil Consumed	(PDB) :	UCD		<b>T</b> 1.
						HSD : FO :		Liter Liter
						FO :		Liter
ost of the Consum	ned Fuel (PDB+Pvt) :	Gas :	Tk70,059,489					
lost of the Collsuit	ieu Fuer (FDB+Fvi).	Coal :	Tk13,671,533		: Tk465,522,101	Total 1	Fk549,253,124	
		coai .	1K15,071,55	Oli	. 18403,322,101	10141 . 1	1KJ49,2J3,124	
	Load S	Shedding & Oth	er Information					
Anna Vantandari				Today				
Area	Yesterday		Estimated Demand	(\$/\$ end)	Estimated Shedd	ing (S/S and)	Rates of Shed	dina
	MW		Estimated Demand (	joro enu)	Esumated Shedd		On Estimated	
Dhaka	191 99	0:00	2690		-		on commandu .	comaliu)
hittagong Area		0:00	687					
hulna Area		0:00	765			-	-	
ajshahi Area		0:00	698			-	-	
Comilla Area		0:00	561			-	-	
fymensingh Area		0:00	428			-	-	
vlhet Area		0:00	316			-	-	
arisal Area	-	0:00	149			-	-	
Rangpur Area	-	0:00	423			-	-	
	-							
otal	0		6717			0		
	Information of the G	enerating machin	nes under shut down.					
	information of the c	cherating machin	les under shar down.					
	Planned Shut- Down			Forced Shut-Do	own	_		
					": Unit-6 (18/07/2010			
					1: Unit-1(28/04/2015			
					3) Khulna ST 110 MW (04/11/2014) 11) Barapukuria Unit-2 (22/05/2015) 4) Ghorasal ST: Unit-4 (05/01/2015)			
				5) Sikalbaha S		9		
					CCPP-ST:(21/04/2	015)		
					CCPP-2:ST(8/4/15)	.010)		
					eaking GT(12/05/20	15)		
						,		
	· · · · · · · · · · · · · · · · · · ·	· · · · · · · · · · · · · · · · · · ·	es, Interruption / Forced Load shed etc.					
	Additional Information	or wrachines, ini	s, interruption / Forceu Load siled etc.					
	Description				ded / Interrupted Ar	eas		
			shut down from 08:23 to 17:30 due to	o painting works.				
			on at 10:05 and 09:59 respectively.					
			at 09:38 & 09:42 respectively.					
			nowing O/C relay and was switched					
			6:37 from both ends showing dist.rel					
) Mymensingh-K			ut down from 17:11 to 18:12 due to a					
) Mymensingh-K Sonargaon-Dau		inpped at 22:3	o nom olion end showing 0/C, C-PI	lase relay and were switched on at				
) Mymensingh-K ) Sonargaon-Dau ) Ullon-Siddhirga	anj 132 kV Ckt-1 & 2		/2015) due to coal mill maintenance.					
) Mymensingh-K ) Sonargaon-Dau ) Ullon-Siddhirga 00:08 (22/05/20	anj 132 kV Ckt-1 & 2 15	t 00.49 (22/05			he			
) Mymensingh-K Sonargaon-Dau ) Ullon-Siddhirga 00:08 (22/05/20 ) Barapukuria Ur	anj 132 kV Ckt-1 & 2 15 nit-2 was shut down a			C (Gae Station) and was even bronize				
) Mymensingh-K Sonargaon-Dau ) Ullon-Siddhirga 00:08 (22/05/20 ) Barapukuria Ur Siddhirganj GT-	anj 132 kV Ckt-1 & 2 15 nit-2 was shut down a -2 was forced shut dow		2/05/2015) due to problem with RMS	6 (Gas Station) and was synchronize				
<ul> <li>Mymensingh-K</li> <li>Sonargaon-Dau</li> <li>Ullon-Siddhirga</li> <li>00:08 (22/05/20)</li> <li>Barapukuria Ur</li> <li>Siddhirganj GT- at 06:36 (22/05/</li> </ul>	anj 132 kV Ckt-1 & 2 15 nit-2 was shut down a -2 was forced shut dow /2015).	wn at 05:39 (2	2/05/2015) due to problem with RMS					
<ul> <li>Mymensingh-K</li> <li>Sonargaon-Dau</li> <li>Ullon-Siddhirga</li> <li>00:08 (22/05/20</li> <li>Barapukuria Ur</li> <li>Siddhirganj GT- at 06:36 (22/05/</li> <li>Rampura 230/1</li> </ul>	anj 132 kV Ckt-1 & 2 15 nit-2 was shut down a -2 was forced shut dow /2015).	wn at 05:39 (2	2/05/2015) due to problem with RMS	5 (Gas Station) and was synchronize				
<ul> <li>Mymensingh-K</li> <li>Sonargaon-Dau</li> <li>Ullon-Siddhirga</li> <li>00:08 (22/05/20)</li> <li>Barapukuria Ut</li> <li>Siddhirganj GT-</li> <li>at 06:36 (22/05/</li> <li>Rampura 230/1</li> <li>230 kV side.</li> </ul>	anj 132 kV Ckt-1 & 2 15 nit-2 was shut down a 2 was forced shut dov (2015). 132 kV T02 transforme	wn at 05:39 (2 er was under s	2/05/2015) due to problem with RMS shut down from 06:02 to 08:55 (22/0	5/2015) due to high temperature of b	oushing of	occurred under S	avar S/S area	as from
) Mymensingh-K I Sonargaon-Dau I) Ullon-Siddhirga 00:08 (22/05/20 I) Barapukuria Ur Siddhirganj GT- at 06:36 (22/05) Rampura 230/1 230 kV side. ) Savar 132/33 k	anj 132 kV Ckt-1 & 2 15 nit-2 was shut down a 2 was forced shut dov (2015). 132 kV T02 transformer VT1 transformer tripp	wn at 05:39 (2 er was under s	2/05/2015) due to problem with RMS shut down from 06:02 to 08:55 (22/0	5/2015) due to high temperature of b relay and was switcheAbout 70 MW	oushing of	occurred under S	avar S/S area	as from
) Mymensingh-K I Sonargaon-Dau I) Ullon-Siddhirga 00:08 (22/05/20 I) Barapukuria U Siddhirganj GT- at 06:36 (22/05/ Rampura 230/1 230 kV side. ) Savar 132/33 k 0 nat 12:32 (22/0	anj 132 kV Ckt-1 & 2 15 nit-2 was shut down a 2 was forced shut dow (2015). 132 kV T02 transformer tripp (5/2015).	wn at 05:39 (2 er was under s bed at 06:22 (2	2/05/2015) due to problem with RMS shut down from 06:02 to 08:55 (22/08 22/05/2015) showing buchholz & diff	5/2015) due to high temperature of b relay and was switcheAbout 70 MW	oushing of power interruption 2 (22/05/2015).	occurred under S	avar S/S area	as from
<ul> <li>Mymensingh-K</li> <li>Sonargaon-Dau</li> <li>Ullon-Siddhirga</li> <li>00:08 (22/05/20)</li> <li>Barapukuria U</li> <li>Siddhirganj GT- at 06:36 (22/05/ Rampura 230/7</li> <li>230 kV side.</li> <li>Savar 132/33 k</li> <li>on at 12:32 (22/0 Savar 132/33 k</li> <li>Bashundhara 12</li> </ul>	anj 132 kV Ckt-1 & 2 15 nit-2 was shut down a 2 was forced shut dor (2015). 132 kV T02 transformer tripp (5/2015). V T1 transformer tripp (5/2015).	wn at 05:39 (2 er was under s bed at 06:22 (2 ed at 06:22 (2	2/05/2015) due to problem with RMS shut down from 06:02 to 08:55 (22/0 22/05/2015) showing buchholz & diff 2/05/2015) showing O/C relay at bol	5/2015) due to high temperature of b relay and was switcheAbout 70 MW 06:22 to 06:33	oushing of power interruption 2 (22/05/2015). 32 (22/05/2015)	occurred under S	avar S/S area	as from
Mymensingh-K Sonargaon-Data Ullon-Siddhirgan Outox (22/05/20) Barapukuria Ur Siddhirganj GT- at 06:36 (22/05) Rampura 230/1 230 kV side. Savar 132/33 k n at 12:32 (22/0 Savar 132/33 k) Bashundhara 13	anj 132 kV Ckt-1 & 2 15 nit-2 was shut down a 2 was forced shut dor (2015). 132 kV T02 transformer tripp (5/2015). V T1 transformer tripp (5/2015).	wn at 05:39 (2 er was under s bed at 06:22 (2 ed at 06:22 (2	2/05/2015) due to problem with RMS shut down from 06:02 to 08:55 (22/0 22/05/2015) showing buchholz & diff 2/05/2015) showing O/C relay at bol	5/2015) due to high temperature of b relay and was switche About 70 MW 06:22 to 06:33 th sides and was switched on at 06:3	oushing of power interruption 2 (22/05/2015). 32 (22/05/2015)	occurred under S	avar S/S area	as from
Mymensingh-K Sonargaon-Data Ullon-Siddhirgan Oi0:08 (22:05/20 Barapukuria Ur Siddhirganj GT- at 06:36 (22/05/ Rampura 230/1 230 kV side. Savar 132/33 kl Savar 132/33 kl Bashundhara 13	anj 132 kV Ckt-1 & 2 15 nit-2 was shut down a 2 was forced shut dor (2015). 132 kV T02 transformer tripp (5/2015). V T1 transformer tripp (5/2015).	wn at 05:39 (2 er was under s bed at 06:22 (2 ed at 06:22 (2	2/05/2015) due to problem with RMS shut down from 06:02 to 08:55 (22/0 22/05/2015) showing buchholz & diff 2/05/2015) showing O/C relay at bol	5/2015) due to high temperature of b relay and was switche About 70 MW 06:22 to 06:33 th sides and was switched on at 06:3	oushing of power interruption 2 (22/05/2015). 32 (22/05/2015)	occurred under S	avar S/S area	as from
) Mymensingh-K Sonargaon-Dau Ullon-Siddhirg 00:08 (22/05/20) Barapukuria UJ Siddhirganj GT- at 06:36 (22/05/ Rampura 230/1/ 230 kV side. ) Savar 132/33 k ) Bashundhara 13 from Tongi to Rar	anj 132 kV Ckt-1 & 2 15 11 <sup>12</sup> was shut down a 2 was forced shut dow (2015). 132 kV T02 transformer (5/2015). V T1 transformer tripp (5/2015). V T2 transformer tripp 32/33 kV T2 & T3 trans mpura.	wn at 05:39 (2 er was under s bed at 06:22 (2 ed at 06:22 (2	2/05/2015) due to problem with RMS shut down from 06:02 to 08:55 (22/0 22/05/2015) showing buchholz & diff 2/05/2015) showing O/C relay at bot i/ited from Rampura to Tongi at 07:50 (;	5/2015) due to high temperature of b relay and was switche About 70 MW 06:22 to 06:33 th sides and was switched on at 06:3	oushing of power interruption 2 (22/05/2015). 32 (22/05/2015)			
Mymensingh-K Sonargaon-Data Ullon-Siddhirgan Ou0x8 (22/05/20) Barapukuria Ur Siddhirganj GT- at 06:36 (22/05) Rampura 230/1 230 kV side. Savar 132/33 k In at 12:32 (22/0 Savar 132/33 k) Bashundhara 13	anj 132 kV Ckt-1 & 2 15 11 <sup>12</sup> was shut down a 2 was forced shut dow (2015). 132 kV T02 transformer (5/2015). V T1 transformer tripp (5/2015). V T2 transformer tripp 32/33 kV T2 & T3 trans mpura.	wn at 05:39 (2 er was under s bed at 06:22 (2 ed at 06:22 (2	2/05/2015) due to problem with RMS shut down from 06:02 to 08:55 (22/0 22/05/2015) showing buchholz & diff 2/05/2015) showing O/C relay at bol	5/2015) due to high temperature of b relay and was switche About 70 MW 06:22 to 06:33 th sides and was switched on at 06:3	oushing of power interruption 2 (22/05/2015). 32 (22/05/2015)		avar S/S area	

Network Operation Division

Executive Engineer Network Operation Division

Superintendent Engineen Load Dispatch Circle