POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT OF-LDC-08 Page -1 Reporting Date : 6-Jul-15 25-Jul-15 Till now the maximum generation is : 21:00 Hrs The Summary of Yesterday's (24-Inl-15 Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand 12:00 Day Peak Generation 4676.0 MW Hour Min. Gen. at 7:00 4118 MW Evening Peak Generation 6512.0 MW Hour: 21:00 Max Generation 7058 MW E.P. Demand (at gen end): 6508.0 MW Hour : 21:00 Max Demand 6800 MW Maximum Generation 6508.0 MW Hour : 21:00 Shortage -258 MW Total Gen. (MKWH) System L/ Factor 126.0 80.70% Load Shed 0 MW EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR Export from East grid to West grid :- Maximum -180 MW a 10:00 Energy 7.867 MKWHR. MW Import from West grid to East grid :- Maximum Energy MKWHR Water Level of Kaptai Lake at 6:00 A M on 25-Jul-15 Ft.(MSL) Actual: Ft.(MSL) Rule curve 87.84 934.08 MMCFD. Oil Consumed (PDB): Gas Consumed: Total HSD FO Liter Cost of the Consumed Fuel (PDB+Pvt): Tk64,263,940 Gas Coal Tk16,483,963 : Tk205,263,035 Total: Tk286,010,938 Load Shedding & Other Information Area Yesterday Today Estimated Demand (S/S end) Estimated Shedding (S/S end) Rates of Shedding MW MW MW (On Estimated Demand) Dhaka 0:00 2591 Chittagong Area 0:00 660 Khulna Area 0:00 734 Rajshahi Area 0:00 689 Comilla Area 0:00 542 Mymensingh Area 0:00 414 Sylhet Area 0:00 305 Barisal Area 0:00 144 398 Rangpur Area 0:00 6477 Total Information of the Generating machines under shut down Planned Shut- Down 1) Ghorasal ST: Unit-6 (18/07/29) Chittagong ST: Unit-1(17/07/2015) 2) Ashuganj ST: Unit-1(28/04/210) Ghorasal ST: Unit-3 (17/07/2015) 3) Khulna ST 110 MW (04/11/2 11) Chandpur CCPP (16/07/2015) 4) Ghorasal ST: Unit-4 (05/01/212) Sikalbaha ST (21/07/2015) 5) Haripur GT 3 (24/05/2015) 6) Meghnaghat CCPP-ST:(21/04/2014) 7) Fenchuganj New ST(31/5/15) 8) Haripur-412 MW (25/5/15) Additional Information of Machines, lines, Interruption / Forced Load shed etc. Description Forced load shaded / Interrupted Areas a) Saidpur-Purbasadipur 132 kV L1 was under shut down from 11:15 to 11:45 due to R/H of CT terminal at saidpur end. b) Gopalganj 132 kV bus was under shut down from 08:08 to 08:38 due to R/H at main bus isolator loop R& Y phase. About 19 MW power interruption occurred under Gopalganj S/S from 08:08 to c) After maintenance Rampura-Ghorashal 230 kV Ckt-1 was switched on at 15:46. d) After maintenance Ghorashal 230 kV Bus coupler 953B was switched on at 16:07. e) After maintenance Ghorashal-Ashuganj 230 kV Ckt-1 was switched on AT 16:11. f) After maintenance Ghorashal Regent RPP Ckt was switched on at 16:15. g) Shahjadpur 132/33 kV T2 Transformer was shut down at 07:20(25/07/2015) due to CT changing. Sub Divisional Engineer **Executive Engineer** Superintendent Engineer Network Operation Division **Network Operation Division** Load Dispatch Circle