

QF-LDC-08  
Page -1

Reporting Date : 11-Aug-15

11-1000-10

Today's Actual Min Gen. & Probable Gen. & Demand	
Actual Min Gen.	1,000 MW
Probable Min Gen.	1,200 MW
Actual Demand	1,500 MW
Probable Demand	1,800 MW

Min. Gen. at	8:00	6038	MW
Max Generation	:	8321	MW
Max Demand	:	8200	MW
Shortage	:	-121	MW
Load Shed	:	0	MW

8:00	Energy	7.867	MK
-	Energy	-	MK

Rule curve :	11-Aug-15	92.20	Ft.( MSL )
--------------	-----------	-------	------------

HSD	:	Lite
FO	:	Lite

**Total : Tk542,479,501**

Information of the Generating machines under shut down.

Forced Shut-Down
------------------

1) Ghorasal ST: Unit-6 (18/07/2010)	9) Ashuganj GT-2 (7/8/15).
2) Ashuganj ST: Unit-1(28/04/2015)	10) Summit Bibiana-2 (10/08/2015)
3) Khulna ST 110 MW (04/11/2014)	
4) Ghorasal ST: Unit-4 (05/01/2015)	
5) Haripur GT 3 (24/05/2015)	
6) Sikalaha ST (21/07/2015)	
7) Siddhirgonj ST(30/07/2015)	
8) Haripur-412 MW (25/5/15)	

### Description

**Forced load shaded / Interrupted Areas**

a) Faridpur 132/33 kV T1 transformer was shut down from 08:10 to 17:02 due to replacing earthing.

b) Manikganj 132/33 kV T3 & T4 transformers were shut down from 09:10 to 11:16 due to red hot maintenance at 132 kV R-phase isolator.

c) After maintenance Agargaon 230/132 kV T02 transformer was switched on at 13:40.

d) After maintenance Lalbagh-Kallyanpur 132 kV Ckt was switched on at 01:24 (11/08/2015).

e) After maintenance Raazan ST Unit-1 was synchronized on at 04:45 (11/08/2015)

f) Ashuganj-Sirajganj 230 kV Ckt-1 & 2 were shut down since 05:55 (11/08/2015) due to project work.

g) Fenchuganj GT-1 was shut down at 05:21 (11/08/2015) due to combine mode operation.

h) Hathazari-Comilla(N) 230 kV Ckt-2 tripped at 15:58 from Comilla(N) end showing dist & E/F relay.

\*\*\*\* Details of tripping and other information is enclosed herewith in attached report.

About 10 MW Power interruption occurred under Faridpur S/S area from 08:10 to 17:02.

About 10 MW Power interruption occurred under Manikganj S/S area from 09:10 to 11:16.

**Superintendent Engineer**  
**Load Dispatch Circle**