			POWER GRID NATIO	COMPANY NAL LOAD	OF BANGLADESH LTD DESPATCH CENTER PORT									OF-LDC-08
				DAILY RE	PORT					Reportii	ng Date :	21-Aug-15		Page -1
Till now the maximum generation is:-			8177 MW			21:00		on	13-A	ug-15				
The Summary of Yesterday's (20-Aug-15			Generation & Dem					Today's Actual M	in Gen					
Day Peak Generation		6220.0	MW	Hour :			12:00	Min. Gen. at		1	7:00	4470	MW	
Evening Peak Genera		7436.0	MW	Hour :			19:30	Max Generation	:			7748	MW	
E.P. Demand (at gen Maximum Generation		7436.0 7436.0	MW MW	Hour : Hour :			19:30 19:30	Max Demand Shortage	:			7500 -248	MW MW	
Total Gen. (MKWH)		153.5	NW System L/ Factor	Hour:			86.03%	Load Shed	:			-248 0	MW	
Total Gen. (WIK WII)		155.5		ORT THROUG	GH EAST-WEST INTERCO	NNECTOR	00.0570	Load Siled				0	111 11	
Export from East grid to West grid :- Maximum -130							MW at	10:00			Energy	7.867	MKWHR	
Import from West grid to East grid :- Maximum -							MW at	-			Energy	-	MKWHR	
Water Level of Kaptai Lake at 6:00 A M on							21-Aug-15							
Actual: 87.64 Ft.(MSL), Rule cur							: 95.40	Ft.(MSL)						
G G 1	m . 1	1015.20	MACED				07.0	I (DDD)						
Gas Consumed :	Total	1015.20	MMCFD.				Oil Consum	ed (PDB):		HSD			Liter	
										FO	:		Liter	
											-			
Cost of the Consume	ed Fuel (PDB+Pvt) :	Gas :		T	k67,735,403									
		Coal :		T	k11,796,582		Oil :	Tk269,053,103			Total :	Tk348,585,088	3	
	Loa	d Shedding & O	ther Information											
Area	Yesterday							Today						
				Estimate	ed Demand (S/S end)			Estimated Sheddin	g (S/S e	end)		Rates of Shed	ding	
	MW				MW					MW	(On Estimated	Demand)	
Dhaka	-	0:00			2887						-	-		
Chittagong Area	-	0:00			742						-	-		
Khulna Area	-	0:00			828						-	-		
Rajshahi Area	-	0:00			775 599						-	-		
Comilla Area Mymensingh Area	-	0:00			599 456						-	-		
Sylhet Area		0:00			339						-	-		
Barisal Area	_	0:00			159						_	-		
Rangpur Area	-	0:00			441						-	-		
	-													
Total	0				7226					0				
Information of the Generating machines under shut down.														
	Planned Shut- Down						Forced Shut-	Down						
								ST: Unit-6 (18/07/20				Jnit-2 (17/08/2	015)	
						2) Ashuganj ST: Unit-1(28/04/201								
							3) Khulna ST 110 MW (04/11/2014) 11) Barapukuria ST: Unit-1 (20/08/2015) 4) Ghorasal ST: Unit-4 (05/01/2015)							
							(4) Gnorasai S1: Onit-4 (05/01/2015) 5) Haripur GT-3 (24/05/2015)							
							6) Siddhirgonj ST(30/07/2015)							
								12 MW (25/5/15)						
							8) Haripur G	T-1 (17/07/2015)						
	Additional Information	on of Machines, l	lines, Interruption / Fo	rced Load shed e	tc.									
	n						n							
Description							Forced load shaded / Interrupted Areas About 25 MW power interruption occurred under Gallamari S/S area							
a) Gallamari 132/33 kV T1 transformer was shut down from 08:38 to 09:40 due to heavy flashing from 33 kV R-phase incomer. b) Haripur-Siddhirganj 132 kV Ckt-2 tripped at 10:14 from Siddhirganj end showing E/F relay and was switched on at 10:22.							from 08:38 to 09:40.							
c) Bogra 230/132 kV T02 transformer was shut down from 10:10 to 12:40 due to 132 kV CT replacement of Y-phase loop.							00.00							
d) Barapukuria ST:														
e) Hathazari 230/132 kV MT2 transformer tripped at 13:45 showing PRD and was switched on at 14:32.														
f) Kishoreganj 132/33 kV T2 transformer tripped at 15:02 showing winding temperature high and was switched on at 15:58								IW power interrupt	ion occ	curred u	nder Kish	oreganj S/S	area	
again tripped at 16:02 showing same reason and was switched on at 18:10.								2 to 15:58.						
	g) Jhenaidah-Chuadanga 132 kV Ckt tripped at 15:51 showing dist Z1, ABC and was switched on at 15:54.													
h) Summit Bibiyana-2 tripped at 15:49 due to gas inlet valve problem. i) Sylhet 132/33 kV T1 transformer was shut down at 07:05(21/08/2015) due to red hot at 33 kV Y-phase Bus isolator About 10 MW power interruption occurred under Sylhet S/S area														
and was switched on at 10:01.								ivv power interrupt i to 10:01.	.011 000	Janea al	idei öylli	or oro area		
j) Comilla(S) 132/33 kV T2 transformer was shut down from 15:00 to 16:10 due to red hot maintenance at Y-phase 33 kV side.							About 15 MW power interruption occurred under Comilla(N) S/S area							
							from 07:05							
Sub Divisional Engineer							Eventin	e Engineer				Superi-4	endent Enc	incor

Sub Divisional Engineer Network Operation Division Executive Engineer Network Operation Division Superintendent Engineer Load Dispatch Circle