## POWER GRID COMPANY OF BANGLADESH LTD. CENTRAL LOAD DESPATCH CENTER, LDC.DHAKA DAILY REPOR

QF-LDC-08 Page -1

KWHR.

Reporting Date: 15-Jul-09 Till now the maximum generation is: - MW at The Summary of Yesterday's ( ) Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand 10:00 3434 MW Day Peak Generation MW Min Gen. at 3675.4 Hour 7:00 Evening Peak Generation 3805 MW MW 20:00 Max Generation Hour E.P. Demand (at gen end) 4600.0 MW Hour 20:00 Max Demand 4600 MW Maximum Generation 3855.5 MW Hour 23:00 Shortage 795 MW Total Gen. (MKWH) 94.01% Load Shed 667 MW 86.99 EXPORT/IMPORT THROUGH EAST-WEST INTERCONNECTOR Export from East grid to West grid :- Maximum 540 MW at 5:00 Energy 10821000 KWHR.

MW

Oil Consumed (PDB):

Water Level of Kaptai Lake at 6:00 A M of 15-Jul-09
Actual: 80.88 Ft.(MSL), Rule curve: 86.24 Ft.(MSL)

MMCFt.

Actual : 00.00 Ft.(IVISE) , Kule curve : 00.24 Ft.(IVISE

 SKO
 :
 0
 Liter

 HSD
 :
 419717
 Liter

 FO
 :
 103641
 Liter

Energy

Cost of the Consumed Fuel (PDB): Gas : Tk55,234,421 Oil : Tk11,866,719 Total : Tk67,101,140

## Load Shedding & Other Information

747.32

Import from West grid to East grid :- Maximum

Gas Consumed: Total

Area	Yesterday		Today		
	Actual She	edding (s/s end), MW	Estimated Demand(s/s end)	Estimated Shedding (s/s end)	Rates of Shedding
generation shortatge at (19:00)			MW	MW	(On Estimated Demand)
Dhaka	253	(19:40 -cont'd, gen. shortage)	1710	263	15%
Chittagong Area	93	(19:40 -cont'd, gen. shortage)	475	94	20%
Khulna Area	87	(19:40 -cont'd, gen. shortage)	415	82	20%
Rajshahi Area	76	(19:40 -cont'd, gen. shortage)	345	67	19%
Comilla Area	63	(19:40 -cont'd, gen. shortage)	263	51	19%
Mymensing Area	45	(19:40 -cont'd, gen. shortage)	212	43	20%
Sylhet Area	8	(19:40 -21:50, gen. shortage)	194	27	14%
Barisal Area	12	(19:40 -cont'd, gen. shortage)	82	20	24%
Rangpur Area	32	(19:40 -cont'd, gen. shortage)	165	20	12%
		(			
Total	669	20:00	3861	667	

Information of the Generating machines under maintenance

Planned Shut- Down	Forced Shut- Down		
1) Khulna 60 MW (05/07/06)	1) Kaptai- 3 (19/04/08)	8) Barapukuria unit -1 (04/07/09)	
	2) Shajibazar- 2 (13/07/08)	9) Bheramara -3 (18/06/09)	
	3) Shajibazar-4 (18/10/08)	10) Baghabari GT-2(02/07/09)	
	4) Ghorasal-1 (30/09/08)	11) Ghorasi -5(13/07/09)	
	5) Sikalbaha Barge (27/04/09)		
	6) Khulna 110 (31/03/09)		
	7) NEPC 1 unit is under S/D		

## Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description Forced load shaded / Interrupted Areas

- There was generation shortage in the evening peak hour yesterday.
- b) Due to gas limitation, Siddhirganj (190 MW), Raozan (360 MW), RPCL (180 MW), NEPC (95 MW), Haripur Power Co. Ltd. (360 MW) were limited to 150 MW, 240 MW, 106 MW, 30 MW and 290 MW respectively.
- c) Due to gas limitation, Shahjibazar 4 & 5, Haripur SBU GT- 1, 2 & 3 (99 MW) were under shut down.
- d) Sikalbaha Steam was forced shut down at 19:19 due to axial displacement.
- e) Haripur Power Ltd. Steam and GT were shut down at 23:52 and 00:01(15/07/09) due to offline washing of GT compressor. It may be synchronized before evening peak hour today.
- f) Serajganj 132/33 KV T2 transformer and Dohazari 132/33 KV T2 transformer were under NLDC project work from 08:21 to 15:10 and 09:10 to 15:05 respectively.
- g) Mymensing 132/33 KV T1 transformer was under shut down from 09:35 to 10:40 due to maintenance of 132 KV breaker.
- h) Serajganj Baghabari 230 KV line -2 was under shut down from 10:49 to 12:37 due to protection work.
- i) Sylhet 132/33 KV T4 transformer tripped at 11:03 showing 'O/C, due to 33 KV Boroikandi feeder fault and was switched on at 11:20.
- j) Chatak 132/33 KV T2 transformer tripped at 12:30 showing 'O/C' due to 33 KV SPM feeder fault and was switched on at 12:33.

So about 669 MW (20:00) of load shed was imposed over the whole area (except Sylhet) of the national grid.

Partial power interruption (20 MW) occurred under Sylhet S/S, areas from 11:03 to 11:20.

Partial power interruption (1 MW) occurred under Chatak S/S, areas for 3 minutes.

Due to generation shortage and MVAR problem, about 350 MW (10:00) of load shed has been running since morning (15/07/09) over the whole area (except Sylhet) of the national grid.

Deputy / Asstt. Manager Load Despatch Division Manager Load Despatch Division Deputy General Manager Load Despatch Circle