

POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT										QF-LDC-08 Page -1
Till now the maximum generation is :-			8177 MW		21:00		Hrs on		Reporting Date : 9-Oct-15 13-Aug-15	
The Summary of Yesterday's (8-Oct-15		Generation & Demand			Today's Actual Min Gen. & Probable Gen. & Demand		
Day Peak Generation :			6348.0		MW		Hour :		11:00	Min. Gen. at 7:00 4751 MW
Evening Peak Generation :			7742.0		MW		Hour :		19:00	Max Generation : 7934 MW
E.P. Demand (at gen end) :			7742.0		MW		Hour :		19:00	Max Demand : 7600 MW
Maximum Generation :			7742.0		MW		Hour :		19:00	Shortage : 334 MW
Total Gen. (MKWH) :			154.9		System L/ Factor		:		83.37%	Load Shed : 0 MW
EXPORT /IMPORT THROUGH EAST-WEST INTERCONNECTOR										
Export from East grid to West grid :- Maximum					-150		MW		at 9:00	Energy 7.867 MKWHR.
Import from West grid to East grid :- Maximum					-		MW		at -	Energy - MKWHR.
Water Level of Kaptai 9-Oct-15										
Actual :			107.78		Ft.(MSL) ,		Rule curve :		106.63	Ft.(MSL)
Gas Consumed : Total			991.40		MMCFD.		Oil Consumed (PDB) :			
							HSD :			Liter
							FO :			Liter
Cost of the Consumed Fuel (PDB+Pvt) :			Gas :		Tk68,101,909					
			Coal :		Tk14,296,519		Oil :		Tk364,255,965	Total : Tk446,654,392
Load Shedding & Other Information										
Area	Yesterday		Estimated Demand (S/S end)				Today		Rates of Shedding	
	MW		MW				Estimated Shedding (S/S end)		(On Estimated Demand)	
							MW			
Dhaka	- 0:00		2914				-		-	
Chittagong Area	- 0:00		750				-		-	
Khulna Area	- 0:00		836				-		-	
Rajshahi Area	- 0:00		782				-		-	
Comilla Area	- 0:00		604				-		-	
Mymensingh Area	- 0:00		460				-		-	
Sylhet Area	- 0:00		342				-		-	
Barisal Area	- 0:00		160				-		-	
Rangpur Area	- 0:00		445				-		-	
Total	0		7293				0			
Information of the Generating machines under shut down.										
	Planned Shut- Down				Forced Shut- Down					
					1) Ghorasal ST: Unit-6 (18/07/ 9) Raozan-1 (6/10/15) 2) Ashuganj ST: Unit-1(12/09/ 10) Ashuganj : GT-2 3) Summit Bibiana- 2 (23/09/2 11) Ashuganj : ST-2,3(09/10/15) 4) Khulna ST 110 MW (04/11/2014) 5) Ghorasal ST: Unit-4 (05/01/2015) 6) Haripur GT-1,3 7) Sikalbaha ST 8) Haripur-412 MW (25/5/15)					
Additional Information of Machines, lines, Interruption / Forced Load shed etc.										
Description							Forced load shaded / Interrupted Areas			
a) Naogaon 132/33 kV T2 transformer was shut down from 09:30 to 14:45 due to AM.										
b) Kishoreganj 132/33 kV T3 transformer was shut down from 10:01 to 13:45 due to sparking from 33 kV bus Isolator.							About 12 MW power interruption occurred under Kishoreganj S/S area from 10:01 to 13:45			
c) Mymenshing-Kishoreganj 132 kV Ckt-2 was shut down from 11:14 to 11:18 due to CB gas filling at Mymenshing end.										
d) Chatak 132/33 kV T2 transformer was shut down from 12:32 to 13:30 due to tap changing work.										
e) Bhandaria-Barisal 132 kV Ckt tripped at 13:28 from Bhandaria end showing dist Z1,ABC and was switched on at 20:13.										
f) Barapukuria Unit #1 tripped at 12:35 due to primary air fan trip and was synchronized at 15:15.										
g) Hathazari-AKSML 230 kV Ckt tripped at 17:31 from both end due to lightning arrester burst at AKSML end showing dist E/F T phase at Hathazari end .										
h) Fenchuganj GT-3 & 4 tripped at 15:34 due to some electrical fault and GT - 3 was synchronized at 19:49.										
i) Rangpur-Lalmonirhat 132 kV Ckt tripped at 21:10 as B-phase jumper torn at tower #126 and was switched on at 05:30							About 58 MW power interruption occurred under Lalmonirhat S/S area from 21:10 to 05:30(9/10/15)			
j) Ashuganj # 3 was under shut down at 12:33 due to leakage at condenser water wall.										
k) Mymenshing 132/33 kV T1 transformer is under shut down since 06:15 due to 33 kV bus section maintenance work.							About 25 MW power interruption occurred under Mymenshing S/S area since 06:15 (9/10/15)			
l) Ghorasal 100 MW & 45 MW is under shut down since 05:58 due to Ghorasal MAX 230 kV U/G cable installation work.										
m) Hathazari-AKSML 230 kV Ckt is shut down from 07:30 to 09:30 due to lightning arrester maintenance at AKSML end.										
Sub Divisional Engineer Network Operation Division			Executive Engineer Network Operation Division			Superintendent Engineer Load Dispatch Circle				