

Till now the maximum generation is :-				8177 MW		21:00		Hrs on 13-Aug-15		Reporting Date : 23-Oct-15	
The Summary of Yesterday's (				22-Oct-15		Generation & Demand				Today's Actual Min Gen. & Probable Gen. & Demand	
Day Peak Generation :				6370.0		MW		Hour :		12:00	
Evening Peak Generation :				7892.0		MW		Hour :		19:30	
E.P. Demand (at gen end) :				7892.0		MW		Hour :		19:30	
Maximum Generation :				7892.0		MW		Hour :		19:30	
Total Gen. (MKWH) :				162.3		System L/ Factor				85.71%	
EXPORT /IMPORT THROUGH EAST-WEST INTERCONNECTOR											
Export from East grid to West grid :- Maximum						-80		MW		a 17:00	
Import from West grid to East grid :- Maximum						-		MW		a -	
Water Level of Kapt 23-Oct-15											
Actual :				107.01		Ft(MSL) ,				Rule curve : 108.10 Ft( MSL )	
Gas Consumed : Total				1005.11		MMCFD.		Oil Consumed (PDB) :			
								HSD : Liter			
								FO : Liter			
Cost of the Consumed Fuel (PDB+Pvt) :				Gas :		Tk68,268,309					
				Coal :		Tk15,663,669		Oil :		Tk410,618,644 Total : Tk494,550,622	
Load Shedding & Other Information											
Area		Yesterday				Estimated Demand (S/S end)				Today	
		MW				MW				Estimated Shedding (S/S end)	
										Rates of Shedding (On Estimated Demand)	
Dhaka		- 0:00				2944				-	
Chittagong Area		- 0:00				758				-	
Khulna Area		- 0:00				846				-	
Rajshahi Area		- 0:00				791				-	
Comilla Area		- 0:00				610				-	
Mymensingh Area		- 0:00				464				-	
Sylhet Area		- 0:00				346				-	
Barisal Area		- 0:00				162				-	
Rangpur Area		- 0:00				450				-	
Total		0				7371				0	
Information of the Generating machines under shut down.											
		Planned Shut- Down				Forced Shut- Down					
						1) Ghorasal ST: Unit-6 (18/09) Raozan Unit-2 (18/10/2015) 2) Ashuganj ST: Unit-1(12/0 10) Ashuganj : GT-2 3) Khulna 150 MW (16/10/11) Ghorasal ST: Unit-1 4) Khulna ST 110 MW (04/1 12) Sylhet 20 MW GT(14/10/2015) 5) Ghorasal ST: Unit-4 (05/0 13) Summit Bibiana-2(21/10/15) 6) Haripur GT-3 14) Meghnaghat 450 MW (22/10/15) 7) Sikalbaha ST 8) Haripur-412 MW (25/5/15)					
Additional Information of Machines, lines, Interruption / Forced Load shed etc.											
		Description				Forced load shaded / Interrupted Areas					
		a) Bangabhaban-Maniknagar 132 kV Ckt-2 was under shut down since 08:28 due to maintenance work . b) Siddhirganj GT-1 MW GT was under shut down since 07:43(23/10/15) due to maintenance at gas station. c) Meghnaghat GT-1,2 was under shut down since 19:03,19:06 due to gas supply problem. d) After maintenance Summit Bibiyana CCPP was synchronized at 19:01 and was under shut down since 23:59 for fire protection maintenance work. e) Kabirpur 132/33 kV T3 transformer is under shut down since 07:04(23/10/15) due to red hot maintenance work.									
Sub Divisional Engineer		Executive Engineer				Superintendent Engineer					
Network Operation Division		Network Operation Division				Load Dispatch Circle					