					BANGLADESH LTD. SPATCH CENTER									OF-LDC-08
				DAILY REPO						Reportin	σ Date ·	13-Nov-15		Page -1
Till now the maxir			8177 MW				21:00	Hrs o		13-Au	ıg-15			
The Summary of Y		12-Nov-15	Generation & I				12.00	Today's Actual Min	Gen. 8				2 6777	
Day Peak Generation Evening Peak Genera		5558.0 7246.0	MW MW	Hour : Hour :			12:00 18:30	Min. Gen. at Max Generation		7	:00	4097 7430	MW MW	
E.P. Demand (at gen		7246.0	MW	Hour :			18:30	Max Demand				7300	MW	
Maximum Generatio		7246.0	MW	Hour :			18:30	Shortage	:			130	MW	
Total Gen. (MKWH)	: :	130.9	System L/ Factor				75.28%	Load Shed	:			0	MW	
				MPORT THROU	GH EAST-WEST INT	TERCONNECTOR					_			
Export from East grid to West grid :- Maximum Import from West grid to East grid :- Maximum					-60			a 17:00			Energy Energy	7.867	MKWHR MKWHR	
import nom west gri	Wa	iter Level of Kap	t 13-Nov-15				IVI VV	a -			Energy		IVIX WIIN	••
Actual :		.(MSL),				Rule curve	: 107.80	Ft.(MSL)						
Gas Consumed :	Total	1001.82	MMCFD.				Oil Consu	imed (PDB):		HSD			Liter	
													Liter	
											•		Lines	
Cost of the Consume	d Fuel (PDB+Pvt):	Gas :		7	Γk61,828,164									
		Coal :			Tk7,890,427		Oil	: Tk254,961,411			Total : T	k324,680,002		
Load Shedding & Other Information														
Loan Strenning & Vallet Into Intalian														
Area	Yesterday							Today						
				Estimat	ted Demand (S/S end)			Estimated Shedding (S/S end			Rates of Shed		
D1 1	MW	0.00			MW					MW	((On Estimated	Demand)	
Dhaka	-	0:00			2753 705						-	-		
Chittagong Area Khulna Area		0:00			785									
Rajshahi Area	-	0:00			736						-	-		
Comilla Area	-	0:00			573						-	-		
Mymensingh Area	-	0:00			437						-	-		
Sylhet Area	-	0:00			324						-	-		
Barisal Area Rangpur Area	-	0:00			152 422						-	-		
Kangpui Area		0.00			422						-	-		
Total	0				6887					0				
Information of the Generating machines under shut down.														
	Planned Shut- Down	n					Forced S	hut- Down						
							1) Ghorasal ST: Unit-6 (18/07/2010)				9) Raozan ST: Unit-2 (18/10/2015)			
							2) Ashuganj ST: Unit-1(12/09/2015) 10) Barapukuria ST-1 (05/11/2015)							
								3) Khulna 150 MW (16/10/2015) 11) Summit Meghnaghat (25/10/2015) 14) Khulna ST 110 MW (04/11/2014) 12) Pagla 50 MW (29/10/2015))	
								4) Knuina ST 110 MW (04/11/2014) 12) Pagia 50 MW (29/10/2015) 5) Ghorasal ST: Unit-4 (05/01/2015) 13) Sylhet-150 MW (9/11/15)						
							6) Haripu		,	, -	,	(*,	-,	
							7) Sikalb							
							8) Haripu	ır-412 MW (25/05/20	15)					
Additional Information of Machines, lines, Interruption / Forced Load shed etc.														
Description							Forced load shaded / Interrupted Areas							
e e e e e e e e e e e e e e e e e e e							r or ced 10	au snaucu / mierrupi	au Are	ao				
a) Hathazari-Feni 132 kV Ckt-2 was under shut down from 08:13 to 15:20 due to A/M.														
b) Cox'bazar-Dohazari 132 kV Ckt-1 was under shut down from 08:28 to 16:53 due to A/M.														
c) Kodda RPP-Joydabpur 132 kV Ckt-2 was shut down from 08:57 to 15:58 due to A/M.														
d) Siddhirganj-Haripur 132 kV Ckt-3 was under shut down from 08:58 to 16:58 due to A/M. e) Comilla(S) 132/33 kV T4 transformer was under shut down from 08:35 to 16:15 due to A/M.														
f) Madaripur 132/33 kV T3 transformer was under shut down from 08:38 to 18:15 due to A/M.														
g) Mirpur-Uttara 132 kV Ckt was under shut down from 09:23 to 19:11 due to A/M.														
h) Jamalpur 132/33 kV T1 transformer was under shut down from 08:28 to 16:08 due to A/M.														
i) Netrokona 132/33 kV T1 transformer was under shut down from 08:40 to 17:45 due to A/M.														
 i) Mymenshing-Kishoreganj 132kV Ckt-1 was under shut down from 08:28 to 16:05 due to A/M. k)Serajganj 225 MW CCPP ST tripped at 11:05 due to drum level problem and was synchronized at 06:54(13/11/15). 														
R) Serajganj 225 MW CCPP 51 impped at 11:05 due to drum level problem and was synchronized at 06:54(13/11/15). 1) Ashuganj-Ghorasal 230 kV Ckt-1 was shut down at 07:42(13/11/2015) due to A/M.														
m) Ashuganj Unit-3 was forced shut down at 23:08 due to leakage at Auxiliary steam line.														
n) Madunaghat-Kaptai via Chandraghona Ckt tripped at 22:26 from both end showing dist relay and was switched on at 22:39. o) Hasnabad-Shyampur 132 kV Ckt was under shut down at 07:13 (13/11/2015) due to A/M.														
o) Hasnabad-Shyar	mpur 132 kV Ckt wa	as under shut o	lown at 07:13 (13	3/11/2015) due to	A/M.									
Sub Divisional Engi	neer		Executive Er	gineer			1			,	Superinte	ndent Engine	er	
Network Operation			Network Opera									ispatch Circl		