

POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT									
Till now the maximum generation is :-				8177 MW	21:00	Hrs on	13-Aug-15	Reporting Date :	9-Dec-15
The Summary of Yesterday's (				8-Dec-15	Generation & Demand			Today's Actual Min Gen. & Probable Gen. & Demand	
Day Peak Generation :	5079.0	MW	Hour :	12:00	Min. Gen. at	5:00	3816		
Evening Peak Generation :	6687.0	MW	Hour :	18:30	Max Generation :		7938		
E.P. Demand (at gen end) :	6687.0	MW	Hour :	18:30	Max Demand :		6800		
Maximum Generation :	6687.0	MW	Hour :	18:30	Shortage :		1138		
Total Gen. (MKWH) :	118.7	System L/ Factor	:	73.98%	Load Shed	:	0		
EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR									
Export from East grid to West grid :- Maximum				-70	MW	at 11:00	Energy	7.867	
Import from West grid to East grid :- Maximum				-	MW	at -	Energy	-	
Water Level of Kaptai 9-Dec-15									
Actual :	100.51	Ft.(MSL) ,		Rule curve :	105.28	Ft.( MSL )			
Gas Consumed :	Total	915.93	MMCFD.		Oil Consumed (PDB) :				
							HSD :		
							FO :		
Cost of the Consumed Fuel (PDB+Pvt) :	Gas :		Tk52,995,611						
	Coal :		Tk0		Oil :	Tk236,173,672	Total :	Tk289,169,284	
Load Shedding & Other Information									
Area	Yesterday		Estimated Demand (S/S end)			Today		Rates of Shedding	
	MW		MW			Estimated Shedding (S/S end)		MW	
								(On Estimated Demand)	
Dhaka	-	0:00	2970			-		-	
Chittagong Area	-	0:00	766			-		-	
Khulna Area	-	0:00	854			-		-	
Rajshahi Area	-	0:00	798			-		-	
Comilla Area	-	0:00	615			-		-	
Mymensingh Area	-	0:00	468			-		-	
Sylhet Area	-	0:00	349			-		-	
Barisal Area	-	0:00	163			-		-	
Rangpur Area	-	0:00	454			-		-	
Total	0		7437			0			
Information of the Generating machines under shut down.									
	Planned Shut- Down				Forced Shut- Down				
					1) Ghorasal ST: Unit-6 (18/07/09) Ghorasal ST: Unit-5(01/12/2015) 2) Ashuganj ST: Unit-1(12/09/ 10) Barapukuria ST-1 (05/11/2015) 3) Barapukuria ST-2 (07/12/2( 11) Sikalbaha 60MW (23/11/15) 4) Khulna ST 110 MW (04/11/ 12) Siddhirgonj ST(23/11/15) 5) Ghorasal ST: Unit-4 (05/01. 13) Ghorasal ST: Unit-5(01/12/2015) 6) Haripur GT-3 14) Summit Bibiana- 2 (08/12/2015) 7) Haripur-412 MW (25/05/2015) 8) Raozan ST: Unit-2 (18/10/2015)				
Additional Information of Machines, lines, Interruption / Forced Load shed etc.									
Description					Forced load shaded / Interrupted Areas				
a) Ghorasal-Narshingdi 132 kV Ckt was under shut down from 08:01 to 19:40 due to A/M. b) Aminbazar-Agargaon 230 kV Ckt-1 was under shut down from 08:42 to 12:59 due to A/M. c) Ishurdi 230 kV bus-2 was under shut down from 08:45 to 12:30 due to A/M. d) Comilla(N)-Abul Khair 230 kV Ckt was under shut down from 08:51 to 16:05 due to A/M. e) Munshiganj-Madanganj 132 kV Ckt-2 was under shut down from 09:28 to 16:44 due to A/M. f) Rangpur-Barapukuria 132 kV Ckt-1 was under shut down from 09:30 to 13:30 due to A/M. g) Faridpur-Bheramara 132 kV Ckt-1 was under shut down from 08:15 to 16:05 due to A/M. h) Khulna(S)-Khulna@ 132 kV Ckt-1 was under shut down from 08:25 to 16:20 due to A/M. i) Kabirpur-Kadda 132 kV Ckt-2 was under shut down from 09:27 to 12:25 due to A/M. j) Kallyanpur-Lalbagh 132 kV Ckt-1 & 2 were under shut down from 09:01 to 17:53 due to A/M. k) Bogra-Sirajganj 132 kV Ckt-2 was under shut down from 08:37 to 15:47 due to A/M. l) Siddirganj Peaking GT-2 was shut down at 08:03 due to air filter replacement and was synchronized at 14:03. m) Summit Bibiyana-2 ST was shut down at 12:20 due to rejection test. n) Khulna 150 MW GT was shut down at 12:31 due to test purpose and was synchronized at 18:47. o) Aminbazar-Agargaon 230 kV Ckt-2 was shut down from 13:09 to 14:44 due to A/M. p) Summit Bibiyana-2 GT was shut down at 13:10 due to test purpose. q) After maintenance Sikalbaha Peaking GT was synchronized at 13:54.									
Sub Divisional Engineer Network Operation Division					Executive Engineer Network Operation Division				
					Superintendent Engineer Load Dispatch Circle				