

POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT									
Till now the maximum generation is :-				8177 MW	21:00	Hrs on	Reporting Date : 14-Dec-15 13-Aug-15		
The Summary of Yesterday's (13-Dec-15	Generation & Demand			Today's Actual Min Gen. & Probable Gen. & Demand			
Day Peak Generation :	5158.0	MW	Hour :	12:00	Min. Gen. at	5:00	3763		
Evening Peak Generation :	6706.0	MW	Hour :	18:00	Max Generation :	8254			
E.P. Demand (at gen end) :	6706.0	MW	Hour :	18:00	Max Demand :	6800			
Maximum Generation :	6706.0	MW	Hour :	18:00	1454				
Total Gen. (MKWH) :	119.2	System L/ Factor :	74.05%			Load Shed :	0		
EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR									
Export from East grid to West grid :- Maximum				-110	MW	16:00	Energy	7.867	
Import from West grid to East grid :- Maximum				-	MW	-	Energy	-	
Water Level of Kapt 14-Dec-15									
Actual :		100.07	Ft.(MSL) ,		Rule curve :		104.80	Ft.(MSL)	
Gas Consumed : Total		975.08		MMCFD.		Oil Consumed (PDB) :		HSD : FO :	
Cost of the Consumed Fuel (PDB+Pvt) :		Gas :	Tk55,728,589		Oil :		Tk147,759,053	Total : Tk203,487,642	
		Coal :	Tk0						
Load Shedding & Other Information									
Area	Yesterday		Estimated Demand (S/S end)			Today		Estimated Shedding (S/S end)	
	MW		MW			MW		Rates of Shedding (On Estimated Dema	
Dhaka	-	0:00	2975			-		-	
Chittagong Area	-	0:00	767			-		-	
Khulna Area	-	0:00	855			-		-	
Rajshahi Area	-	0:00	800			-		-	
Comilla Area	-	0:00	616			-		-	
Mymensingh Area	-	0:00	469			-		-	
Sylhet Area	-	0:00	350			-		-	
Barisal Area	-	0:00	164			-		-	
Rangpur Area	-	0:00	454			-		-	
Total	0		7450			0			
Information of the Generating machines under shut down.									
	Planned Shut- Down				Forced Shut- Down				
					1) Ghorasal ST: Unit-6 (18/07/2010) 2) Ashuganj ST: Unit-1(12/09/2015) 3) Barapukuria ST-2 (07/12/2015) 4) Khulna ST 110 MW (04/11/2014) 5) Ghorasal ST: Unit-4 (05/01/2015) 6) Haripur GT-3 7) Haripur-412 MW (25/05/2015) 8) Raozan ST: Unit-2 (18/10/2015) 9) Barapukuria ST-1 (05/11/2015) 10) Sikalbaha 60MW (23/11/15) 11) Siddhirgonj ST(23/11/15) 12) Ghorasal ST: Unit-2 13) Ashuganj ST: Unit-2 14) Baghabari GT 71 MW(20/11/15) 15) Rangpur GT(02/11/2015) 16)Siddhirganj (Desh)(11/12/2015)				
Additional Information of Machines, lines, Interruption / Forced Load shed etc.									
Description					Forced load shaded / Interrupted Areas				
a) Comilla(N)-BSRM 230 kV Ckt-2 was under shut down from 10:16 to 15:51 due to A/M. b) Hathazari-BSRM 230 kV Ckt-2 was under shut down from 10:16 to 16:16 due to A/M. c) Kabirpur 132/33 kV T1 transformer was under shut down from 09:20 to 13:33 due to A/M. d) Rampura 230/132 kV T02 transformer was under shut down from 09:21 to 17:13 due to A/M. e) Aminbazar-Savar 132 kV Ckt-1 was under shut down from 08:15 to 15:31 due to A/M. f) Jamalpur-Sherpur 132 kV Ckt-1 was under shut down from 08:50 to 17:20 due to A/M. g) Sylhet-Chatak 132 kV Ckt-1 was under shut down from 08:14 to 14:35 due to A/M. h) Faridpur S/S-Faridpur P/S 132 kV Ckt was under shut down from 08:53 to 16:09 due to A/M. i) Ashuganj-B.Barua 132 kV Ckt-1 was under shut down from 09:32 to 19:59 due to A/M. j) Mymensingh-Netrokona 132 kV Ckt-2 was under shut down from 07:58 to 16:42 due to A/M. k)Tongi-Bashundhara 132 kV Ckt-2 was under shut down from 08:46 to 17:05 due to A/M. l) Bashundhara 132/33 kV T1 transformer was under shut down from 08:28 to 17:20 due to A/M. m) Matuail-Maniknagar 132 kV Ckt was under shut down from 10:25 to 15:30 due to A/M. n) Haripur AES 360 MW tripped at 20:07 due to gas pressure failure. o)Comilla(S) 132 kV bus was under shut down at 06:30 (14/12/2015) due to hook up Tripura Ckt to feed in power and was switched on at 10:50					About 74 MW power interruption occurred under Comilla(S) S/S area from 06:30 to 10:50 (14/12/2015).				
Sub Divisional Engineer Network Operation Division			Executive Engineer Network Operation Division			Superintendent Engineer Load Dispatch Circle			