

Description	Forced load shaded / Interrupted Areas
<p>a) Summit Bibiyana Unit-2 tripped at 07:52 due to problem with thermocouple and was synchronized at 13:19.</p> <p>b) Ishurdi-Bheramara 132 kV Ckt-1 was under shut down from 07:56 to 12:13 due to A/M.</p> <p>c) Ishurdi-Bheramara 132 kV Ckt-2 was under shut down from 07:57 to 12:13 due to A/M.</p> <p>d) Haripur-Maniknagar-Siddhirganj-Ullon 132 kV Ckt was under shut down from 08:54 to 21:19 due to A/M.</p> <p>e) Chandpur CAPP tripped at 08:57 due to tripping of gas booster and was synchronized at 12:47.</p> <p>f) Maniknagar-Narinda 132 kV Ckt-2 was under shut down from 09:00 to 15:27 due to A/M.</p> <p>g) Chandpur 132/33 kV T1 transformers tripped at 08:54 showing discrepancy between CB & CS and was switched on at 14:15.</p> <p>h) Chandpur 132/33 kV T2 transformer tripped at 08:54 showing without any relay and was switched on at 09:14.</p> <p>i) Bogra (New)-Bogra S/S 132 kV Ckt-1 was under shut down from 08:39 to 11:33 due to A/M.</p> <p>j) Bogra (New)-Bogra S/S 132 kV Ckt-2 was under shut down from 11:38 to 14:22 due to A/M.</p> <p>k) Kaliyanpur 132/33 kV T2 transformer was under shut down from 09:20 to 15:52 due to A/M.</p> <p>l) Daudkandi 132 kV Bus was under shut down from 10:02 to 17:54 due to A/M.</p> <p>m) Kamrangirchar-Lalbagh 132 kV Ckt was under shut down from 10:25 to 12:50 due to red hot maintenance at Kamrangirchar end.</p> <p>n) After maintenance Baghabari 71 MW was synchronized at 11:39.</p> <p>o) After maintenance Joydevpur 132/33 kV GT-2 transformer was switched on at 20:27.</p> <p>p) Haripur-Siddhirganj 132 kV Ckt-2 tripped at 20:48 showing E/F relay and was switched on at 20:53.</p> <p>q) Hasnabad-Shyampur 132 kV Ckt is under shut down since 06:57 (19/12/2015) due to A/M.</p> <p>r) Hasnabad-Meghnaghat 230 kV Ckt tripped at 05:55 (19/12/2015) showing dist.relay at both sides.</p> <p>s) Haripur-Rampura 230 kV Ckt-2 tripped at 05:55 (19/12/2015) from Haripur end showing directional E/F relay and was switched on at 06:40 (19/12/2015).</p> <p>t) Hasnabad-Sitalkha 132 kV Ckt is under shut down since 06:52 (19/12/2015) due to A/M.</p>	<p>About 25 MW power interruption occurred under Chandpur S/S areas from 08:54 to 14:15.</p> <p>About 15 MW power interruption occurred under Daudkandi S/S areas from 10:02 to 17:54.</p>
<p>Sub Divisional Engineer Network Operation Division</p>	<p>Executive Engineer Network Operation Division</p> <p>Superintendent Engineer Load Dispatch Circle</p>