

POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT										OF-LDC-08 Page -1
Till now the maximum generation is :-		8177 MW		21:00		Hrs on		Reporting Date : 3-Jan-16 13-Aug-15		
The Summary of Yesterday's ( 2-Jan-16				Generation & Demand				Today's Actual Min Gen. & Probable Gen. & Demand		
Day Peak Generation :	4742.0	MW	Hour :	12:00	Min. Gen. at	4:00	3586	MW		
Evening Peak Generation :	6538.0	MW	Hour :	18:30	Max Generation :		7607	MW		
E.P. Demand (at gen end) :	6538.0	MW	Hour :	18:30	Max Demand :		6700	MW		
Maximum Generation :	6538.0	MW	Hour :	18:30			907	MW		
Total Gen. (MKWH) :	111.7		System L/ Factor :	71.18%	Load Shed :		0	MW		
EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR										
Export from East grid to West grid :- Maximum				-60		MW	a 17:00	Energy	7.867	
Import from West grid to East grid :- Maximum						MW	a -	Energy	-	
Actual : 99.10				Water Level of Kapt 3-Jan-16						
				Ft.(MSL) ,		Rule curve : 102.62		Ft.( MSL )		
Gas Consumed : Total		902.62		MMCFD.		Oil Consumed (PDB) :				
						HSD :		Liter		
						FO :		Liter		
Cost of the Consumed Fuel (PDB+Pvt) :		Gas :		Tk55,887,094						
		Coal :		Tk0		Oil : Tk183,654,704		Total : Tk239,541,798		
Load Shedding & Other Information										
Area	Yesterday						Today			
	MW		Estimated Demand (S/S end)				Estimated Shedding (S/S end)		Rates of Shedding (On Estimated Demand)	
			MW				MW			
Dhaka	-	0:00	2835				-		-	
Chittagong Area	-	0:00	728				-		-	
Khulna Area	-	0:00	811				-		-	
Rajshahi Area	-	0:00	759				-		-	
Comilla Area	-	0:00	589				-		-	
Mymensingh Area	-	0:00	449				-		-	
Sylhet Area	-	0:00	333				-		-	
Barisal Area	-	0:00	157				-		-	
Rangpur Area	-	0:00	434				-		-	
Total	0		7095				0			
Information of the Generating machines under shut down.										
Planned Shut- Down				Forced Shut- Down						
				1) Ghorasal ST: Unit-6 (18/07/2010) 2) Ashuganj ST: Unit-1(12/09/2015) 3) Barapukuria ST-2 (07/12/2015) 4) Khulna ST 110 MW (04/11/2014) 5) Ghorasal ST: Unit-4 (05/01/2015) 6) Haripur GT-3 7) Haripur-412 MW (25/05/2015) 8) Raozan ST: Unit-2 (18/10/2015) 9) Barapukuria ST-1 (05/11/2015) 10) Sikalbaha 60MW (23/11/15) 11) Raozan ST: Unit-1(22/12/2015) 12)Siddhirganj (Desh)(11/12/2015) 13) Ashuganj ST: Unit- 3(02/01/2016)						
Additional Information of Machines, lines, Interruption / Forced Load shed etc.										
Description				Forced load shaded / Interrupted Areas						
a) Madunaghat-Sikalbaha 132 kV Ckt was under shut down from 08:18 to 16:05 due to A/M. b) Rampura-Haripur 230 kV Ckt-1 was shut down from 09:38 to 17:07 due to A/M. c) Ashuganj-Comilla(N) 230 kV Ckt-2 was under shut down from 08:43 to 17:13 due to A/M. d) Aminbazar-Hasnabad 230 kV Ckt-1 was under shut down from 09:31 to 16:44 due to A/M. e) Meghnaghat-Aminbazar 230 kV Ckt-1 was under shut down from 10:39 to 17:15 due to A/M. f) Sitalakha 132/33 kV T2 transformer was under shut down from 09:28 to 15:45 due to A/M. g) Sreemongal-Fenchuganj 132 kV Ckt-2 was under shut down from 09:43 to 13:39 due to A/M. h) Mymensingh S/S-Mymensingh RPCL 132 kV Ckt-1 was shut down from 11:18 to 15:03 due to A/M. i) Baghabari 230/132 kV T02 transformer was under shut down from 08:33 to 16:18 due to A/M. j) Madaripur-Barisal(N) 132 kV Ckt-1 was shut down from 08:14 to 17:17 due to A/M. k) Noapara-Jessore 132 kV Ckt-1 was under shut down from 08:45 to 16:26 due to A/M. l) Khulna(S)-Gallamari 132 kV Ckt-1 was under shut down from 08:36 to 16:12 due to A/M. m) Ishurdi-Natore 132 kV Ckt-2 was under shut down from 08:40 to 17:53 due to A/M. n) Barisal 230/132 kV T01 transformer was under shut down at 08:45 due to A/M. o) Rampura 230/132 kV T3 transformer was under shut down from 08:37 to 15:26 due to A/M. p) Uttara 132/33 kV GT2 transformer was under shut down from 08:22 to 17:16 due to A/M. q) Comilla(S)-Tripura 132 kV Ckt-1 & 2 was charged at 19:42 & 19:44 respectively till Border end. r) Ashuganj Unit-3 was forced shut down at 22:52 due to aspirating door red hot. s) Aminbazar-Meghnaghat 230 kV Ckt-1 was under shut down at 07:10(03/01/2016) due to A/M. t) Ashuganj-Sirajganj 230 kV Ckt-1 was under shut down at 07:10 (03/01/2016) due to A/M.										
Sub Divisional Engineer Network Operation Division				Executive Engineer Network Operation Division				Superintendent Engineer Load Dispatch Circle		