

POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT									
Till now the maximum generation is :-				8177 MW	21:00	Hrs on		Reporting Date : 26-Jan-16 13-Aug-15	
The Summary of Yesterday's ( 25-Jan-16				Generation & Demand			Today's Actual Min Gen. & Probable Gen. & Demand		
Day Peak Generation :	5611.0	MW	Hour :	9:00	Min. Gen. at	5:00	3993		
Evening Peak Generation :	7080.0	MW	Hour :	19:00	Max Generation :		7468		
E.P. Demand (at gen end) :	7080.0	MW	Hour :	19:00	Max Demand :		7150		
Maximum Generation :	7080.0	MW	Hour :	19:00			318		
Total Gen. (MKWH) :	121.5	System L/ Factor	:	71.48%	Load Shed	:	0		
EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR									
Export from East grid to West grid :- Maximum				-100	MW	a 15:00	Energy	7.867	
Import from West grid to East grid :- Maximum				-	MW	a -	Energy	-	
Water Level of Kapt 26-Jan-16									
Actual :		97.77	Ft.(MSL) ,		Rule curve :		98.20	Ft( MSL )	
Gas Consumed : Total		848.69	MMCFD.		Oil Consumed (PDB) :		HSD : FO :		
Cost of the Consumed Fuel (PDB+Pvt) :		Gas :	Tk53,883,418						
		Coal :	Tk3,724,994		Oil :		Tk280,620,351	Total : Tk338,228,763	
Load Shedding & Other Information									
Area	Yesterday					Today			
	MW		Estimated Demand (S/S end)			Estimated Shedding (S/S end)		MW	Rates of Shedding (On Estimated Demand)
Dhaka	-	0:00	2657					-	-
Chittagong Area	-	0:00	678					-	-
Khulna Area	-	0:00	755					-	-
Rajshahi Area	-	0:00	708					-	-
Comilla Area	-	0:00	554					-	-
Mymensingh Area	-	0:00	423					-	-
Sylhet Area	-	0:00	313					-	-
Barisal Area	-	0:00	147					-	-
Rangpur Area	-	0:00	408					-	-
Total	0		6643					0	
Information of the Generating machines under shut down.									
	Planned Shut- Down					Forced Shut- Down			
						1) Ghorasal ST: Unit-6 (18/07/2010) 2) Ashuganj ST: Unit-1(12/09/2015) 3) Barapukuria ST-2 (07/12/2015) 4) Khulna ST 110 MW (04/11/2014) 5) Ghorasal ST: Unit-4 (05/01/2015) 6) Haripur GT-2 & 3 (07/01/2016) 7) Barisal GT: Unit-1, 2 8) Chittagong ST: Unit-2 (18/10/2015) 09) Siddhirganj (Desh)(11/12/2015) 10) Sikalbaha 60MW (23/11/15) 11) Ashuganj : GT-2 12) Saidpur GT 13) Haripur Power CCPP 14) Siddhirgonj GT: Unit-1& 2 15) Tongi GT			
Additional Information of Machines, lines, Interruption / Forced Load shed etc.									
Description						Forced load shaded / Interrupted Areas			
a) After maintenance Meghnaghat-Hasnabad 230 kV Ckt-2 was switched on at 09:50. b) Madunaghat-Sikalbaha 132 kV Ckt-1 was under shut down from 08:38 to 12:56 due to A/M. c) Jamalpur 132/33 kV T1 transformer was under shut down from 08:55 to 18:20 due to A/M. d) Tongi-Uttara 132 kV Ckt was under shut down from 09:25 to 16:26 due to A/M. e) Daudkandi 132/33 kV T2 transformer was under shut down from 09:55 to 17:02 due to A/M. f) Noapara-Jessore 132 kV Ckt-2 was under shut down from 09:45 to 10:29 for filling of SF6 gas at Noapara end. g) Aminbazar-Meghnaghat 230 kV Ckt-1 was under shut down from 10:10 to 15:29 due to A/M. h) Jessore-Jhenaidah 132 kV Ckt-1 was under shut down from 10:33 to 17:18 due to A/M. i) Mymensingh-Netrokona 132 kV Ckt-2 was under shut down from 11:50 to till now due to attend air compressor gas leakage. j) Hathazari 230/132 kV MT-2 transformer was under shut down from 08:50 to 14:28 due to A/M. k) Haripur S/S-Haripur HPL 230 kV Ckt-1 was under shut down from 09:56 to 15:12 due to A/M. l) Tongi 230 kV busbar-2 was under shut down from 10:08 to 13:35 due to maintenance work. m) After maintenance Khulna 150 MW GT was synchronized at 13:49. n) After maintenance Comilla(S)-Tripura Ckt-1 & 2 were closed at 17:11. o) After maintenance Bhola GT2 was synchronized at 02:44(26/01/16). p) After maintenance Haripur EGCB (only GT) was synchronized at 17:09 and was forced shut down at 08:50 (26/01/16) due to gas line change over by gas company.									
Sub Divisional Engineer Network Operation Division						Executive Engineer Network Operation Division			
						Superintendent Engineer Load Dispatch Circle			