

POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT									
Till now the maximum generation is :-		8177 MW		21:00		Hrs on		Reporting Date : 25-Feb-16 13-Aug-15	
The Summary of Yesterday's (24-Feb-16				Generation & Demand		Today's Actual Min Gen. & Probable Gen. & Demand			
Day Peak Generation :	5656.0	MW	Hour :	11:00		Min. Gen. at	5:00		4093
Evening Peak Generation :	7147.0	MW	Hour :	20:00		Max Generation :			7973
E.P. Demand (at gen end) :	7147.0	MW	Hour :	20:00		Max Demand :			7500
Maximum Generation :	7147.0	MW	Hour :	20:00					473
Total Gen. (MKWH) :	132.3		System L/ Factor :	77.10%		Load Shed :			0
EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR									
Export from East grid to West grid :- Maximum				-300		MW	a 5:00	Energy	7.867
Import from West grid to East grid :- Maximum				-		MW	a -	Energy	-
Water Level of Kapt 25-Feb-16									
Actual : 94.51		Ft.(MSL) ,		Rule curve : 93.60		Ft.(MSL)			
Gas Consumed : Total		891.19		MMCFD.		Oil Consumed (PDB) :			
								HSD : FO :	
Cost of the Consumed Fuel (PDB+Pvt) :		Gas : Tk61,754,879		Oil : Tk211,285,992		Total : Tk283,801,554			
		Coal : Tk10,760,683							
Load Shedding & Other Information									
Area	Yesterday		Estimated Demand (S/S end)		Today		Estimated Shedding (S/S end)		Rates of Shedding
	MW		MW		MW		MW		(On Estimated Demand)
Dhaka	-	0:00	2757				-		-
Chittagong Area	-	0:00	706				-		-
Khulna Area	-	0:00	786				-		-
Rajshahi Area	-	0:00	737				-		-
Comilla Area	-	0:00	574				-		-
Mymensingh Area	-	0:00	437				-		-
Sylhet Area	-	0:00	324				-		-
Barisal Area	-	0:00	153				-		-
Rangpur Area	-	0:00	422				-		-
Total	0		6896				0		
Information of the Generating machines under shut down.									
	Planned Shut- Down				Forced Shut- Down				
					1) Ghorasal ST: Unit-6 (18/07/2010) 2) Ashuganj ST: Unit-1(12/09/2015) 3) Siddhirgonj GT: Unit-1& 2 4) Khulna ST 110 MW (04/11/2014) 5) Ghorasal ST: Unit-4 (05/01/2015) 6) Haripur GT- 1 & 3 7) Chandpur CCPP 8) Chittagong ST: Unit-2 (18/10/2015)				
					9) Tongi GT 10) Sikalbaha 60MW (23/11/15) 11)Ghorasal ST: Unit-1 12) Saidpur GT 13) Bhola GT-2 14) Ashuganj : GT-2 15) Chittagong ST: Unit-1 16) Barapukuria ST: Unit-1				
Additional Information of Machines, lines, Interruption / Forced Load shed etc.									
Description					Forced load shaded / Interrupted Areas				
a) Ishurdi- Bheramara 132 kV Ckt-1 was shut down at 13:10 due to remove polythene b) Khulna@ 132/33 kV T1, T2 & T3 transformers tripped at 15:08 from both end showing Inst. E/F relays and were switched on at 15:13 respectively c) Sylhet-Fenchuganj 132 kV Ckt was shut down from 17:22 to 18:31 due to oil leakage maintenance at Sylhet end. d) Siddhirganj 230 kV CB no 852 & 855 was shut down at 17:22 due to post insulator C/M work. e) After maintenance AES Haripur-360 MW GT & ST were synchronized at 23:19 & 01:56 (25/2/16) respectively. f) Meghnaghat-450 MW GT-2 tripped at 23:47 showing DC power failure and was synchronized at 01:37 (25/2/16).									
Sub Divisional Engineer Network Operation Division					Superintendent Engineer Load Dispatch Circle				
Executive Engineer Network Operation Division									