

POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT									
Till now the maximum generation is :-			8177 MW		21:00		Hrs on		Reporting Date : 6-Mar-16
The Summary of Yesterday's (5-Mar-16		Generation & Demand		Today's Actual Min Gen. & Probable Gen. & Demand		
Day Peak Generation :			6127.0		MW		Hour :		12:00
Evening Peak Generation :			8002.0		MW		Hour :		20:00
E.P. Demand (at gen end) :			8002.0		MW		Hour :		20:00
Maximum Generation :			8002.0		MW		Hour :		20:00
Total Gen. (MKWH) :			148.3		System L/ Factor		:		77.20%
									Load Shed
									0
EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR									
Export from East grid to West grid :-			Maximum		-320		MW		a 15:00
Import from West grid to East grid :-			Maximum		-		MW		a -
									Energy
									7.867
									Energy
									-
Actual :			92.32		Ft.(MSL) ,		Rule curve :		92.20
									Ft.(MSL)
Gas Consumed :			Total		954.77		MMCFD.		Oil Consumed (PDB) :
									HSD :
									FO :
Cost of the Consumed Fuel (PDB+Pvt) :			Gas :		Tk61,812,671				
			Coal :		Tk10,606,229		Oil :		Tk334,339,757
							Total :		Tk406,758,657
Load Shedding & Other Information									
Area									
Yesterday									
MW									
Estimated Demand (S/S end)									
MW									
Today									
Estimated Shedding (S/S end)									
MW									
Rates of Shedding (On Estimated Demand)									
Dhaka									
Chittagong Area									
Khulna Area									
Rajshahi Area									
Comilla Area									
Mymensingh Area									
Sylhet Area									
Barisal Area									
Rangpur Area									
Total									
0									
7486									
0									
Information of the Generating Units under shut down.									
Planned Shut- Down									
Nil									
Forced Shut- Down									
1) Ghorasal ST: Unit-6 (18/07/2010)									
2) Ashuganj ST: Unit-1(12/09/2015)									
3) Siddhirgonj GT: Unit-1,2									
4) Khulna ST 110 MW (04/11/2014)									
5) Ghorasal ST: Unit-4 (05/01/2015)									
6) Haripur GT- 3									
7) Chandpur CCPP									
8) Chittagong ST: Unit-2 (18/10/2015)									
9) Tongi GT									
10) Sikalbaha 60MW (23/11/15)									
11)Ghorasal ST: Unit-1									
12) Saidpur GT									
13) Bhola GT-2									
14) Ashuganj : GT-2									
15) Chittagong ST: Unit-1									
16) Barapukuria: Unit-2									
Additional Information of Machines, lines, Interruption / Forced Load shed etc.									
Description									
Comments on Power Interruption									
a) Khulna 230/132 kV T-2 transformer was under shut down from 09:01 to 17:36 for correction maintenance.									
b) Siddhirganj-Maniknagar 230 kV Ckt-2 was under shut down from 08:39 to 17:52 for A/M.									
c) Cantonment 132/33 kV T1 transformer was under shut down from 09:28 to 14:09 for correction maintenance.									
d) Gulshan 132/33 kV T2 transformer was under shut down from 10:01 to 10:57 for correction maintenance.									
About 10 MW power interruption occurred under Gulshan S/S areas from 10:01 to 10:57.									
e) Bheramara-GK 132 kV Ckt was shut down from 09:17 to 10:31 for bus-B shiftment work.									
f) Bheramara 132 kV Bus-B was shut down from 11:05 to 17:08 for D/W.									
g) Bheramara HVDC auxiliary power was shut down from 08:42 to 10:44 for Bheramara 132 kV Bus-B shifting.									
h) Haripur-Ullon 132 kV Ckt-2 was shut down from 10:35 to 13:50 for safety.									
i) Madaripur 132/3.3 kV T1 & T2 transformers were shut down from 09:38 to 13:20 for new feeder connection by PBS at 33 kV end.									
About 30 MW power interruption occurred under Madaripur S/S areas from 09:38 to 13:20.									
j) After maintenance Baghabari-100 MW was synchronized at 15:45.									
k) Dohazari-Cox'baza 132 kV Ckt-1 was under shut down from 17:09 to 18:05 for gantry work at Dohazari end.									
l) Haripur-Narsingdi Ckt tripped at 18:54 showing dist.Z1,CN at Haripur end.									
About 50 MW power interruption occurred under Narsingdi S/S areas from 18:54 to 19:12.									
m) Tongi-Kabirpur 132 kV Ckt-1 & 2 tripped at 02:02(6/3/16) showing under voltage at Ckt-1 & dist.CSW, CAT CD, CE at Tongi end & dist. Main protection at Ckt-2 at Kabirpur end and were switched on at 02:35 & 02:40(6/3/16) respectively.									
About 140 MW power interruption occurred under Manikganj & Tangail S/S areas from 02:02 to 02:35 (6/3/16).									
n) Feni 33 kV Bus was shut down at 07:00(6/3/16) for cable changing and was switched on at 08:55 (6/3/16).									
About 60 MW power interruption occurred under Feni S/S areas from 07:00 to 08:55 (6/3/16)									
o) Goalpara-Bagerhat 132 kV Ckt tripped at 05:40 (6/3/16) showing dist.Z2 at Goalpara end and was switched on at 06:48 (6/3/16).									
Sub Divisional Engineer Network Operation Division			Executive Engineer Network Operation Division			Superintendent Engineer Load Dispatch Circle			