POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT Reporting Date : 8-Mar-16 8177 MW Hrs Till now the maximum generation is: 21:00 13-Aug-15 Today's Actual Min Gen. & Probable Gen. & Demand Min. Gen. at 5:00 The Summary of Yesterday's (Day Peak Generation : Generation & Demand MW He 7-Mar-16 6151.0 MW Evening Peak Generation 7485.0 Hour 19:00 Max Generation 8054 E.P. Demand (at gen end) Maximum Generation Hour Hour Max Demand (Evening) : Reserve (Generation end) : 7750 304 7485.0 мw 19:00 Total Gen. (MKWH) 138.0 76.81% Load Shed 0 EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR Export from East grid to West grid :- Maximum Energy 7.867 Import from West grid to East grid :- Maximum Water Level of Kapt 8-Mar-16 Ft.(MSL), 91.84 Actual: Rule curve : 91.88 Ft.(MSL) 940 45 MMCFD. Oil Consumed (PDB) HSD FO Cost of the Consumed Fuel (PDB+Pvt): Coal Tk10.451.770 Oil : Tk287,754,354 Total: Tk356,666,929 Load Shedding & Other Information Estimated Demand (S/S end) Estimated Shedding (S/S end) Rates of Shedding MW 2881 741 MW (On Estimated Demand) Dhaka Chittagong Area 0:00 826 773 598 Khulna Area 0:00 Rajshahi Area Comilla Area 0:00 Mymensingh Area Sylhet Area Barisal Area 0:00 455 339 159 0:00 Rangpur Area 0.00 441 Total 7213 Information of the Generating Units under shut down. Planned Shut- Down Forced Shut-Down Sheet Sheet Source Grant Bown Grant Bo 9) Tongi GT 10) Sikalbaha 60MW (23/11/15) (2) Ashuganj ST: Unit-1(12/09/2015) (3) Siddhirgonj GT: Unit-12 (4) Khulna ST 110 MW (04/11/2014) (5) Ghorasal ST: Unit-4 (05/01/2015) (6) Haripur GT-3 (7) Chandpur CCPP 11)Ghorasal ST: Unit-1 12) Saidpur GT 13) Bhola GT-2 14) Ashuganj : GT-2 15) Chittagong ST: Unit-1 8) Chittagong ST: Unit-2 (18/10/2015) Additional Information of Machines, lines, Interruption / Forced Load shed etc. Description Comments on Power Interruption a) Dohazari-Cox'sbazar 132 kV Ckt-2 was under shut down from 08:40 to 16:53 for A/M. b) Mymensing-Netrokona 132 kV Ckt-1 was under shut down from 11:46 to 13:18 for C/M relay test. c) Khulna (S) 230/132 kV T01 transformer was shut down from 09:39 to 16:41 for neutral grounding box maintenance. d) Noapara-Jessore 132 kV Ckt-1 was under shut down from 08:35 to 18:26 for conductor replacement of 132 kV A-bus. e) Faridpur 132/33 kV T2 transformer was shut down from 08:12 to 10:28 for replacement of 33 kV R-phase loop. f) Mymensing-Netrokona 132 kV Ckt-2 was under shut down from 13:26 to 15:15 for relay test. g) Kabirpur 132/33 kV T1 & T2 transformers were shut down from 14:14 to 14:47 for replacement of 33 kV R-phase clamp. About 40 MW power interruption occurred under Kabirpur S/S h) After maintenance Barapukuria ST Unit-2 was synchronized at 20:26. areas from 14:14 to 14:47 i) Ashunanj 225 MW ST was synchronized at 00:50 (08/03/2016). j) Chandpur-Comilla(S) 132 kV Ckt charged at 22:43 from Chandpur end. Sub Divisional Engineer Executive Engineer Superintendent Engineer

Load Dispatch Circle

Network Operation Division

Network Operation Division