POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT Reporting Date: 29-Mar-16 Till now the maximum generation is : -8177 MW 21:00 Hrs on Today's Actual Min Gen. & Probate Min. Gen. at 5:00 The Summary of Yesterday's 28-Mar-16 Generation & Demand Day Peak Generation : 5991.0 MW H 9:00 4610 Evening Peak Generation E.P. Demand (at gen end) 7013.0 MW Hour 20:00 Max Generation 8020 Hour Max Demand (Evening) MW Reserve (Generation end): Maximum Generation 7054.0 Hour 1:00 320 n L/ Factor Total Gen. (MKWH) EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR Export from East grid to West grid :- Maximum Energy 7.867 Import from West grid to East grid :- Maximum Water Level of Kaptai Lake at29-Mar-16 MW Rule curve : 88.51 Ft.(MSL) 85.43 Ft.(MSL) Gas Consumed: Total MMCFD. 891.04 Oil Consumed (PDB): HSD FO Cost of the Consumed Fuel (PDB+Pvt) : Tk66,053,261 Tk9.010.142 Oil : Tk339,163,291 Total: Tk414,226,695 Load Shedding & Other Information Area Yesterday Today Estimated Demand (S/S end) Estimated Shedding (S/S end) Rates of Shed MW MW MW (On Estimated D 2883 806 Dhaka Chittagong Area 0:00 Khulna Area Rajshahi Area 0:00 806 783 0:00 Comilla Area 0:00 598 Mymensingh Area 0:00 Svlhet Area 0:00 284 0:00 Rangpur Area 0:00 441 7215 Total Information of the Generating Units under shut down. Forced Shut- Down 1) Ghorasal ST: Unit-6 (18/07/201(9) Tongi GT Planned Shut- Down 1) Ghidasai ST. Unite (10/09/2015) 10) Sikalbaha 60MW (23/11/ 2) Ashuganj ST. Unit-1(12/09/201510) Sikalbaha 60MW (23/11/ 3) Siddhirgonj GT: Unit-1,2 11) Ghorasal ST: Unit-3 4) Khulna ST 110 MW (04/11/201412) Saidpur GT Nii 5) Ghorasal ST: Unit-4 (05/01/201513) Bhola GT-2 6) Haripur GT- 3 14) Sikalbaha 150MW (10/3/ 7) Chandpur CCPP 15) Ashuganj : GT-2 8) Chittagong ST: Unit-2 16) Summit Bibiana- 2 Additional Information of Machines, lines, Interruption / Forced Load shed etc. Description Comments on Power Interruption a) Ashugani 225 MW CCPP tripped at 11:51 due to GT auxiliary power fail. b) Meghnaghat-Hasnabad 230 kV Ckt-1 tripped at 10:13 showing dist.relay and was switched on at 16:04. c) After maintenance Baghabari 100 MW GT was synchronized at 12:27. d) Saidpur 132/33 kV T4 transformer was under shut down from 09:15 to 09:40 for red hot maintenance. e) Saidpur-Purbasadipur 132 kV Ckt-2 was under shut down from 09:48 to 10:05 for red hot maintenance. f) Siddhirganj-Ullon 132 kV Ckt-1 tripped at 10:03 showing dist.relay and was switched on at 15:08. g) Hasnabad-Shyampur 132 kV Ckt tripped at 14:43 showing dist.relay and was switched on at 14:54. h) Shahjibazar-B.Baria 132 kV Ckt-2 tripped at 14:45 showing dist relay and was switched on at 15:12. i) Ashuganj 132 kV Bus-1 tripped at 14:45 showing bus differential relay and was switched on at 16:40. At the same time Ashuganj TSK, Ashuganj MW, B.Baria 85 MW, Shahjibazar 50 & 86 MW tripped. j) Bhola CCPP GT-2 was under shut down from 14:51 to 16:10 due to voltage high. k) Gallamari 132/33 kV T1 transformer was under shut down from 15:02 to 18:14 due to red hot maintenance at 33 kV) Fenchuganj 132/33 kV T2 transformer tripped at 16:34 showing main protection trip at 132 kV side & E/F relay at 33 kV side and was switched on at 16:40. m) Dohazari 132/33 kV,50/75 MVA T2 transformer was switched on at 19:15. n) Khulna Central 132/33 kV T3 transformer is under shut down since 06:36 (29/03/2016) for changing 33 kV loop.

Superintendent Engineer

Load Dispatch Circle

Sub Divisional Engineer

Network Operation Division

Executive Engineer

Network Operation Division