POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT

				ŀ	Reporting Date:	18-May-16				
Till now the maximum generat	ion is : -	8348 MW	21:00	Hrs on	9-Apr-16					
The Summary of Yesterday's	17-May-16	Generation & Demand		Today's Actual Min Ger	ı. & Probable Gen.	& Demand				
Day Peak Generation :	7003.0	MW	10:00	Min. Gen. at	6:00	5336				
Evening Peak Generation :	7523.0	MW	20:00	Max Generation :		7817				
E.P. Demand (at gen end):	7900.0	MW	20:00	Max Demand (Evening):		8000				
Maximum Generation :	7694.0	MW	1:00	Shortage(Generation end)):	183				
Total Gen. (MKWH) :	166.6	System L/ Factor :	90.24%	Load Shed :		168				
EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR										
Export from East grid to West grid :- 1	Maximum	20	MW at	23:00	Energy	7.867				
Import from Most grid to East grid : A	Avimum		NAA/ ot		Enorgy					

Oil Consumed (PDB):

: Tk536,643,701

Water Level of Kaptai Lake at 6:00, 18-May-16

Rule curve : 78.77 Ft.(MSL) Actual 69.80 Ft.(MSL) MMCFD.

> HSD FO

Cost of the Consumed Fuel (PDB+Pvt): Tk70,783,459

944.22

Gas Consumed :

Total

Tk15,077,744

Total : Tk622,504,904

Load Shedding & Other Information

Area	Yest	erday	Today			
			Estimated Demand (S/S end)	Estimated Shedding (S/S end)	Rates of Shedding	
	MW		MW	MW	(On Estimated Demand)	
Dhaka	127	(19:01-22:41)	2941	-	-	
Chittagong Area	42	(19:01-22:41)	860	38	-	
Khulna Area	44	(19:01-22:41)	860	36	-	
Rajshahi Area	38	(19:01-22:41)	834	34	-	
Comilla Area	32	(19:01-22:41)	632	23	-	
Mymensingh Area	22	(19:01-22:41)	480	16	-	
Sylhet Area	-	0:00	291	-	-	
Barisal Area	8	(19:01-22:41)	167	5	=	
Rangpur Area	26	(19:01-22:41)	465	16	-	
Total	339		7530	16	8	

Information of the Generating Units under shut down.

Planned Shut- Down	Forced Shut- Down	
	1) Ghorasal ST: Unit-6 (18/07/20109) Sikalbaha 60MW (23/11	/15)
Nil	2) Ashuganj ST: Unit-1(12/09/2015 10) Saidpur GT	
	3) Ashuganj CCPP 225 MW 11) Bhola GT-2	
	4) Khulna ST 110 MW (04/11/201412) Chittagong ST: Unit-1	
	5) Ghorasal ST: Unit-4 (05/01/201513) Kaptai Hydro: Unit-5,	
	6) Haripur GT- 3 14)Summit Bibiana- 2(15/0	5/2016)
	7) Sirajganj-210 MW	
	8) Meghan 450 MW (24/04/2016)	

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Comments on Power Interruption Description

- a) Natore-Rajshahi 132 kV Ckt-2 was under shut down from 10:15 to 10:49 for taking into service of line CB. b) After maintenance Bashundhara -Rampura 132 kV Ckt-2 was switched on at 10:20.
- c) Hasnabad-Aminbazar 230 kV Ckt-2 was under shut down from 10:39 to 11:43 for B-phase CT red
- d) Ashuganj CCPP 450 MW GT was synchronized at 18:01.
- e) Rajshahi 132/33 kV T1& T3 transformers tripped at 20:20 from 33 kV side showi About 58 MW power interruption occurred under Rajshahi S/S due to 33 kV Poba feeder fault and were switched on at 20:45.At the same tim area from 20:20 to 20:45. & Katakhali Peaking got tripped.
- f) Thakurgaon-Panchagor 132 kV Ckt tripped at 21:27 from Thakurgaon end showin About 22 MW power interruption occurred under Panchagor S/S switched on at 21:38. area from 21:27 to 21:38.
- g) Bogra-Naogaon 132 kV Ckt-2 was under shut down from 22:01 to 22:20 for kite removing.
- h) Khulna(S)-Bheramara HVDC 230 kV Ckt-2 tripped at 23:34 from Khulna(S) end showing E/F at B-phase and was switched on at 23:58.
- i) Gopalganj 132/33 kV T1 transformer tripped at 23:08 showing O/L and was switched on at 00:23(18/05/2016).
- j) Madaripur 132/33 kV T1 ,T2 & T3 transformers tripped at 00:09 (18/05/2016) shoy About 48 MW power interruption occurred under Madaripur S/S were switched on at 00:35,00:35 & 00:40 respectively. area from 00:09 to 00:35 (18/05/2016).
- k) Feni-Comilla(N) 132 kV Ckt-2 (T-line) tripped at 01:34(18/05/2016) showing dist Z2 B& C phase and was switched on 01:53.
- I) Feni-Hathazari 132 kV Ckt-1 tripped at 02:42(18/05/2016) from both end showing O/C at Feni end and E/F dist A-phase at Hathazari end and was switched on at 02:58.
- m) Madunaghat-Sikalbaha 132 kV Ckt tripped at 02:46 (18/05/2016) from both end showing 21R,A-phase & 67GR inst at Madunaghat end and dist Z2 at Sikalbaha end and was switched on at 03:05.
- n) Madunaghat-TK Chemical 132 kV Ckt tripped at 02:46 (18/05/2016) from Madunaghat end showing
- 21R A-phase and was switched on at 03:05.
- o) Sikalbaha-TK Chemical 132 kV Ckt tripped at 02:46 (18/05/2016) showing dist Z2 and was switched on at 03:08.

Sub Divisional Engineer **Network Operation Division**

Executive Engineer Network Operation Division Superintendent Engineer Load Dispatch Circle