## POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT

Till now the maximum generation is:The Summary of Yesterday' 18-Jun-16 8776 MW 21:00 Hrs on 15-Jun-16
Today's Actual Min Gen. & Probable Gen. & Demand The Summary of Yesterday Generation & Demand 12:00 Hour Day Peak Generation 6684.0 Min. Gen. at 6:00 Evening Peak Generation 8582.0 Max Generation 8905 E.P. Demand (at gen end) : 8700.0 MW Hour 21:00 Max Demand (Evening) 8800 Maximum Generation 8617.0 MW Hour 22:00 Reserve(Generation end): 105 System L/ Factor Total Gen. (MKWH) 177.4 85.77% Load Shed 0 EXPORT/ IMPORT THROUGH EAST-WEST INTERCONNECTO

Export from East grid to West grid :- Maximum -100 MW

 Water Level of Kaptai Lake at 19-Jun-16

 Actual: 85.29
 Ft.(MSL),
 Rule curve: 80.76
 Ft.(MSL)

HSD : FO :

Reporting Date :

Energy

Energy

19-Jun-16

7.867

Cost of the Consumed Fuel (PI Gas : Tk71,268,747

1086.71

Coal : Tk15,858,978 Oil : Tk512,524,858 Total : Tk599,652,583

## Load Shedding & Other Information

MMCFD.

Area	Yesterday		Today		
			Estimated Demand (S/S end)	Estimated Shedding (S/S end)	Rates of Shedding
	MW		MW	MW	(On Estimated Demand)
Dhaka	-	0:00	3267	-	-
Chittagong Area	32	(21:05-21:55)	913	-	-
Khulna Area	35	(21:05-21:55)	927	-	-
Rajshahi Area	-	0:00	894	-	-
Comilla Area	20	(21:05-21:55)	672	-	-
Mymensingh Area	19	(21:05-21:55)	510	-	-
Sylhet Area	-	0:00	328	-	-
Barisal Area	-	0:00	178	-	-
Rangpur Area	-	0:00	497	-	-
Total	106		8186	0	

Information of the Generating Units under shut down.

Planned Shut- Down

Nil

Description

Import from West grid to East grid :- Maximum

Gas Consumed: Total

orced Shut-Down

1) Ghorasal ST: Unit-6 (18/07/201(9) Sikalbaha 60MW (23/11/15)

2) Ashuganj ST: Unit-1 (12/09/201 10) Saidpur GT

3) Ashuganj CCPP 225 MW

at 18:30

Oil Consumed (PDB):

MW at

4) Khulna ST 110 MW (04/11/2014)

5) Kaptai Hydro: Unit-5, 6) Haripur GT-3

7 Bhola GT-2 8) Meghnaghat 450 MW(24/04/2016)

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Comments on Power Interruption

- a) Rampura 230/132 kV TR2 auto transformer was under shut down from 10:09 to 24:33 due to spare transformer hot process.
- b) Comilla(N) 132/33 kV T4 transformer was under shut down from 11:43 to 13:38 due to 33 kV PE About 70 MW power interruption occurred under Comilla(N) S/S feeder red hot.
- c) Hathazari-BSRM 132 kV Ckt tripped at 10:38 from Hathazari end showing REL,backup,start line-1, start line -n general tripped and was switched on at 10:50.
- d) Khulshi 132/33 kV T1 transformer was under shut down from 12:16 to 14:57 for 33 kV feeder About 40 MW power interruption occurred under Khulshi S/S
- shiftment work.

About 40 MW power interruption occurred under Khulshi S/S area from 12:16 to 14:57.

- e) Shahjibazar GT-8 & 9 were under shut down at 12:04 & 12:02 for Shahjibazar P/S Commissioning
- work and were synchronized at 18:19 & 20:17 respectively. f) Ashuganj Unit-5 was synchronized at 01:25(19/06/2016).
- g) Ghorasal Unit-1 tripped at 23:24 due to problem with condenser and was switched on
- at 02:00(19/06/2016).
- h) Sylhet 132/33 kV T2 transformer was under shut down from 06:42 to 08:03 (19/06/2016) due to red

hot at 132 kV R-phase bus isolator.

Sub Divisional Engineer Network Operation Division

Executive Engineer
Network Operation Division

Superintendent Engineer Load Dispatch Circle