I	, ,	NATIONAL	OMPANY OF BA LOAD DESPAT DAILY REPOR	CH CENT	ER			
Till now the max	imum generation is : -	8942 MW	_		21:00		porting Date 25-Jun-16	: 27-Jun-16
The Summary of	Yesterday's 26-Jun	-16 Generation & De	emand			Today's Actual Min Ge	n. & Probab	le Gen. & Demand
Day Peak Generati	on : 7889		-	Hour :	11:00	Min. Gen. at	7:00	7203
Evening Peak Gene				Hour:	21:00	Max Generation		8781
E.P. Demand (at ge				Hour : Hour :	21:00 21:00	Max Demand (Evening)	: d) ·	9000 219
Maximum Generat Total Gen. (MKWH				Hour .	90.65%	Shortage(Generation en Load Shed	u).	202
Total Gen. (WKWI)	. 100.		RT THROUGH EAST-WEST	NTERCONNECTO		Luau Sileu		202
Export from East or	rid to West grid :- Maximu		-200	IN LINGUINEO I C		18:30	Energy	y 7.867
	rid to East grid :- Maximu				MW at	-	Energy	
	Water Level of Kaptai La							,
Actual	85.20 Ft.(MSL),			Rule curve	: 82.92	Ft.(MSL)		
Gas Consumed :	Total 1075.	I1 MMCFD.			Oil Consume		HSD : FO :	
Cost of the Consun	and Eurol (BDE		Tk76,899,345					
Lost of the Consun		Gas : Goal :	Tk/6,899,345 Tk15,819,917		Oil	Tk570,640,906	Total	· TLEE2 260 160
		oai .	1815,019,917		Oil	18370,040,900	Total	: Tk663,360,169
	Load Shed	ding & Other Information	<u>1</u>					
Area	Yesterday					Today		
	·		Estimated Demand (S/S en	i)		Estimated Shedding (S/S		Rates of Shedding
	MW		MW				MW	(On Estimated Demand)
Dhaka	53 19:35-2		3388				77	-
Chittagong Area	29 19:35-2		948				22	-
Khulna Area Rajshahi Area	36 19:35-2 29 19:35-2		965 930				24 23	-
Rajshahi Area Comilla Area	29 19:35-2 25 19:35-2		930 698				23 18	-
Mymensingh Area	19 19:35-2		530				18	-
Sylhet Area	- 0:00		341				7	
Barisal Area	6 19:35-2		186				5	_
Rangpur Area	17 19:35-2		515				12	-
otal	214		8501				202	
	Planned Shut- Down				2) Ashugan 3) Ashugan 4) Khulna S 5) Kaptai Hy 6) Haripur G 7 Bhola GT	ST: Unit-6 (18/07/2010 ST: Unit-1 (12/09/2015 CCPP 225 MW T 110 MW (04/11/2014 dro: Unit-5,)	a 60MW (23/11/15)
	Additional Information	of Machines, lines, Inter	ruption / Forced Load shed e	tc.				
ı	Additional Information	of Machines, lines, Inter	ruption / Forced Load shed e	tc.		Comments	on Powe	er Interruption
a) Ghorasal-Tong 11:56 & 16:56 b) Tongi-Kabirpur at 12:16.	Description i 230 kV Ckt-1 & 2 tripp respectively. 132 kV Ckt-2 tripped a	ed at 11:20 showing dis	it.relay and were switched or ay at Kabirpur end and was	at switched on	About 550 N	Comments MW power interruption o Kabirpur,Manikganj S/S	ccurred und	der Tongi,NewTongi,
a) Ghorasal-Tong 11:56 & 16:56 b) Tongi-Kabirpur at 12:16. c) Kabirpur-Manik d) Joydebpur-Gho on at 11:28.	Description i 230 kV Ckt-1 & 2 tripp respectively. 132 kV Ckt-2 tripped a gganj 132 kV Ckt-1 tripp prasal 132 kV Ckt-1 & 2	ed at 11:20 showing dist t 11:20 showing dist.rel ed at 11:20 showing dist tripped at 11:20 showir	it.relay and were switched or ay at Kabirpur end and was t.relay and was switched on g differential E/F relay and v	at switched on at 12:17.	About 550 N	/IW power interruption o	ccurred und	der Tongi,NewTongi,
a) Ghorasal-Tong 11:56 & 16:56 b) Tongi-Kabirpur at 12:16. c) Kabirpur-Manik d) Joydebpur-Gho on at 11:28. e) Joydebpur-Gho on at 12:09. f) Baghabari 100	Description i 230 kV Ckt-1 & 2 tripp respectively. 132 kV Ckt-2 tripped a ganj 132 kV Ckt-1 tripp rasal 132 kV Ckt-1 & 2 crasal 132 kV Ckt-1 & 2 crasal 132 kV Ckt-1 & 2 crasal 132 kV Ckt-1 & 2 kV Ckt	ed at 11:20 showing distrel t 11:20 showing distrel ad at 11:20 showing distripped at 11:20 showin again tripped at 11:39 se to exhaust temperatur	at.relay and were switched or ay at Kabirpur end and was t.relay and was switched on by differential E/F relay and v showing the same relay and the high and was synchronize	at 12:17. vere switched were switched d at 17:40.	About 550 N	/IW power interruption o	ccurred und	der Tongi,NewTongi,
a) Ghorasal-Tong 11:56 & 16:56 b) Tongi-Kabirpur at 12:16. c) Kabirpur-Manik d) Joydebpur-Gho on at 11:28. e) Joydebpur-Gho on at 12:09. f) Bgahabari 100 Comilla (S)-Su wire from this I	Description i 230 kV Ckt-1 & 2 tripp respectively. 132 kV Ckt-2 tripped a ganj 132 kV Ckt-1 tripp rasal 132 kV Ckt-1 & 2 corasal 132 kV Ckt-1 & 2 corasal 132 kV Ckt-1 & 2 kV Ckt-1 & 2 corasal 132	ed at 11:20 showing distrel ed at 11:20 showing distriped at 11:20 showing dis tripped at 11:20 showin again tripped at 11:39 s e to exhaust temperatur tt-1 was under shut dow	t.t.relay and were switched or ay at Kabirpur end and was t.relay and was switched on g differential E/F relay and v showing the same relay and the high and was synchronize on from 14:50 to 16:05 for rei	at 12:17. vere switched were switched d at 17:40.	About 550 N	/IW power interruption o	ccurred und	der Tongi,NewTongi,
a) Ghorasal-Tong 11:56 & 16:56 b) Tongi-Kabirpur at 12:16. c) Kabirpur-Manik d) Joydebpur-Gho on at 11:28. e) Joydebpur-Gho on at 12:09. f) Baghabari 100 g) Comilla (S)-Su wirel from this I) h) After maintena n) Ashuganj ST U i) Kulaura-Fench.	Description i 230 kV Ckt-1 & 2 tripp respectively. 132 kV Ckt-2 tripped a ganj 132 kV Ckt-1 tripp rasal 132 kV Ckt-1 & 2 corasal 132 kV Ckt-1 & 2 corasal 132 kV Ckt-1 & 2 corasal 132 kV Ckt-1 & 2 kV Ckt-1 & 2 corasal 132 kV Ckt-1 & 2 corasal 132 kV Ckt-1 & 2 kV Ckt-1 & 2 corasal 132 kV Ckt-1 & 2 corasal 132 kV Ckt-1 & 2 corasal 132 kV Ckt-1 tripp d at 20-47 du ganj 132 kV Ckt-1 tripp d 12 corasal 132 kV Ckt-1 tripp	ed at 11:20 showing dist.rel ed at 11:20 showing dist.rel ed at 11:20 showing dis tripped at 11:20 showin again tripped at 11:39 s e to exhaust temperatur tt-1 was under shut dow s synchronized at 16:44 e to generator internal f	t.t.relay and were switched or ay at Kabirpur end and was t.relay and was switched on gg differential E/F relay and v showing the same relay and the high and was synchronize on from 14:50 to 16:05 for rei 4. ault.	at 12:17. at 12:17. are switched were switched d at 17:40. moving	About 550 N	/IW power interruption o	ccurred und	der Tongi,NewTongi,
a) Ghorasal-Tong 11:56 & 16:56 b) Tongi-Kabirpur at 12:16. c) Kabirpur-Manik d) Joydebpur-Gho on at 11:28. e) Joydebpur-Gho on at 12:09. f) Baghabari 100 g) Comilla (S)-Su wire from this l) After maintena i) Ashugani ST Ui j) Kulaura-Fenchu burst at Kulaur Sub Divisi	Description i 230 kV Ckt-1 & 2 tripp respectively. 132 kV Ckt-2 tripped a ganj 132 kV Ckt-1 tripp rasal 132 kV Ckt-1 & 2 corasal 132 kV Ckt-1 & 2 corasal 132 kV Ckt-1 & 2 corasal 132 kV Ckt-1 & 2 kV Ckt-1 & 2 corasal 132 kV Ckt-1 & 2 corasal 132 kV Ckt-1 & 2 kV Ckt-1 & 2 corasal 132 kV Ckt-1 & 2 corasal 132 kV Ckt-1 & 2 corasal 132 kV Ckt-1 tripp d at 20-47 du ganj 132 kV Ckt-1 tripp d 12 corasal 132 kV Ckt-1 tripp	ed at 11:20 showing dist.rel at 11:20 showing dist.rel at 11:20 showing distripped at 11:20 showin again tripped at 11:39 se to exhaust temperatur tt-1 was under shut dow as synchronized at 16:4 e to generator internal f	t.t.relay and were switched or ay at Kabirpur end and was t.relay and was switched on gg differential E/F relay and v showing the same relay and the high and was synchronize on from 14:50 to 16:05 for rei 4. ault.	at 12:17. at 12:17. are switched were switched d at 17:40. moving Bus-A PT	About 550 N Joydebpur, ł	/IW power interruption o	ccurred und	der Tongi,NewTongi,