POWER GRID COMPANY OF BANGLADESH LTD.

NATIONAL LOAD DESPATCH CENTER DAILY REPORT Reporting Date : 17-Jul-16 Till now the maximum generation is:The Summary of Yesterday: 16-Jul-16 9036 MW 21:00 Hrs Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand 12:00 5722 Ηοι Day Peak Generation 6621.0 MW Evening Peak Generation Max Generation E.P. Demand (at gen end) : 21:00 7990.0 MW Ηοι Max Demand (Evening) 8500 Maximum Generation 7990.0 MW Ηοι 21:00 Reserve (Generation end) 423 System L/ Factor Total Gen. (MKWH) 162.0 84.50% Load Shed EXPORT/ IMPORT THROUGH EAST-WEST INTERCONNECTOR Export from East grid to West grid :- Maximum MW at 10:00 7.867 -280 Energy Import from West grid to East grid :- Maximum MW Energy Water Level of Kaptai Lake at 17-Jul-16 95.34 Ft.(MSL), Rule curve : 86.56 Ft.(MSL) Actual : Gas Consumed: Total 1036.21 MMCFD. Oil Consumed (PDB): HSD FO Cost of the Consumed Fuel (PI Gas Tk62.706.939 Tk15,233,996 : Tk308,516,688 Total : Tk386,457,623 Coal Load Shedding & Other Information Area Yesterday Today Estimated Demand (S/S end) Estimated Shedding (S/S end) Rates of Shedding MW MW MW (On Estimated Demand) Dhaka Chittagong Area Khulna Area 0:00 887 0:00 897 Rajshahi Area 0:00 867 Comilla Area 0:00 653 Mymensingh Area 0:00 496 Sylhet Area 0:00 317 Rangpur Area 0.00 483 Total 7945 Information of the Generating Units under shut down Planned Shut- Down 1) Ghorasal ST: Unit-6 (18/07/2010) 2) Ashuganj ST: Unit-1 (12/09/2015) 9) Sikalbaha 60MW (23/11/15) Nil 10) Siddhirganj ST (6/07/2016) 3) Ashuganj CCPP 225 MW 11) Ashuganj GT-2 4) Khulna ST 110 MW (04/11/2014) 12) Ghorasal ST: Unit-4 5) Kaptai Hvdro: Unit-5. 13) Saidpur GT 6) Haripur GT-1,2& 3 14) Ashuganj ST: Unit-3 7 Bhola GT-2 8) Meghnaghat 450 MW(24/04/2016) Additional Information of Machines, lines, Interruption / Forced Load shed etc. Description Comments on Power Interruption a) Jessore-Jhenaidah 132 kV Ckt-2 was under shut down from 08:50 to 10:47 due to armouring at b) Ashuganj unit-3 w as shut down at 11:55 due to condenser tube leakage. c) Sikalbaha 150 MW GT tripped at 12:47 and synchronized at 16:37. d) Bagerhat-Bhandaria 132 kV Ckt tripped at 13:17 showing Dist.S-phase, E/F at Bagerhat end & Dist at Bhandaria end. e) Haripur-Rahim steel 132 kV Ckt tripped at 14:45 from Haripur end showing Dist. Z1, A-phase. At the same time Summit Madanganj unit-1&2, Meghnaghat IEL, Dutch bangla, NEPC, Sinha, Desh (Approximately 285 MW) got tripped. f) Haripur-Rampura 230 kV Ckt-2 was tripped at 14:45 from Haripur end showing Dir. E/F and was switched on at 14:53. g) After maintenance Sylhet 150 MW was synchronized at 14:53. h) Ullon CB 926B and 929 B opened at 05:12 (17/07/2016) and CB 917 B closed at 06:48(17/07/2016) due to red hot at Y phase DS no 930M.

> Sub Divisional Engineer **Network Operation Division**

Executive Engineer Network Operation Division Superintendent Engineer Load Dispatch Circle