POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT Reporting Date : 24-Jul-16 Till now the maximum generation is : The Summary of Yesterday' 23-Jul-16 9036 MW 21:00 Hrs The Summary of Yesterday' Today's Actual Min Gen. & Probable Gen. & Demand Generation & Demand Hour 11:00 6086 Day Peak Generation 6585.0 MW Min. Gen. at 7:00 Evening Peak Generation 8259.0 Max Generation E.P. Demand (at gen end) : 8259.0 MW Hour 21:00 Max Demand (Evening) 8500 Maximum Generation 8263.0 MW Hour 22:00 Reserve (Generation end) 20 Total Gen. (MKWH) System L/ Factor 164.0 82.72% Load Shed 0 EXPORT/ IMPORT THROUGH EAST-WEST INTERCONNECTO Export from East grid to West grid :- Maximum 7.867 -160 MW at 16:00 Energy Import from West grid to East grid :- Maximum Energy Water Level of Kaptai Lake at 24-Jul-16 95.09 Ft.(MSL), Rule curve : 87.68 Ft.(MSL) Actual : Gas Consumed: Total 978.21 MMCFD. Oil Consumed (PDB): HSD FO Cost of the Consumed Fuel (PI Gas Tk71.104.572 Tk15,194,936 : Tk399,308,120 Total : Tk485,607,628 Coal Load Shedding & Other Information Area Today Yesterday Estimated Demand (S/S end) Estimated Shedding (S/S end) Rates of Shedding MW MW MW (On Estimated Demand) Chittagong Area Khulna Area 0:00 879 0:00 889 Rajshahi Area 0:00 859 648 Comilla Area 0:00 Mymensingh Area 0:00 493 Sylhet Area 0:00 314 0:00 172 Rangpur Area 0.00 479 Total 7878 Information of the Generating Units under shut down. Planned Shut- Down Forced Shut-Down 1) Ghorasal ST: Unit-6 (18/07/2010) 9) Sikalbaha 60MW (23/11/15) 2) Ashugani ST: Unit-1.2.3 10) Ghorasal ST: Unit-4 Nil 3) Ashuganj CCPP 225 MW 11) Siddhirgonj ST 4) Khulna ST 110 MW (04/11/2014) 12) Haripur 412 MW (22/07/16) 5) Kaptai Hvdro: Unit-5. 13) Sylhet 150 MW GT 6) Haripur GT-2& 3 14) Sylhet 20 MW GT 7 Bhola GT-2 15) Baghabari GT 71MW 8) Meghnaghat 450 MW(24/04/2016) Additional Information of Machines, lines, Interruption / Forced Load shed etc. Description Comments on Power Interruption a) Chandpur-Chow mohani 132 kV Ckt-1 & 2 w as shut down at 10:02 for bring down a mentally disabled man from tower and were switched on at 13:52 & 11:52 respectively. b) Siddirganj-210 MW ST tripped at 10:21 showing auxiliary problem. c) Rampura-Bashundhara 132 kV Ckt-1 tripped at 12:00 showing protection trip at Rampura end and was switched on at 12:24 d) Bottail 132/33 kV T-1 & T-2 transformers tripped at 13:30 showing E/F relay and was About 68 MW power interruption occurred under Bottail S/S sw itched on at 13:33. area from 13:30 to 13:33. e) Ashuganj #3 tripped at 13:54 due to problem at feed water valve control. f) Aminbazar-Savar 132 kV Ckt-2 tripped at 15:56 showing E/F relay and was switched on at 16:16. g) Tongi 230/132 kV T01 transformer tripped at 16:50 due to OLTC problem and was switched h) Munsiganj 132/33 kV T-2 transformer tripped at 16:55 showing differential relay and was About 56 MW power interruption occurred under MunsiganjS/S area from 16:55 to 23:12. switched on at 23:12.

Sub Divisional Engineer Network Operation Division Executive Engineer
Network Operation Division

Superintendent Engineer Load Dispatch Circle