POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT

Reporting Date : 12-Aug-16 Till now the maximum generation is : The Summary of Yesterday: 11-Aug-16 9036 MW 21:00 Hrs 30-Jun-16 The Summary of Yesterday Today's Actual Min Gen. & Probable Gen. & Demand Generation & Demand 12:00 Day Peak Generation 6931.0 MW Hour Min. Gen. at 7:00 Evening Peak Generation Max Generation 8597

E.P. Demand (at gen end): 8165.0 MW Hour 21:00 Max Demand (Evening) Maximum Generation 8165.0 MW 21:00 Reserve (Generation end) Total Gen. (MKWH) System L/ Factor 161.3 82.29% Load Shed EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

-170 Import from West grid to East grid :- Maximum MW at Water Level of Kaptai Lake at 12-Aug-16

95.40 Ft.(MSL), Rule curve : 92.52 Ft.(MSL) Actual :

> Oil Consumed (PDB): HSD

> > : Tk383,457,512

MW

at 7:00

FO

Energy

Energy

Total : Tk460,584,245

8200

397

0

7.867

Cost of the Consumed Fuel (PI Gas Tk69.978.476

995.29

Tk7,148,257 Coal

Load Shedding & Other Information

MMCFD.

Area	Yesterday			Today	
			Estimated Demand (S/S end)	Estimated Shedding (S/S end)	Rates of Shedding
	MW		MW	MW	(On Estimated Demand)
Dhaka	-	0:00	3045	-	-
Chittagong Area	-	0:00	851	-	-
Khulna Area	-	0:00	857	-	-
Rajshahi Area	-	0:00	830	-	-
Comilla Area	-	0:00	629	-	-
Mymensingh Area	-	0:00	478	-	-
Sylhet Area	-	0:00	303	-	-
Barisal Area	-	0:00	167	-	-
Rangpur Area	-	0:00	464	-	-
Total	0		7624	0	

Information of the Generating Units under shut down.

Planned Shut- Down

Nil

Export from East grid to West grid :- Maximum

Gas Consumed: Total

1) Ghorasal ST: Unit-6 (18/07/201(10) Ghorasal ST: Unit-4

2) Ashugani ST: Unit-1

11) Chittagong ST: Unit-2

3) Ashuganj CCPP 225 MW 12) Shahazibazar 50 MW 4) Khulna ST 110 MW (04/11/2014 13) Ashuganj ST: Unit-4

5) Kaptai Hvdro: Unit-5 6) Haripur GT-3.

7 Bhola GT-2

8) Meghnaghat 450 MW(24/04/2016)

9) Barapukuria ST: Unit-1

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description

Comments on Power Interruption

- a) Noapara 132/33 kV T4 transformer was shut down at 09:46 due to 33 kV side SF6 CB problem and it is still under maintenance.
- b) Ashuganj 450 MW GT was shut down at 16:17 due to diverter damper problem.
- c) Ghorasal Max GT-1 was shut down at 01:12(12/08/2016) due to 230 kV PT replacement work.
- d) Ashuganj 132 kV Bus -2 was shut down at 07:40 (12/08/2016) due to loops replacement & tightening clamp About 90 MW power interruption has been runingunder Ashuganj S/S & Mymenshing Zone (except Tangail) since 07:40 to till. Ashuganj-Shahazibazar Ckt-3 & Ashuganj-Kishorganj Ckt-2 were under shut down at the same time.
- e) Daudkandi 132 kV Bus was shut down at 07:22(12/08/2016) due to red hot maintenance and was switcher About 20 MW power interruption occurred under Daudkandi S/S area at 11:08(12/08/2016). from 07:22 to 11:08(12/08/2016).

Sub Divisional Engineer **Network Operation Division**

Executive Engineer Network Operation Division Superintendent Engineer **Load Dispatch Circle**