## POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT Reporting Date: 19-Sep-16 9036 MW 30-Jun-16 Till now the maximum generation is:-The Summary of Yesterday's Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand Day Peak Generation 6772 N N/M// Hour 12:00 Min. Gen. at 7:00 6182 Evening Peak Generation 8082.0 MW Hour 20:00 Max Generation 9270 8300.0 E.P. Demand (at gen end) : MW Max Demand (Evening) : 8700 Hour 20:00 Maximum Generation MW 20:00 Reserve (Generation end) 8082.0 570 Total Gen. (MKWH) 166.7 System L/ Factor 85.93% oad Shed 0 EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR Export from East grid to West grid :- Maximum 7 867 -310 MW 17:00 Energy Import from West grid to East grid :- Maximum MW Energy Water Level of Kaptai Lake at 6:00, 19-Sep-16 106.21 Ft.(MSL) Rule curve : 103.14 Ft.( MSL ) Actual 985.15 MMCFD. Gas Consumed : Oil Consumed (PDB): Total HSD FO Cost of the Consumed Fuel (PDB+P) Gas Tk70,023,927 Coal Tk15,026,969 : Tk427,420,151 Total : Tk512,471,048 Load Shedding & Other Information Area Yesterday Today Estimated Demand (S/S end) Rates of Shedding Estimated Shedding (S/S end) (On Estimated Demand) MW MW 18:30-22:30 Dhaka 52 3208 26 18:30-22:31 897 Chittagong Area 18:30-22:31 34 909 Rajshahi Area 27 18:30-22:32 877 Comilla Area 17 18:30-22:32 660 Mymensingh Area 11 18:30-22:33 502 10 Sylhet Area 18:30-22:33 322 Barisal Area 5 18:30-22:35 175 18:30-22:35 Rangpur Area 14 488 Total 140 8038 Information of the Generating Units under shut down. Planned Shut- Dow n Forced Shut- Down 1) Ghorasal ST: Unit-6 (18/07/2010 10) Chandpur CCPP ST 2) Chittagong ST: Unit-1 11) Sylhet 20 MW GT 3) Ashuganj CCPP 225 MW 12) Haripur 412 MW CCPP 4) Khulna ST 110 MW (04/11/2014 13) Ashuganj ST: Unit- 1 & 3 14) Ghorasal ST: Unit-3 5) Kaptai Hydro: Unit-5 15) Ghorasal ST: Unit-5 6) Ashuganj GT2 7) Bhola GT-2 & ST. 8) Baghabari 100 MW 9)) Haripur SBU GT-1,2,3 Additional Information of Machines, lines, Interruption / Forced Load shed etc. Description **Comments on Power Interruption** a) Bogra-Barapukuria 230 kV Ckt-2 tripped at 10:08 from both end showing dist BN at Bogra end & B phase at Barapukuria and was switched on at 10:33. b) Siddhirganj GT1 & GT2 tripped at 11:18 due to gas buster problem and was synchronized at 12:04. c) After maintenance Baghabari 71 MW was synchronized at 15:54. d) Meghnaghat Summit GT-1 was synchronized at 16:15. e) Meghnaghat Summit ST was synchronized at 20:45. f) Barapukuria-Saidpur 132 kV Ckt-1,2 tripped at 23:18 from both end showing dist ABC at Saidpur end & O/C E/F relay at Barapukuria end and were switched on at 23:40, Again tripped at 02:33(19/9/16) showing same relay and ware switched on at 02:34. g) Jamalpur-Sherpur 132 kV Ckt-1,2 tripped at 22:22 from both end showing dist B,Z1 at Jamalpur About 22 MW power interruption occurred under Sherpur S/S areas B-phase .E/F relay at Sherpur end and were switched on at 23:26. from 22:22 to 23:26. h) Munshiganj 132/33 kV T1 & T2 transformer tripped at 02:35 from 33 kV side due to fault at 33 kAbout 90 MW power interruption occurred under Munshiganj S/S areas and were switched on at 03:02. from 02:35 to 03:02(19/9/16). i) After maintenance Ashuganj #3 was synchronized at 03:33.

**Executive Engineer** 

**Network Operation Division** 

Superintendent Engineer

**Load Dispatch Circle** 

Page 1 of 7

Sub Divisional Engineer

**Network Operation Division**