POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT Reporting Date : 26-Sep-16 Till now the maximum generation is:The Summary of Yesterday: 25-Sep-16 9036 MW Hrs 30-Jun-16 The Summary of Yesterday Today's Actual Min Gen. & Probable Gen. & Demand Generation & Demand 12:00 Hour 6174 7032.0 Evening Peak Generation Hour Max Generation Max Demand (Evening) E.P. Demand (at gen end) : 8484.0 MW Hour 20:00 9000 Maximum Generation 8484.0 MW Hour 20:00 Reserve (Generation end) 347 Total Gen. (MKWH) System L/ Factor 176.0 86.45% Load Shed 0 EXPORT/IMPORT THROUGH EAST-WEST INTERCONNECTOR Export from East grid to West grid :- Maximum MW 7.867 -380 at 10:00 Energy Import from West grid to East grid :- Maximum MW Energy Water Level of Kaptai Lake at 26-Sep-16 107.36 Ft.(MSL), 104.80 Ft.(MSL) Actual : Rule curve : Gas Consumed : Total 1051.94 MMCFD. Oil Consumed (PDB): HSD FO Cost of the Consumed Fuel (PI Gas Tk80.499.843 Tk15,429,301 : Tk335,900,216 Total : Tk431,829,360 Coal Load Shedding & Other Information Area Yesterday Today Estimated Demand (S/S end) Estimated Shedding (S/S end) Rates of Shedding MW MW MW (On Estimated Demar Dhaka 0:00 Chittagong Area 0 0:00 935 0:00 Khulna Area 952 Rajshahi Area 0 0:00 917 Comilla Area 0 0:00 687 Mymensingh Are 0 0:00 521 Sylhet Area 0 0:00 337 0:00 182 Rangpur Area ٥ 0.00 508 Total 8383 Information of the Generating Units under shut down. Planned Shut- Down 1) Ghorasal ST: Unit-6 (18/07/2010) 10) Sikalbaha ST 2) Chittagong ST: Unit-1 11) Svlhet 20 MW GT Nil 3) Ashuganj ST: Unit- 1 12) Siddhirgonj GT: Unit-1 4) Khulna ST 110 MW (04/11/2014) 13) Meghnaghat 450 MW 5) Kaptai Hvdro: Unit-5 6) Ashuganj GT2 7) Bhola GT-2 & ST. 8) Baghabari 100 MW 9)) Haripur SBU GT-1 & 3 Additional Information of Machines, lines, Interruption / Forced Load shed etc. Description Comments on Power Interruption a) Noapara-Khulna© 132 kV Ckt-1 was shut down at 08:28 for breaker replacement. b) Siddhirganj Peaking GT-1 w as shut down at 11:09 due to gas pressure low. c) Rampura-Mathertak 132 kV cable was shut down from 09:30 to for maintenance work. About 40 MW pow er interruption occurred under Kishoreganj S/S area d) Kishoreganj 132/33 kV T2 transformer w as under shut down from 10:31 to 11:02 for replace from 010:31 to 11:02. 33 kV breaker of Bhairab feeder. e) Kaptai unit-4 was shut down at 14:53 due to problem at DC motor and was synchronized at 17:46. f) Faridpur 132/33 kV T2 transformer tripped at 21:45 showing restricted E/F at 132 kV side and CB tripped at 33 kV side and was switched on at 21:48.. g) Kabirpur-Tangail 132 kV Ckt-1 & 2 w as shut down at 06:09 (26/09/2016) due to Kaliakoir 132 kV h) Tangail 132 kV main bus was shut down at 06:26 (26/09/2016) due to GND project work. i) Faridpur 132/33 kV T1 & T2 transformers tripped at 05:14 from both sides of T2 & 33 kV side of T1 About 90 MW pow er interruption occurred under Faridpur S/S area showing O/C & restricted E/F at 33 kV sides due to 33 kV Jhiltali feeder fault and was switched on at 05:20. from 05:14 to 05:20(26/09/2016), j) Meghnaghat 450 MW CCPP was shut down at 23:54 due to maintenance.

Executive Engineer

Network Operation Division

Superintendent Engineer

Load Dispatch Circle

Sub Divisional Engineer

Network Operation Division