POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT Reporting Date 2-Oct-16 Till now the maximum generation is: 9036 MW 21:00 The Summary of Yester Day Peak Generation Evening Peak Generation Generation & Demand MW MW | Today's Actual Min Gen. & Probable Gen. & Deman | Min. Gen. at | 7:00 | 6975 | Max Generation | : 8900 | 1-Oct-16 7395.0 8570.0 12:00 E.P. Demand (at gen end) 8800.0 MW 20:00 Max Demand (Evening) 8900 Maximum Generation 8606.0 MW 21:00 Reserve (Generation end)) System L/ Factor : 88.11% EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR 182.0 Load Shed Export from East grid to West grid :- Maxim MW a 17:00 7.867 Import from West grid to East grid :- Maxim Water Level of Kaptai Lak 2-Oct-16 Actual: 108.44 Ft.(MSL) 106.09 Ft.(MSL) Gas Consumed Total 994 35 MMCFD Oil Consumed (PDB) FO Tk15, 585, 549 : Tk518, 392,907 Total : Tk611, 146,468 Load Shedding & Other Information Estimated Shedding (S/S end) Estimated Demand (S/S end) Rates of Shedding (On Estimated Dema 76 22 Chittagong Area 0:00 903 Khulna Area 27 0:00 916 Rajshahi Area 26 14 13 12 0:00 883 Comilla Area 0:00 665 0:00 505 Sylhet Area 0:00 324 Barisal Area 0:00 176 Rangpur Area 13 Total 207 8092 Information of the Generating Units under shut down Planned Shut- Down Forced Shut- Down 1) Ghorasal ST: Unit-6 (1877 17) Sylhet 20 MW GT 2) Chittagong ST: Unit-1 11) Sylhet 20 MW GT 3) Ashuganj ST: Unit-1 21) Siddhirgonj GT: Unit-1 4) Khulna ST 110 MW (04/1 13) Haripur EGCB 412 MW 14) Ghorasal Unit-5 10 MW GT 5) Kaptai Hydro: Unit-5 6) Ashuganj GT2 15) Sylhet 150 MW GT 7) Bhola GT-2 & ST. 8) Baghabari 100 MW 9)) Haripur SBU GT-3 Additional Information of Machines, lines, Interruption / Forced Load shed et Description Comments on Power Interruption a) Ashuganj-Kishorganj 132 kV Ckt-1 & 2 tripped at 08:16 showing O/C relay and were swit About 50 MW power interruption occurred under Kishorganj & 08:26 respectively. from 08:16 to 08:24. b) Sylhet 132/33 kV T-4 transformer was shut down at 09:40 for red hot maintenance at 33 | About 24 MW power interruption occurred under Sylhet S/S a was switched on at 10:13. from 09:40 to 10:13. c) Saidpur 33 kV Bus partial was shut down at 09:30 for red hot maintenance at 33 kV isolat About 40 MW power interruption occurred under Saidpur S/S and was switched on at 10:08. d) Ashuganj Network-Ashuganj (South) 230 kV Ckt-2 tripped at 10:40 showing general trip. e) Haripur EGCB-412 MW was forced shut down at 09:14 for gas line excessive dust. f) Bhola-194 MW GT-1 & ST were synchronized at 08:22 & 11:36 respectively. g) Bottail 33 k/ Bus under T-1 transformer was shut down at 12:10 for snapped loop of trans About 25 MW power interruption occurred under Bottail S/S a switched on at 14:44. h) Barisal 132/33 kV T-2 transformer was shut down at 12:35 for red hot maintenance at Bus isolator 33 kV end and was switched on at 14:25. Maniknagar 230/132 kV TR-1 transformer was shut down at 11:56 for major inspection and was switched on at 13:09 j) Sirajganj 132/33 kV T-3 transformer was shut down at 11:06 for red hot maintenance at 3 About 11 MW power interruption occurred under Sirajganj S/ from 11:06 to 13:08. was switched on at 13:08. k) Raozan #1 was shut down at 16:45 for problem at unit breaker and was synchronized on at 17:42. I) Ashuganj #2 tripped at 17:50 showing under excitation. m) Shahjibazar-330 MW GT was synchronized at 08:18 (2/10/16).

Executive Engineer

Network Operation Division

Superintendent Engineer

Load Dispatch Circle

Sub Divisional Engineer

Network Operation Division