POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT Reporting Date 4-Oct-16 Till now the maximum generation is: 9036 MW 21:00 Hrs Generation & Demand MW MW | Today's Actual Min Gen. & Probable Gen. & Dem: | Min. Gen. at 7:00 6860 | | Max Generation : 9050 | 10:00 E.P. Demand (at gen end) 8900.0 MW 20:00 Max Demand (Evening) 9000 Maximum Generation 8692.0 MW 21:00 Reserve (Generation end) 50 System L/ Factor : 90.01% EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR 187.8 Load Shed Export from East grid to West grid :- Maxim MM a 17:00 7.867 Import from West grid to East grid :- Maxim Water Level of Kaptai Lake 4-Oct-16 Actual: 108.86 Ft.(MSL), 106.27 Ft.(MSL) Gas Consumed Total 1032 80 MMCFD Oil Consumed (PDB) FO Tk14,491,827 : Tk555,743,392 Total : Tk648,924,389 Load Shedding & Other Information Estimated Shedding (S/S end) Estimated Demand (S/S end) Rates of Shedding (On Estimated Dema Chittagong Area 21 (19:05-22:10) 920 Khulna Area 36 (19:05-22:10) 935 Rajshahi Area (19:05-22:10) Com illa Area 21 (19:05-22:10) 676 (19:05-22:10) 513 (19:05-22:10) 331 Sylhet Area Barisal Area (19:05-22:10) 180 21 (19:05-22:10) 500 Rangpur Area Total 8247 Information of the Generating Units under shut down Planned Shut- Down 1) Ghorasal ST: Unit-6 (18/0 10) Sikalbaha ST 1) Shintagong ST: Unit-1 11) Sylhet 20 MW GT 3) Ashuganj ST: Unit-1,2 12) Haripur EGCB 412 MW 4) Khulna ST 110 MW (04/1 13) Ghorasal Unit-5 5) Sylhet 150 MW GT 6) Ashuganj GT2 7) Bhola GT-2 & ST. 8) Baghabari 100 MW 9)) Haripur SBU GT-3 Additional Information of Machines, lines, Interruption / Forced Load shed et Description Comments on Power Interruption a) After maintenance Ashuganj-Ashuganj (S) 230 kV Ckt-2 was switched on at 08:41. b) Chandpur CCPP GT tripped at 10:52 due to tripping of gas booster and was synchronized at 20:05. c) Ghorasal-Tongi 230 kV Ckt-2 tripped at 11:15 from both ends showing PTAW & PD-3 at Ghorasal end and dist Y-phase at Tongi end and was switched on at 11:46. d) Ghorasal-Joydevpur 132 kV Ckt-1 & 2 tripped at 11:15 from Joydevpur end showing E/F & About 250 MW power interruption occurred under Kabirpur. operated and were switched on at 11:20 Joydevpur & Kodda S/S areas from 11:15 to 11:20. e) Raozan Unit-2 was synchronized at 11:51 f) Ashuganj-Sirajganj 230 kV Ckt-1 tripped at 12:37 from both ends showing gen. trip & 67N at both ends and g) Ashuganj -Comilla(N) 132 kV Ckt-1 tripped at 13:02 from Ashuganj end showing dist C-phase and was switched on at 13:18. h) Dhammondi-Ullon 132 kV Ckt-1 tripped at 13:40 from Ullon end showing O/C relay and w About 95 MW power interruption occurred under Ullon S/S at i) After maintenance Barapukuria Unit-1 was synchronized at 17:14. from 113:40 to 13:54. j) Feni-Hathazari 132 kV Ckt-2 tripped at 23:13 from Feni end showing SOTF dist relay k) Dohazari-Cox'sbazar 132 kV Ckt-1 & 2 tripped at 23:46 from Dohazari end showing dist B About 50 MW power interruption occurred under Cox'sbazar 5/ only and were switched on at 00:01 & 23:56 respectively from 23:46 to 23:56. Tangail 33 kV bus was under shut down from 23:20 to 23:25 due to Modhupur 33 kV feed About 60 MW power interruption occurred under Tangail S/S finger got damaged by heavy flashing. from 23:20 to 23:25. m) Saidpur-Purbasadipur 132 kV Ckt-1 was under shut down from 07:52 to 08:30 (04/10/2016) for red hot maintenance at Saidour end . n) Saidpur-Purbasadipur 132 kV Ckt-2 tripped at 07:52 (04/10/2016) due to phase discordar About 30 MW power interruption occurred under Saidpur S/S from 07:52 to 07:54(04/10/2016).

Sub Divisional Engineer Network Operation Division Executive Engineer Network Operation Division Superintendent Engineer Load Dispatch Circle