POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT 10-Oct-16 Reporting Date Till now the maximum generation is 9036 MW The Summary of Yest 9-Oct-16 Generation Day Peak Generation 7388.0 MW 21:00 Hrs Generation & Demand Today's Actual Min Gen. & Probable Gen. & Dem Min. Gen. at 7:00 6433 The Summary of Yest Day Peak Generation 11:00 Evening Peak Generation 8864.0 MW 19:30 Max Generation 9043 E.P. Demand (at gen en Maximum Generation Max Demand (Evening) : Reserve (Generation end) 9000 8864.0 MW 19:30 8864.0 MW 19:30 86.95% Load Shed NECTOR ε 17:00 7.867 Energy MW MW Rule curve: 106.82 Ft.(MSL) Gas Consumed Total 1073.19 MMCFD. Oil Consumed (PDB): HSD FO Cost of the Consumed F Gas Coal Tk82.031.395 Tk15,546,485 : Tk459,827,091 Total : Tk557,404,971 Load Shedding & Other Information Today Estimated Shedding (S/S en Rates of Shedding MW (On Estimated Dema Area Yesterday Estimated Demand (S/S end) MW (On Estimated Deman 3316 Dhaka 0:00 0 0 0 Chittagong A Khulna Area 0:00 927 943 908 681 517 Rajshahi Area 0 0:00 Comilla Area Mymensingh 0:00 334 181 504 Sylhet Area Barisal Area 0 0:00 Rangpur Area 0 0:00 Total 8311 Information of the Generating Units under shut down. Planned Shut- Down Forced Shut-Down Nil 5) Ghorasal Unit-5 6) Ashuganj GT2 7) Bhola GT-2 & ST. 8) Baghabari 100 MW 9)) Haripur SBU GT- 3 Additional Information of Machines, lines, Interruption / Forced Load shed etc. Description C a) Bogra-Natore 132 kV Ckt-2 was under shut down from 11:13 to 20:05 due to strand maintenance at Bogra S/S Comments on Power Interruption b) Bogra-Bogra New S/S 132 kV Ckt-1 was under shut down from 11:13 to 16:04 due to strand maintenance at Bogra S/S end. c) Rangpur 132/33 kV T2 transformer was under shut down from 08:55 to 11:30 due to A/M. d) Chapainawabganj 132/33 kV T2 transformer was under shut down from 09:25 to 15:05 due to A/M. e) Mongla 132/33 kV T1 & T2 transformerstripped at 09:03 from 33 kV side showing instantaneous earth fault relay and were switched on at 09:15. f) Comilla (N)-BSRM 230 kV Ckt-2 tripped at 13:52 from Comilla (N) showing dist.relay and was switched on at 14:10. g) Bogra-Natore 132 kV Ckt-1 was shut down at 16:56 as smoke was coming out from Y-Phase CT at Bogra end h) Ishurdi-Bheramara HVDC 230 kV Ckt-1 was shut down at 05:18 (10/10/2016) for project work. i) Bheramara HVDC 230 kV bus was shut down at 05:22 (10/10/2016) for project work. j) Ishurdi-Bheramara 132 kV Ckt-1 was under shut down from 06:24 to 07:55 (10/10/2016) for red hot maintenance. Sub Divisional Engineer

Executive Engineer

Network Operation Division

Network Operation Division

Superintendent Engineer

Load Dispatch Circle