POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT Reporting Date: 7-Oct-16 Till now the maximum generation is : - 9036 MW 21:00 Hrs on 30-Jun-16 The Summary of Yester Today's Actual Min Gen. & Probable Gen. & Demand Generation & Demand 6-Oct-16 Hour Min. Gen. at Evening Peak Generation 8704.0 MW Hour 21:00 Max Generation 8930 8850.0 E.P. Demand (at gen end) Hour 21:00 Max Demand (Evening) Maximum Generation 8704.0 MW Hour 21:00 Reserve (Generation end) 430 Total Gen. (MKWH) 186.1 System L/ Factor 89.07% Load Shed 0 EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR Export from East grid to West grid :- Maximum 7.867 -290 MW at 16:00 Energy Import from West grid to East grid :- Maximum MW Energy at Water Level of Kaptai Lake at 7-Oct-16 106.54 Ft.(MSL) Actual: Rule curve : 108.51 Ft.(MSL) Gas Consumed: Total 1052.30 MMCFD. Oil Consumed (PDB): HSD : FO Cost of the Consumed Fuel (F Gas Tk79.539.045 Coal Tk14.843.380 : Tk518,279,369 Total: Tk612,661,794 Load Shedding & Other Information Area Yesterday Today Rates of Shedding Estimated Demand (S/S end) Estimated Shedding (S/S end) MW MW MW (On Estimated Demand) 3138 Dhaka 0:00 0 Chittagong Area 0:00 878 Khulna Area 43 (19:15-21:20) Raishahi Area 33 (19:15-21:20) 857 Comilla Area 0 0:00 647 Mymensingh Are 25 (19:15-21:20) 492 Sylhet Area 0 314 0:00 Rarisal Area 0 0:00 172 Rangpur Area 30 (19:15-21:20) 478 Total 131 7863 Information of the Generating Units under shut dow n. Planned Shut- Down Forced Shut- Down 1) Ghorasal ST: Unit-6 (18/07/201(10) Sikalbaha ST 2) Chittagong ST: Unit-1 11) Sylhet 20 MW GT 3) Ashuganj ST: Unit- 1,2 12) Haripur EGCB 412 MW 4) Khulna ST 110 MW (04/11/2014 13) Kaptai Unit-5 5) Ghorasal Unit-5 6) Ashugani GT2 7) Bhola GT-2 & ST. 8) Baghabari 100 MW 9)) Haripur SBU GT- 3 Additional Information of Machines, lines, Interruption / Forced Load shed etc. Comments on Power Interruption Description a) Savar 33 kV Bus was shut down at 08:14 for 33 kV Breaker replacement and was switched on at 09:36. About 86 MW power interruption occurred under Sava S/S areas from 08:14 to 09:36. b) Ashuganj-Shahjibazar 132 kV Ckt-3 tripped at 15:16 due to LA of R-phase burst at Ashuganj end and was switched on at 19:57. c) Ashuganj 132 kV Bus coupler tripped at 15:16 showing O/C relay and was switched on at 15:32.At the same time Ashuganj #3, B.Baria Aggreko & Ashuganj Precision also tripped and were synchronized at 19:57, 15:55 & 16:30 d) Amnura-50 MW tripped at 15:21 showing over voltage and was synchronized at 15:53. e) B.Baria 132/33 kV T-1 transformer was shut down at 20:09 for red hot maintenance at 33 kV Y-phase loop About 40 MW power interruption occurred under B.Baria S/S areas was switched on at 20:52. from 20:09 to 20:52. f) Baghabari-71 MW was shut down at 06:05(7/10/16) for air filter change. g) Bheramara HVDC-Ishurdi 230 kV Ckt-1 was shut down at 06:12(7/10/16) for development work. h) HVDC 230 kV Bus-1 was shut down at 06:16(7/10/16) development work.

i) Natore-Ishurdi 132 kV Ckt-2 w as shut down at 06:43(7/10/16) for A/M.

Sub Divisional Engineer Network Operation Division

Executive Engineer Network Operation Division Superintendent Engineer Load Dispatch Circle